

SABLE ISLAND, NS, Canada

WMO: 730250

Lat: 43.9314N

Lon: 60.0083W

Elev: 63

StdP: 100.58

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.8	-7.1	-13.8	1.1	-7.8	-12.5	1.3	-6.6	21.0	0.4	19.0	-0.2	9.6	300	0.771

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	22.1	20.1	21.2	19.5	20.5	18.9	20.7	21.6	19.9	20.9	19.2	20.2	5.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.1	21.4	19.5	14.3	20.7	18.7	13.7	20.0	59.8	21.8	57.1	21.0	54.8	20.3	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 17.1	15.2	13.4	DB	-11.1	23.4	2.0	1.1	-12.5	24.2	-13.7	24.9	-14.8	25.5	-16.2	26.3	(4)
(5)			WB	-11.8	21.6	1.9	0.9	-13.1	22.2	-14.2	22.7	-15.3	23.3	-16.6	23.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	0.4	-0.4	1.1	4.1	7.5	11.4	16.2	18.5	16.5	12.2	7.8	3.5	(6)
(7)		DBStd	6.98	3.78	3.49	2.92	2.23	2.05	2.16	1.89	1.61	2.45	2.90	3.29	3.55	(7)
(8)		HDD10.0	1433	297	292	277	177	82	10	0	0	0	12	82	203	(8)
(9)		HDD18.3	3704	555	526	536	427	337	207	69	17	63	190	317	461	(9)
(10)		CDD10.0	804	0	0	0	0	4	52	193	263	196	81	14	1	(10)
(11)		CDD18.3	36	0	0	0	0	0	0	4	22	9	0	0	0	(11)
(12)		CDH23.3	3	0	0	0	0	0	0	0	2	1	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.9	8.6	8.4	8.0	7.1	5.9	5.4	4.9	4.9	5.9	7.2	7.7	8.4	(14)
(15)	Precipitation	PrecAvg	1353	133	109	123	97	93	97	97	105	104	122	135	139	(15)
(16)		PrecMax	1839	314	185	216	279	193	270	199	260	299	267	224	300	(16)
(17)		PrecMin	675	9	37	29	26	9	32	5	23	17	18	32	56	(17)
(18)		PrecStd	233	50	41	46	40	45	45	47	47	62	62	49	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	8.9	8.7	10.4	13.9	17.8	22.1	23.4	23.0	19.5	16.0	12.5	(19)
(20)			MCWB	10.0	8.6	8.0	9.3	12.0	15.9	19.7	21.4	21.4	17.8	15.1	12.0	(20)
(21)		2%	DB	8.7	7.3	7.5	9.2	12.5	16.5	20.8	22.4	21.7	18.3	14.7	11.2	(21)
(22)			MCWB	8.3	6.9	6.8	8.3	11.1	14.9	18.9	20.5	19.9	16.6	13.7	10.6	(22)
(23)		5%	DB	7.2	5.9	6.5	8.3	11.6	15.4	19.8	21.7	20.8	17.4	13.7	10.1	(23)
(24)			MCWB	6.7	5.3	5.8	7.4	10.4	14.0	18.3	19.8	19.1	15.8	12.7	9.4	(24)
(25)		10%	DB	5.9	4.5	5.4	7.4	10.6	14.5	19.0	21.0	19.9	16.4	12.7	8.7	(25)
(26)			MCWB	5.1	3.8	4.5	6.4	9.5	13.2	17.7	19.3	18.2	14.8	11.8	7.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	8.2	8.2	9.8	12.7	16.5	20.4	22.0	21.6	18.2	15.3	12.2	(27)
(28)			MCDB	10.2	8.4	8.3	10.2	13.5	17.2	21.6	22.9	22.6	19.0	15.9	12.4	(28)
(29)		2%	WB	8.4	6.6	6.9	8.6	11.6	15.4	19.4	21.0	20.4	17.1	14.0	10.9	(29)
(30)			MCDB	8.6	6.8	7.2	9.0	12.2	16.1	20.4	21.9	21.2	17.9	14.5	11.2	(30)
(31)		5%	WB	6.9	5.2	5.9	7.8	10.6	14.4	18.7	20.3	19.4	16.1	12.9	9.5	(31)
(32)			MCDB	7.2	5.5	6.4	8.2	11.2	15.1	19.5	21.3	20.4	16.9	13.5	10.0	(32)
(33)		10%	WB	5.3	3.7	4.6	6.7	9.6	13.5	18.0	19.7	18.5	15.0	11.9	7.9	(33)
(34)			MCDB	5.8	4.2	5.2	7.3	10.3	14.3	18.8	20.7	19.5	16.2	12.6	8.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	5.0	4.5	4.4	4.4	4.4	4.2	4.2	4.5	4.2	4.5	4.8	(35)
(36)			MCDBR	7.4	7.0	6.2	5.2	5.4	4.9	4.9	4.7	4.7	4.7	5.5	6.5	(36)
(37)			MCWBR	8.3	7.5	6.1	4.7	4.2	3.5	3.5	3.4	3.7	4.5	6.0	7.4	(37)
(38)		5% WB	MCDBR	7.5	6.9	5.9	5.0	5.0	4.2	4.3	4.2	4.2	4.5	5.5	6.6	(38)
(39)			MCWBR	8.4	7.6	6.2	5.1	4.3	3.4	3.3	3.3	3.7	4.8	6.1	7.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.317	0.309	0.327	0.353	0.369	0.387	0.409	0.383	0.357	0.343	0.322	0.305	(40)	
(41)		taud	2.482	2.551	2.514	2.471	2.467	2.439	2.425	2.482	2.534	2.552	2.562	2.547	(41)	
(42)		Ebn at Noon	811	894	916	913	902	884	858	872	872	840	804	795	(42)	
(43)		Edh at Noon	71	79	92	104	108	112	112	102	90	78	66	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.19	2.00	3.37	4.50	5.20	5.54	5.31	5.00	4.20	2.63	1.54	1.02	(44)	
(45)		RadStd	0.11	0.18	0.31	0.35	0.44	0.51	0.43	0.40	0.29	0.21	0.17	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+0.64	N/A	N/A	N/A	N/A	N/A	+18

Nomenclature: See separate page