

GRAND ETANG, NS, Canada

WMO: 730300

Lat: 46.550N

Lon: 61.050W

Elev: 42

StdP: 14.67

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.8	8.2	-3.0	4.7	5.7	1.8	6.0	9.5	58.1	33.5	50.7	31.7	12.4	250	0.763

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	79.9	70.4	77.6	69.3	75.4	68.3	72.2	77.6	70.8	75.9	69.3	74.3	12.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.2	111.3	76.1	68.8	105.9	74.8	67.3	100.6	73.3	36.0	77.8	34.7	76.1	33.5	74.4	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.5	39.0	34.0	DB	0.7	85.3	6.3	2.6	-3.9	87.1	-7.5	88.7	-11.1	90.1	-15.7	92.0	(4)
(5)			WB	0.3	75.2	5.3	1.9	-3.5	76.5	-6.6	77.6	-9.5	78.7	-13.4	80.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.5	26.4	23.9	29.4	38.2	48.0	57.4	67.2	66.9	60.3	50.7	42.2	33.4
	DBStd	16.45	8.75	9.43	8.54	7.52	7.34	7.21	5.32	4.67	6.01	6.30	7.40	7.22
	HDD50	3457	733	732	640	365	129	15	0	0	2	68	258	515
	HDD65	7372	1197	1151	1104	803	528	245	38	32	167	444	685	978
	CDD50	1806	1	0	1	12	68	238	535	525	310	91	23	2
	CDD65	244	0	0	0	0	1	18	107	92	25	1	0	0
	CDH74	776	0	0	0	0	2	47	379	295	51	2	0	0
	CDH80	59	0	0	0	0	0	3	32	21	3	0	0	0
Wind	WSAvg	15.1	19.5	16.1	15.0	13.9	12.1	11.3	11.0	11.8	13.9	17.1	18.8	20.2
Precipitation	PrecAvg	54.7	5.3	4.4	4.0	3.7	3.5	3.5	3.3	4.6	4.6	5.5	5.7	6.4
	PrecMax	62.0	7.8	6.5	6.5	5.7	5.1	7.0	6.3	8.9	12.5	7.7	9.3	13.1
	PrecMin	41.2	3.1	2.1	1.5	1.6	1.6	1.7	1.8	2.5	0.9	2.8	3.9	2.3
	PrecStd	5.1	1.2	1.2	1.4	1.1	0.9	1.2	1.0	1.5	2.5	1.5	1.3	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.9	55.5	58.2	66.5	72.3	78.3	83.2	82.8	79.1	71.6	67.0	59.7
		MCWB	55.5	52.8	52.9	58.7	62.4	68.9	72.2	71.4	71.5	65.8	62.3	56.5
	2%	DB	51.8	48.7	51.8	60.7	67.5	74.8	80.4	79.7	75.0	67.3	63.1	54.4
		MCWB	49.0	46.2	48.2	54.9	58.7	66.0	70.3	70.4	69.2	62.7	59.4	51.7
	5%	DB	43.7	42.1	46.7	55.7	63.8	71.9	78.1	77.3	72.4	63.9	59.1	48.6
		MCWB	41.2	39.4	43.1	50.8	56.2	64.6	69.3	69.3	67.1	59.3	55.6	46.1
	10%	DB	37.4	36.5	41.4	50.2	60.3	68.9	75.8	75.1	70.0	60.6	54.0	43.5
		MCWB	35.2	34.1	37.9	45.3	53.4	62.2	68.6	68.0	65.0	56.3	50.6	41.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.0	53.6	52.2	61.3	64.3	70.9	74.3	73.7	72.7	67.0	62.2	57.1
		MCDB	59.0	55.2	55.3	65.5	70.4	76.6	79.8	79.6	77.7	70.8	65.6	59.7
	2%	WB	48.9	45.8	47.4	56.1	61.0	68.4	72.5	72.0	70.0	63.3	59.4	52.2
		MCDB	51.2	48.0	50.3	60.2	65.9	73.4	78.1	77.2	74.3	66.7	62.9	54.7
	5%	WB	41.4	38.9	42.5	51.7	57.6	65.9	71.1	70.5	67.9	60.0	55.9	47.0
		MCDB	44.0	41.2	45.6	55.8	62.6	70.3	76.4	75.5	72.1	63.6	59.0	49.3
	10%	WB	35.7	33.8	37.8	46.2	54.2	63.1	69.7	69.0	65.6	56.9	51.1	41.9
		MCDB	37.5	35.9	40.7	50.0	59.3	67.8	74.8	73.9	69.6	60.4	53.9	44.1
Mean Daily Temperature Range	5% DB	MDBR	11.5	13.2	13.3	13.4	14.6	14.3	13.7	13.1	12.5	10.7	10.3	9.7
		MCDBR	22.1	21.4	20.8	21.2	19.5	17.2	15.0	15.3	14.5	15.1	17.0	19.3
		MCWBR	21.1	20.2	18.4	17.2	13.8	11.8	9.5	9.9	10.8	12.6	15.7	18.7
	5% WB	MCDBR	22.2	21.5	20.0	21.1	18.0	14.5	13.1	13.5	13.7	14.6	16.8	20.1
		MCWBR	21.3	20.6	18.5	18.4	14.5	11.5	9.4	9.9	11.1	13.0	15.9	19.4
Clear-Sky Solar Irradiance	taub	0.304	0.295	0.330	0.356	0.371	0.390	0.417	0.397	0.364	0.350	0.328	0.305	
	taud	2.307	2.289	2.269	2.373	2.414	2.375	2.354	2.413	2.477	2.473	2.449	2.377	
	Ebn at Noon	247	278	283	285	284	278	268	270	270	256	239	234	
	Edh at Noon	24	30	36	36	36	36	37	38	34	30	26	22	21
All-Sky Solar Radiation	RadAvg	300	543	939	1323	1609	1737	1748	1539	1171	713	362	228	
	RadStd	23	78	105	114	132	157	115	98	96	68	43	19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.79	N/A	N/A	N/A	N/A

Nomenclature: See separate page