

GRAND ETANG, NS, Canada

WMO: 730300

Lat: 46.550N

Lon: 61.050W

Elev: 13

StdP: 101.17

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.7	-13.2	-19.4	0.7	-14.6	-16.8	0.9	-12.5	26.0	0.8	22.7	-0.2	5.6	250	0.763

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	26.6	21.3	25.3	20.7	24.1	20.1	22.4	25.4	21.6	24.4	20.7	23.5	5.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	15.9	24.5	20.4	15.1	23.8	19.6	14.4	23.0	65.8	25.5	62.9	24.5	60.1	23.6	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	17.4	15.2	-17.4	29.6	3.5	1.4	-19.9	30.6	-22.0	31.5	-23.9	32.3	-26.5	33.3		
(5)			-17.6	24.0	2.9	1.1	-19.7	24.7	-21.4	25.4	-23.1	26.0	-25.2	26.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-3.1	-4.5	-1.4	3.5	8.9	14.1	19.6	19.4	15.7	10.4	5.6	0.8	(6)
(7)		DBStd	9.14	4.86	5.24	4.74	4.18	4.08	4.01	2.96	2.60	3.34	3.50	4.11	4.01	(7)
(8)		HDD10.0	1921	407	407	356	203	72	8	0	0	1	38	143	286	(8)
(9)		HDD18.3	4096	665	639	613	446	293	136	21	18	93	247	381	543	(9)
(10)		CDD10.0	1003	1	0	1	7	38	132	297	292	172	51	13	1	(10)
(11)		CDD18.3	136	0	0	0	0	1	10	59	51	14	1	0	0	(11)
(12)		CDH23.3	431	0	0	0	0	1	26	211	164	28	1	0	0	(12)
(13)		CDH26.7	33	0	0	0	0	0	2	18	12	2	0	0	0	(13)
(14)	Wind	WSAvg	6.7	8.7	7.2	6.7	6.2	5.4	5.0	4.9	5.3	6.2	7.6	8.4	9.0	(14)
(15)	Precipitation	PrecAvg	1390	135	111	102	93	90	90	85	116	116	139	146	163	(15)
(16)		PrecMax	1574	197	164	164	145	130	179	160	227	317	196	237	332	(16)
(17)		PrecMin	1047	78	53	37	41	41	44	46	63	24	72	99	59	(17)
(18)		PrecStd	129	31	30	35	28	23	31	26	39	63	37	32	56	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	13.0	14.6	19.1	22.4	25.7	28.5	28.2	26.1	22.0	19.4	15.4	(19)
(20)			MCWB	13.1	11.6	11.6	14.8	16.9	20.5	22.3	21.9	22.0	18.8	16.9	13.6	(20)
(21)		2%	DB	11.0	9.3	11.0	15.9	19.7	23.8	26.9	26.5	23.9	19.6	17.3	12.4	(21)
(22)			MCWB	9.5	7.9	9.0	12.7	14.8	18.9	21.3	21.4	20.7	17.0	15.2	10.9	(22)
(23)		5%	DB	6.5	5.6	8.2	13.2	17.7	22.2	25.6	25.2	22.5	17.7	15.0	9.2	(23)
(24)			MCWB	5.1	4.1	6.2	10.4	13.5	18.1	20.7	20.7	19.5	15.2	13.1	7.8	(24)
(25)		10%	DB	3.0	2.5	5.2	10.1	15.7	20.5	24.4	23.9	21.1	15.9	12.2	6.4	(25)
(26)			MCWB	1.8	1.2	3.3	7.4	11.9	16.8	20.3	20.0	18.3	13.5	10.3	5.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	12.0	11.2	16.3	17.9	21.6	23.5	23.2	22.6	19.4	16.8	14.0	(27)
(28)			MCDWB	15.0	12.9	12.9	18.6	21.3	24.8	26.5	26.4	25.4	21.6	18.7	15.4	(28)
(29)		2%	WB	9.4	7.7	8.5	13.4	16.1	20.2	22.5	22.2	21.1	17.4	15.2	11.2	(29)
(30)			MCDWB	10.6	8.9	10.2	15.7	18.8	23.0	25.6	25.1	23.5	19.3	17.2	12.6	(30)
(31)		5%	WB	5.2	3.8	5.9	11.0	14.2	18.8	21.7	21.4	19.9	15.5	13.3	8.3	(31)
(32)			MCDWB	6.6	5.1	7.5	13.2	17.0	21.3	24.6	24.1	22.3	17.6	15.0	9.6	(32)
(33)		10%	WB	2.1	1.0	3.2	7.9	12.3	17.3	20.9	20.6	18.7	13.8	10.6	5.5	(33)
(34)			MCDWB	3.0	2.2	4.9	10.0	15.1	19.9	23.8	23.3	20.9	15.8	12.2	6.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	7.3	7.4	7.4	8.1	7.9	7.6	7.3	7.0	6.0	5.7	5.4	(35)
(36)			MCDBR	12.3	11.9	11.6	11.8	10.8	9.6	8.4	8.5	8.0	8.4	9.4	10.7	(36)
(37)			MCWBR	11.7	11.2	10.2	9.5	7.7	6.5	5.3	5.5	6.0	7.0	8.7	10.4	(37)
(38)		5% WB	MCDBR	12.3	12.0	11.1	11.7	10.0	8.1	7.3	7.5	7.6	8.1	9.3	11.2	(38)
(39)			MCWBR	11.8	11.5	10.3	10.2	8.0	6.4	5.2	5.5	6.2	7.2	8.8	10.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.304	0.295	0.330	0.356	0.371	0.390	0.417	0.397	0.364	0.350	0.328	0.305	(40)	
(41)		taud	2.307	2.289	2.269	2.373	2.414	2.375	2.354	2.413	2.477	2.473	2.449	2.377	(41)	
(42)		Ebn at Noon	778	875	892	900	895	876	845	850	851	807	753	737	(42)	
(43)		Edh at Noon	77	95	113	113	113	118	119	108	93	81	68	65	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.95	1.71	2.96	4.17	5.07	5.48	5.51	4.85	3.69	2.25	1.14	0.72	(44)	
(45)		RadStd	0.07	0.24	0.33	0.36	0.42	0.50	0.36	0.31	0.30	0.21	0.14	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.44	N/A	N/A	N/A	N/A

Nomenclature: See separate page