

COMFORT COVE, NL, Canada

WMO: 741930

Lat: 49.274N

Lon: 54.879W

Elev: 326

StdP: 14.52

Time Zone: -3.50 (NAF)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.1	-3.3	-17.1	2.2	-5.2	-12.8	2.8	-1.9	36.4	24.4	30.3	19.2	11.5	240	0.786

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.7	78.4	65.9	75.2	64.3	71.9	62.7	68.4	74.9	66.4	72.4	64.4	70.1	12.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	97.1	72.3	64.0	90.5	69.9	61.9	83.9	67.8	32.9	75.3	31.3	72.4	29.7	70.3	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.6	24.8	21.7	DB	-13.3	84.1	4.8	2.2	-16.8	85.7	-19.6	87.0	-22.3	88.3	-25.8	89.9	(4)
(5)			WB	-13.9	71.2	4.7	1.9	-17.3	72.6	-20.1	73.7	-22.8	74.7	-26.2	76.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.1	16.8	15.6	23.0	34.2	43.6	51.5	58.0	60.6	52.1	43.3	33.4	23.1
	DBStd	17.30	9.80	11.24	9.53	7.38	8.68	8.29	7.58	6.32	6.29	6.46	7.44	8.30
	HDD50	5262	1030	964	837	477	241	80	20	3	50	226	499	835
	HDD65	9890	1495	1384	1302	924	662	410	238	165	389	673	948	1300
	CDD50	906	0	0	0	3	44	126	268	333	113	18	1	0
	CDD65	57	0	0	0	0	0	6	21	29	1	0	0	0
	CDH74	379	0	0	0	0	12	66	143	154	4	0	0	0
	CDH80	35	0	0	0	0	0	10	15	10	0	0	0	0
Wind	WSAvg	11.7	13.8	12.6	12.8	11.3	11.3	10.5	9.3	10.2	10.5	11.4	13.2	13.2
Precipitation	PrecAvg	47.8	4.3	3.9	4.3	3.7	3.6	3.3	3.3	4.3	3.8	4.4	4.3	4.4
	PrecMax	55.0	7.1	5.7	8.5	7.6	6.5	5.8	5.6	8.3	6.8	7.9	8.8	6.2
	PrecMin	38.1	1.3	1.5	1.9	1.0	1.2	0.9	1.1	1.5	2.2	1.7	1.4	2.0
	PrecStd	4.7	1.6	1.2	1.6	1.5	1.6	1.5	1.2	2.0	1.0	1.8	1.6	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	49.8	49.0	64.2	75.3	80.9	82.1	81.3	73.5	66.0	59.0	47.2
		MCWB	48.2	49.1	45.0	59.0	57.3	65.1	68.6	67.5	64.7	61.6	57.1	46.8
	2%	DB	39.8	42.2	45.0	54.6	68.6	75.0	78.0	78.4	69.9	62.3	54.2	40.9
		MCWB	38.8	41.6	42.3	47.9	55.5	63.5	66.0	66.3	61.5	59.2	53.0	39.9
	5%	DB	35.2	36.6	40.7	49.8	63.7	69.7	74.5	75.3	66.3	58.0	48.8	36.6
		MCWB	33.7	35.1	38.4	44.2	52.9	60.3	64.4	64.6	60.1	54.7	47.3	35.3
	10%	DB	31.5	31.9	36.4	45.7	58.9	65.6	71.0	72.1	63.1	54.1	43.8	34.1
		MCWB	30.4	30.7	34.0	40.8	51.8	57.4	62.7	63.6	57.5	51.2	41.8	33.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	48.7	46.6	58.7	61.4	67.7	71.5	70.3	66.8	62.7	57.4	46.9
		MCDB	48.9	50.1	48.2	64.2	68.2	77.2	79.9	77.0	71.6	64.8	58.2	47.4
	2%	WB	39.0	41.7	43.0	50.1	58.0	64.8	68.8	68.5	63.7	59.5	53.4	39.9
		MCDB	39.7	42.1	44.1	52.5	65.2	73.0	74.8	75.1	67.4	62.0	54.3	40.7
	5%	WB	34.0	35.4	38.6	45.0	55.2	62.1	66.2	66.6	61.0	55.5	47.9	35.6
		MCDB	35.1	36.3	40.6	47.3	60.7	68.0	71.3	72.7	64.7	57.7	49.0	36.2
	10%	WB	30.5	30.9	34.6	41.2	51.8	58.7	63.9	64.7	58.2	51.4	42.0	33.2
		MCDB	31.4	31.9	36.1	45.2	59.3	63.7	69.9	70.3	62.3	53.7	43.4	33.9
Mean Daily Temperature Range	5% DB	MDBR	15.3	15.8	14.7	13.4	16.0	16.7	16.1	15.7	14.6	12.3	10.8	11.9
		MCDBR	21.0	18.2	17.9	21.1	25.7	24.8	22.6	20.4	20.2	18.1	18.0	15.7
		MCWBR	21.0	18.0	15.9	14.8	15.5	15.2	13.1	11.0	13.1	15.9	18.2	16.1
	5% WB	MCDBR	20.7	18.3	18.2	18.3	23.2	23.6	18.5	17.7	18.1	17.2	18.0	15.2
		MCWBR	20.8	18.4	17.5	15.1	16.3	16.1	12.6	11.5	14.2	16.7	18.5	15.9
Clear-Sky Solar Irradiance	taub	0.297	0.297	0.326	0.349	0.364	0.381	0.405	0.384	0.357	0.333	0.307	0.302	
	taud	2.313	2.346	2.311	2.364	2.410	2.386	2.362	2.421	2.490	2.514	2.499	2.317	
	Ebn at Noon	238	271	280	285	284	279	270	271	268	256	238	217	
	Edh at Noon	22	27	33	36	35	36	37	33	28	23	19	19	
All-Sky Solar Radiation	RadAvg	291	524	880	1236	1487	1594	1659	1361	1030	627	337	217	
	RadStd	23	69	89	140	123	179	135	97	75	70	36	18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	+2.45	N/A	+0.81	+1.13	N/A	N/A	N/A	N/A

Nomenclature: See separate page