

COMFORT COVE, NL, Canada

WMO: 741930

Lat: 49.274N

Lon: 54.879W

Elev: 99

StdP: 100.14

Time Zone: -3.50 (NAF)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.7	-19.6	-27.3	0.3	-20.7	-24.9	0.4	-18.8	16.3	-4.2	13.5	-7.1	5.1	240	0.786

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.7	25.8	18.8	24.0	17.9	22.2	17.1	20.2	23.8	19.1	22.4	18.0	21.2	5.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.9	22.4	17.8	12.9	21.0	16.6	12.0	19.9	58.6	24.0	54.9	22.4	51.3	21.3	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.1	9.7	DB	-25.2	29.0	2.7	1.2	-27.1	29.8	-28.7	30.6	-30.2	31.3	-32.1	32.2	(4)
(5)			WB	-25.5	21.8	2.6	1.1	-27.4	22.5	-28.9	23.1	-30.4	23.7	-32.3	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-8.5	-9.1	-5.0	1.2	6.5	10.8	14.4	15.9	11.2	6.3	0.8	-5.0	(6)	
	DBStd	9.61	5.44	6.25	5.29	4.10	4.82	4.60	4.21	3.51	3.49	3.59	4.14	4.61	(7)	
	HDD10.0	2923	572	536	465	265	134	44	11	2	28	126	277	464	(8)	
	HDD18.3	5494	831	769	723	513	368	228	132	92	216	374	527	722	(9)	
	CDD10.0	503	0	0	0	2	24	70	149	185	63	10	1	0	(10)	
	CDD18.3	32	0	0	0	0	0	3	12	16	1	0	0	0	(11)	
	CDH23.3	211	0	0	0	0	7	37	79	86	2	0	0	0	(12)	
	CDH26.7	19	0	0	0	0	0	6	8	6	0	0	0	0	(13)	
(14) Wind	WSAvg	5.2	6.2	5.6	5.7	5.1	5.0	4.7	4.2	4.5	4.7	5.1	5.9	5.9	(14)	
(15) Precipitation	PrecAvg	1213	108	100	108	94	92	84	84	108	97	113	110	111	(15)	
	PrecMax	1398	180	145	216	192	165	148	142	210	172	201	224	157	(16)	
	PrecMin	968	33	37	47	26	31	23	29	37	57	42	35	51	(17)	
	PrecStd	119	41	31	41	39	40	39	30	51	26	45	40	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	9.9	9.4	17.9	24.1	27.2	27.8	27.4	23.0	18.9	15.0	8.5	(19)	
		MCWB	9.0	9.5	7.2	15.0	14.0	18.4	20.3	19.7	18.2	16.5	13.9	8.2	(20)	
	2%	DB	4.3	5.7	7.2	12.6	20.3	23.9	25.6	25.8	21.1	16.8	12.3	4.9	(21)	
		MCWB	3.8	5.3	5.7	8.9	13.1	17.5	18.9	19.1	16.4	15.1	11.7	4.4	(22)	
	5%	DB	1.8	2.5	4.8	9.9	17.6	21.0	23.6	24.0	19.1	14.4	9.3	2.5	(23)	
		MCWB	1.0	1.7	3.6	6.8	11.6	15.7	18.0	18.1	15.6	12.6	8.5	1.8	(24)	
	10%	DB	-0.3	0.0	2.4	7.6	15.0	18.7	21.7	22.3	17.3	12.3	6.6	1.2	(25)	
		MCWB	-0.9	-0.7	1.1	4.9	11.0	14.1	17.0	17.5	14.2	10.7	5.5	0.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	9.3	8.1	14.8	16.3	19.8	22.0	21.3	19.3	17.1	14.1	8.3	(27)	
		MCDB	9.4	10.1	9.0	17.9	20.1	25.1	26.6	25.0	22.0	18.2	14.6	8.5	(28)	
	2%	WB	3.9	5.4	6.1	10.1	14.4	18.2	20.4	20.3	17.6	15.3	11.9	4.4	(29)	
		MCDB	4.3	5.6	6.7	11.4	18.5	22.8	23.8	23.9	19.7	16.6	12.4	4.8	(30)	
	5%	WB	1.1	1.9	3.7	7.2	12.9	16.7	19.0	19.2	16.1	13.0	8.8	2.0	(31)	
		MCDB	1.7	2.4	4.8	8.5	15.9	20.0	21.8	22.6	18.2	14.3	9.5	2.4	(32)	
	10%	WB	-0.8	-0.6	1.4	5.1	11.0	14.8	17.7	18.2	14.6	10.8	5.6	0.7	(33)	
		MCDB	-0.3	0.0	2.3	7.3	15.2	17.6	21.1	21.3	16.8	12.0	6.4	1.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	8.8	8.2	7.5	8.9	9.3	8.9	8.7	8.1	6.9	6.0	6.6	(35)	
		MCDBR	11.6	10.1	10.0	11.7	14.3	13.8	12.5	11.3	11.2	10.0	10.0	8.7	(36)	
	5% WB	MCWBR	11.7	10.0	8.9	8.2	8.6	8.4	7.3	6.1	7.3	8.8	10.1	9.0	(37)	
		MCWBR	11.5	10.2	10.1	10.2	12.9	13.1	10.3	9.8	10.1	9.5	10.0	8.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.297	0.297	0.326	0.349	0.364	0.381	0.405	0.384	0.357	0.333	0.307	0.302	(40)	
		taud	2.313	2.346	2.311	2.364	2.410	2.386	2.362	2.421	2.490	2.514	2.499	2.317	(41)	
	Ebn at Noon	Ebn at Noon	749	853	883	898	896	879	850	854	845	806	749	685	(42)	
		Edh at Noon	70	85	105	112	111	115	116	105	89	73	59	61	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.92	1.65	2.77	3.90	4.69	5.03	5.23	4.29	3.25	1.98	1.06	0.68	(44)	
	RadStd	RadStd	0.07	0.22	0.28	0.44	0.39	0.56	0.43	0.31	0.24	0.22	0.12	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	+1.36	N/A	+0.45	+0.63	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page