

DARRINGTON 21 NNE, WA, USAWMO: **742020**Lat: **48.5405N**Lon: **121.4460W**Elev: **124**StdP: **99.84**Time Zone: **-8.00 (NAP)**Period: **03-19**WBAN: **04223****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.9	-3.9	-14.7	1.1	-0.8	-12.1	1.3	-1.4	4.5	0.5	3.9	-0.1	1.6	N/A	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	31.0	19.6	28.9	18.7	26.8	18.2	20.6	28.5	19.7	27.3	18.8	25.9	1.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	12.9	23.7	16.8	12.1	22.5	15.9	11.5	21.4	59.7	28.5	56.5	27.0	53.6	25.9	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.1	2.2	1.7	-9.6	34.8	1.8	2.1	-10.9	36.2	-11.9	37.4	-12.9	38.6	-14.2	40.1		
(5)			-9.6	22.5	1.6	0.7	-10.8	23.0	-11.8	23.4	-12.7	23.8	-13.9	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	2.8	3.7	5.9	8.9	12.9	15.3	18.3	18.5	15.0	9.8	5.0	2.3
	DBStd	6.43	2.96	2.94	2.86	3.03	3.11	3.01	2.66	2.51	2.82	2.66	3.04	2.89
	HDD10.0	1020	223	176	132	56	8	1	0	0	1	36	150	238
	HDD18.3	3158	482	409	387	283	168	102	32	29	106	264	399	496
	CDD10.0	987	0	0	4	23	99	158	258	263	151	29	1	0
	CDD18.3	83	0	0	0	0	2	9	32	34	6	0	0	0
	CDH23.3	1455	0	0	1	14	86	191	538	499	126	1	0	0
	CDH26.7	466	0	0	0	2	19	62	183	166	34	0	0	0
Wind	WSAvg	0.5	0.6	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.4	0.4	0.5	0.5
Precipitation	PrecAvg	1798	287	162	173	99	74	65	34	46	72	200	319	280
	PrecMax	2457	495	325	361	199	127	133	92	128	182	520	694	488
	PrecMin	1323	146	2	19	29	23	18	6	2	12	19	99	128
	PrecStd	292	91	94	86	46	30	29	22	35	52	115	167	89
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	14.4	19.7	25.4	29.1	31.8	34.5	33.1	30.6	21.9	13.8	10.2
		MCWB	7.9	8.5	10.5	14.0	16.8	20.9	19.5	19.6	18.0	13.3	10.6	7.4
	2%	DB	9.6	11.4	15.6	20.8	25.8	28.4	30.9	30.6	26.9	18.7	11.8	8.4
		MCWB	6.6	7.7	9.2	12.1	16.3	19.1	19.5	19.5	17.3	12.7	10.3	7.0
	5%	DB	8.0	9.6	12.8	17.4	22.9	25.2	28.6	28.5	24.0	16.2	10.4	7.2
		MCWB	6.4	7.4	8.1	10.8	15.3	17.6	19.4	18.8	16.2	11.9	9.2	6.3
	10%	DB	6.7	7.9	10.5	14.7	20.1	22.5	26.3	26.2	21.4	14.2	9.3	6.2
		MCWB	5.7	6.6	7.6	9.6	14.1	16.2	18.5	18.4	15.4	11.4	8.3	5.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	10.2	12.7	15.7	18.8	21.8	21.5	21.6	19.7	16.1	12.0	8.5
		MCDB	10.7	11.7	17.9	24.2	27.1	30.2	29.2	29.3	27.1	18.4	12.9	8.9
	2%	WB	7.5	9.0	10.5	13.1	17.2	19.8	20.7	20.3	18.6	14.1	10.9	7.2
		MCDB	8.5	10.2	15.2	19.8	24.5	27.9	28.6	28.2	25.2	16.3	11.5	7.7
	5%	WB	6.5	7.7	9.2	11.5	15.9	18.1	19.8	19.5	17.3	12.9	9.7	6.2
		MCDB	7.4	8.7	12.2	16.1	22.4	24.7	27.4	26.8	22.7	14.6	10.1	6.7
	10%	WB	5.7	6.6	8.1	10.3	14.9	16.7	18.8	18.6	16.1	11.9	8.6	5.4
		MCDB	6.5	7.7	10.4	13.8	20.4	22.3	26.0	25.5	20.3	13.8	9.2	5.9
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.9	8.6	10.4	11.9	11.4	14.0	13.9	11.8	8.5	5.7	4.4
		MCDBR	7.9	10.4	13.9	16.8	18.4	18.4	19.1	19.2	18.0	13.3	7.6	5.8
		MCWBR	5.9	5.7	8.2	8.8	9.5	9.3	8.8	8.5	8.7	7.7	5.5	4.3
	5% WB	MCDBR	6.8	6.9	12.3	14.5	16.4	16.8	17.0	16.6	15.1	9.5	5.2	4.7
	MCWBR	5.2	4.8	7.4	7.9	9.0	9.0	8.5	8.0	7.6	6.1	4.4	3.8	
Clear-Sky Solar Irradiance	taub	0.294	0.294	0.313	0.346	0.379	0.363	0.350	0.351	0.334	0.336	0.301	0.296	
	taud	2.374	2.386	2.358	2.283	2.309	2.424	2.476	2.494	2.536	2.510	2.503	2.356	
	Ebn at Noon	772	866	904	902	882	898	905	890	876	809	768	713	
	Edh at Noon	68	84	101	121	124	111	104	98	85	75	60	61	
All-Sky Solar Radiation	RadAvg	1.02	1.88	2.81	4.22	5.20	5.71	6.67	5.67	4.03	2.28	1.12	0.81	
	RadStd	0.16	0.21	0.33	0.40	0.45	0.56	0.55	0.40	0.33	0.30	0.16	0.12	