

WHEELER-SACK AAF, NY, USA

WMO: 743700

Lat: 44.050N

Lon: 75.733W

Elev: 210

StdP: 98.83

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14715

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.7	-20.5	-26.4	0.3	-22.8	-23.7	0.5	-19.6	13.3	4.1	11.9	0.7	3.1	140	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	30.2	21.7	28.8	20.9	27.4	20.2	23.7	27.3	22.7	26.5	21.9	25.5	4.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	17.9	25.1	21.7	16.8	24.5	20.7	15.8	24.0	72.1	27.4	68.3	26.9	64.8	25.7	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	9.3	8.3	-28.5	32.5	3.4	1.5	-30.9	33.6	-32.9	34.4	-34.8	35.3	-37.2	36.3
			-28.6	25.5	3.3	1.4	-31.0	26.5	-33.0	27.4	-34.8	28.2	-37.3	29.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-7.5	-6.0	-1.1	6.3	13.4	18.4	20.9	20.0	16.1	9.5	2.8	-3.3	(6)
(7)		DBStd	11.26	7.77	6.54	6.30	5.24	4.65	3.74	3.00	3.04	4.29	4.91	5.57	6.22	(7)
(8)		HDD10.0	2203	543	449	347	134	18	0	0	0	4	71	224	412	(8)
(9)		HDD18.3	4190	801	682	602	362	164	46	10	18	93	277	467	669	(9)
(10)		CDD10.0	1302	1	0	4	24	125	251	337	311	187	55	8	1	(10)
(11)		CDD18.3	247	0	0	0	2	12	46	88	71	26	2	0	0	(11)
(12)		CDH23.3	1909	0	0	2	19	127	376	684	492	197	13	0	0	(12)
(13)		CDH26.7	441	0	0	0	3	24	91	169	108	45	1	0	0	(13)
(14)	Wind	WSAvg	4.1	4.5	4.6	4.6	4.7	4.2	3.6	3.5	3.3	3.5	3.9	4.3	4.2	(14)
(15)	Precipitation	PrecAvg	982	74	61	65	79	83	82	92	79	92	104	92	84	(15)
(16)		PrecMax	1226	154	107	121	144	146	175	198	118	173	182	144	143	(16)
(17)		PrecMin	782	26	25	28	10	33	18	33	24	49	19	42	37	(17)
(18)		PrecStd	106	32	18	25	36	34	39	37	31	31	46	26	29	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	12.4	20.1	25.9	29.4	31.3	32.1	31.4	30.6	25.2	19.0	14.0	(19)
(20)		0.4%	MCWB	11.7	8.7	14.6	16.3	20.5	22.1	23.7	21.9	21.4	17.8	14.1	11.3	(20)
(21)		2%	DB	8.0	7.8	14.1	21.8	26.6	29.1	30.1	29.1	27.7	22.1	16.2	9.9	(21)
(22)		2%	MCWB	6.6	5.3	9.3	13.0	18.0	20.8	22.2	21.2	20.6	17.0	12.0	8.3	(22)
(23)		5%	DB	5.0	5.1	11.0	17.9	24.4	27.4	28.7	27.7	25.7	19.6	13.7	7.3	(23)
(24)		5%	MCWB	3.6	3.1	7.5	11.3	16.7	20.0	21.2	20.4	19.7	15.2	10.6	5.9	(24)
(25)		10%	DB	2.5	2.7	7.7	15.1	22.1	25.4	27.2	26.2	23.5	17.3	11.2	4.8	(25)
(26)		10%	MCWB	1.3	1.3	4.9	9.8	15.4	18.8	20.3	20.0	18.4	13.8	8.8	3.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	9.0	15.4	17.9	22.1	24.2	25.4	24.9	23.7	20.5	15.1	12.0	(27)
(28)		0.4%	MCDWB	13.1	11.2	20.7	22.5	27.4	28.6	29.3	27.6	27.2	21.9	17.3	13.6	(28)
(29)		2%	WB	7.1	5.8	10.7	15.1	20.2	22.7	23.9	23.2	22.0	17.9	13.0	8.3	(29)
(30)		2%	MCDWB	7.9	7.5	13.5	19.2	24.3	26.8	27.4	26.4	25.8	20.4	15.5	9.2	(30)
(31)		5%	WB	3.7	3.4	7.7	12.8	18.6	21.5	22.8	22.3	20.6	15.8	11.0	5.9	(31)
(32)		5%	MCDWB	4.8	5.0	10.3	17.1	22.6	25.3	26.6	25.6	24.0	18.6	13.3	7.3	(32)
(33)		10%	WB	1.4	1.5	5.0	10.2	16.8	20.3	21.9	21.2	19.4	14.1	8.8	3.4	(33)
(34)		10%	MCDWB	2.4	2.7	7.6	14.4	20.2	23.8	25.6	24.4	22.6	16.9	10.9	4.6	(34)
(35)	Mean Daily Temperature Range	MDBR	9.0	9.1	9.0	10.4	11.0	10.4	10.2	10.4	10.9	9.2	8.1	7.8	(35)	
(36)		5% DB	MCDBR	9.7	10.0	12.9	15.3	13.8	12.7	11.7	12.0	12.6	12.1	11.7	9.4	(36)
(37)		5% DB	MCWBR	9.0	8.5	9.0	8.8	7.2	6.2	5.3	5.6	6.4	7.4	8.5	8.2	(37)
(38)		5% WB	MCDBR	9.5	9.9	12.0	13.4	11.7	10.4	9.7	9.6	10.7	10.7	10.6	9.3	(38)
(39)		5% WB	MCWBR	9.1	8.8	9.0	9.2	7.5	6.0	5.6	5.6	6.4	7.4	8.8	8.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.289	0.294	0.325	0.354	0.380	0.412	0.425	0.414	0.364	0.346	0.308	0.283	(40)	
(41)		taud	2.361	2.345	2.397	2.389	2.362	2.291	2.255	2.281	2.412	2.459	2.508	2.451	(41)	
(42)		Ebn at Noon	835	900	914	910	891	860	842	839	860	829	815	814	(42)	
(43)		Edh at Noon	78	94	103	113	120	129	133	125	101	85	68	65	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.33	2.19	3.48	4.38	5.27	5.64	5.77	5.11	4.06	2.41	1.52	1.01	(44)	
(45)		RadStd	0.15	0.23	0.29	0.54	0.55	0.46	0.51	0.25	0.36	0.24	0.17	0.13	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	(d) +0.44	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) -147	(k) -210	(l) N/A	(m) N/A	(46)
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page