

BRUNSWICK, ME, USA

WMO: 743920

Lat: 43.900N

Lon: 69.933W

Elev: 70

StdP: 14.66

Time Zone: -5.00 (NAE)

Period: 94-10

WBAN: 14611

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.3	(c) 1.8	(d) -17.9	(e) 2.1	(f) 0.8	(g) -12.7	(h) 2.8	(i) 5.4	(j) 27.1	(k) 34.7	(l) 24.6	(m) 26.9	(n) 5.4	(o) 330	(p) 0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.0	(c) 85.8	(d) 70.6	(e) 82.3	(f) 68.6	(g) 79.9	(h) 66.9	(i) 73.2	(j) 81.7	(k) 71.3	(l) 79.3	(m) 69.5	(n) 76.1	(o) 9.6	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.3	112.0	77.8	68.7	105.7	75.5	66.8	99.0	73.3	36.9	81.9	35.1	79.2	33.6	76.5	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.7	20.0	17.9	-11.5	92.4	5.8	3.2	-15.6	94.8	-19.0	96.7	-22.3	98.5	-26.5	100.8
			-12.1	77.3	5.6	2.1	-16.1	78.8	-19.4	80.0	-22.5	81.2	-26.6	82.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	21.1	23.9	32.7	43.5	53.6	63.7	68.9	68.3	60.3	48.7	39.1	28.6	
	DBStd	18.09	10.89	9.60	8.65	6.12	6.20	6.60	5.17	4.84	6.17	6.92	8.22	9.02	
	HDD50	3526	896	732	539	212	29	1	0	0	4	109	339	665	
	HDD65	7241	1361	1152	1002	646	360	101	22	23	163	506	777	1128	
	CDD50	2117	0	0	2	16	140	412	585	568	312	69	12	1	
	CDD65	355	0	0	0	0	5	61	141	125	22	1	0	0	
	CDH74	2453	0	0	3	5	78	476	952	792	141	6	0	0	
	CDH80	595	0	0	1	0	18	126	245	177	28	0	0	0	
Wind	WSAvg	7.6	7.9	8.2	8.8	8.8	8.1	6.9	6.7	6.3	6.8	7.6	7.9	7.9	
Precipitation	PrecAvg	46.6	3.6	3.6	4.3	3.9	3.8	3.6	2.9	3.4	3.3	3.9	5.0	4.6	
	PrecMax	67.4	10.8	7.3	10.2	8.9	8.8	9.1	7.9	9.8	8.5	10.6	14.3	10.0	
	PrecMin	35.9	0.5	0.1	0.7	0.4	0.6	0.7	0.6	0.4	0.6	0.9	1.2	1.1	
	PrecStd	8.0	2.0	1.6	2.0	1.6	1.9	1.9	1.6	2.0	1.8	2.2	2.5	2.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.0	48.2	60.6	71.8	82.0	88.4	90.2	89.7	83.6	73.4	63.0	56.5	
		MCWB	49.2	42.3	48.0	55.9	63.7	71.3	73.3	71.8	69.4	60.1	55.9	49.4	
	2%	DB	45.7	44.9	52.9	63.7	74.6	83.7	85.6	84.3	77.9	67.1	58.7	49.8	
		MCWB	42.2	40.4	43.8	49.5	60.1	67.9	71.0	70.6	64.6	56.9	54.0	45.9	
	5%	DB	40.6	41.7	48.1	58.8	69.6	79.5	82.2	81.5	73.8	63.4	55.0	45.7	
		MCWB	37.4	37.4	41.2	46.6	56.5	65.8	69.1	68.9	63.0	55.9	50.7	42.7	
	10%	DB	36.3	38.2	45.0	54.8	64.4	75.4	79.4	78.8	71.3	60.5	52.3	41.9	
		MCWB	33.4	34.4	39.2	44.5	53.4	63.8	67.4	66.5	62.4	53.8	48.4	38.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	45.3	51.3	57.4	65.5	74.3	76.4	75.4	70.8	64.1	58.8	52.0
			MCDB	50.6	46.4	55.6	67.1	78.6	84.8	85.5	84.3	77.6	68.7	61.1	54.4
2%		WB	43.3	41.5	46.1	51.8	61.5	71.2	73.3	73.1	68.5	60.2	55.4	47.1	
		MCDB	45.1	44.3	49.9	58.6	72.3	79.6	81.9	80.8	74.1	65.1	57.9	48.4	
5%		WB	37.7	37.8	42.4	48.8	58.4	68.6	71.3	71.1	66.1	57.7	52.3	43.3	
		MCDB	40.2	40.6	47.2	56.0	66.3	75.7	79.7	78.4	71.1	61.7	54.1	45.5	
10%		WB	33.4	35.0	39.5	46.3	55.9	66.2	69.5	69.3	64.1	55.1	48.6	38.3	
		MCDB	35.7	38.1	43.8	52.6	62.7	72.6	76.3	75.4	68.1	58.5	51.6	41.4	
Mean Daily Temperature Range		5% DB	MDBR	17.0	17.9	16.5	18.7	18.6	18.0	18.0	18.7	18.6	18.4	15.9	16.1
			MCDBR	18.9	18.7	21.7	26.3	26.7	23.7	22.2	22.3	22.3	22.5	18.0	20.3
	MCWBR		17.2	15.1	14.7	15.1	14.2	12.3	10.8	11.5	12.4	14.9	14.0	17.7	
	5% WB	MCDBR	18.4	17.1	19.5	22.3	22.4	20.9	18.9	19.3	17.8	18.7	15.9	19.5	
		MCWBR	17.7	15.2	14.7	14.7	13.3	12.7	10.8	10.8	11.7	14.5	14.1	18.4	
Clear-Sky Solar Irradiance	taub	0.290	0.303	0.329	0.355	0.384	0.433	0.447	0.414	0.375	0.338	0.319	0.293		
	taud	2.435	2.403	2.431	2.413	2.376	2.253	2.230	2.311	2.403	2.504	2.522	2.507		
	Ebn at Noon	267	283	289	289	282	267	261	266	270	267	255	256		
	Edh at Noon	23	29	32	35	37	43	43	38	32	26	22	20		
All-Sky Solar Radiation	RadAvg	517	801	1171	1459	1640	1761	1847	1675	1349	863	553	410		
	RadStd	37	63	71	155	197	147	131	88	80	78	51	43		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	-2.88	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+137	N/A

Nomenclature: See separate page