

SPARTA, IL, USA

WMO: 744653

Lat: 38.149N

Lon: 89.699W

Elev: 164

StdP: 99.37

Time Zone: -6.00 (NAC)

Period: 02-19

WBAN: 63814

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.5	-10.1	-18.9	0.7	-10.1	-16.4	0.9	-8.5	10.7	7.3	9.4	5.1	2.7	310	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	34.3	24.6	32.9	24.6	32.2	24.3	27.3	31.2	26.4	30.5	25.6	30.0	3.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	22.1	29.6	25.2	20.7	28.9	24.1	19.4	28.0	87.3	31.2	82.7	30.2	79.5	30.2	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.9	7.1	-16.0	37.0	2.2	1.9	-17.6	38.4	-18.9	39.5	-20.1	40.5	-21.7	41.9		
(5)			-16.8	28.2	2.5	1.4	-18.6	29.2	-20.0	30.0	-21.4	30.8	-23.2	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	0.5	2.6	8.7	14.1	19.3	24.4	25.8	24.9	21.1	14.7	8.0	3.0	(6)
(7)		DBStd	10.13	6.41	6.25	6.02	5.03	4.50	3.14	3.03	3.00	3.74	5.14	5.42	5.52	(7)
(8)		HDD10.0	978	302	218	98	19	1	0	0	0	0	13	100	226	(8)
(9)		HDD18.3	2429	553	441	302	142	45	2	0	1	16	138	312	477	(9)
(10)		CDD10.0	2427	7	11	58	142	289	431	488	461	334	158	39	8	(10)
(11)		CDD18.3	837	0	0	3	15	76	183	230	203	100	25	2	0	(11)
(12)		CDH23.3	7940	0	0	18	116	592	1809	2409	1909	877	202	7	0	(12)
(13)		CDH26.7	3089	0	0	1	14	156	725	1057	779	306	51	1	0	(13)
(14)	Wind	WSAvg	2.9	3.5	3.4	3.6	3.6	2.8	2.4	2.1	1.9	2.6	3.2	3.3	(14)	
(15)	Precipitation	PrecAvg	1077	58	62	104	106	117	96	101	85	77	75	102	80	(15)
(16)		PrecMax	1382	193	112	245	288	308	225	327	231	208	191	291	268	(16)
(17)		PrecMin	693	4	7	27	30	23	7	9	8	5	0	16	18	(17)
(18)		PrecStd	174	44	30	52	60	66	55	63	48	46	44	62	53	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	21.1	25.9	28.0	32.3	35.2	37.4	37.2	33.8	31.0	23.9	18.7	(19)
(20)			MCWB	16.5	16.4	18.1	19.1	22.9	24.2	24.4	23.8	22.3	22.6	16.8	16.5	(20)
(21)		2%	DB	17.0	18.0	22.8	26.8	30.0	33.2	34.8	34.0	32.1	27.8	21.1	16.3	(21)
(22)			MCWB	15.0	14.0	16.9	18.6	22.6	24.5	25.3	24.2	23.0	20.2	15.4	13.9	(22)
(23)		5%	DB	12.9	15.6	20.9	24.2	28.0	32.3	33.0	32.5	30.1	25.9	18.7	13.8	(23)
(24)			MCWB	10.3	12.1	15.4	17.5	21.4	24.1	25.4	24.5	22.7	18.5	14.8	11.1	(24)
(25)		10%	DB	9.7	12.5	18.0	22.6	27.1	31.0	32.1	31.1	28.0	22.9	17.0	11.2	(25)
(26)			MCWB	7.4	9.2	14.0	16.7	20.9	23.4	25.1	24.3	21.0	17.5	13.1	9.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	17.7	19.7	22.2	25.3	27.4	29.0	28.4	25.9	23.5	19.3	17.2	(27)
(28)			MCD B	18.0	19.6	23.5	25.7	29.4	31.3	33.1	32.0	29.3	28.6	22.5	18.2	(28)
(29)		2%	WB	15.0	15.3	17.9	20.2	24.0	26.2	27.6	27.0	24.9	22.1	17.3	14.4	(29)
(30)			MCD B	16.8	17.6	21.7	24.6	27.8	31.1	31.7	30.8	29.5	26.0	19.1	16.3	(30)
(31)		5%	WB	11.0	12.7	16.6	18.9	22.9	25.4	26.7	26.0	23.9	20.6	15.4	12.0	(31)
(32)			MCD B	12.5	14.8	19.9	22.5	26.7	30.4	30.7	30.1	28.0	23.9	18.2	13.2	(32)
(33)		10%	WB	7.2	9.3	14.9	17.6	21.8	24.6	25.7	25.1	22.8	18.8	13.2	9.0	(33)
(34)			MCD B	9.3	12.1	17.7	20.9	25.6	29.2	30.0	29.4	26.4	22.1	16.1	10.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	8.9	9.7	10.7	10.1	10.3	10.0	10.2	11.3	10.9	9.5	7.8	(35)
(36)			MCD BR	12.0	13.3	12.2	12.6	11.2	11.5	11.1	11.7	13.0	12.9	11.9	10.5	(36)
(37)			MCWBR	9.7	10.0	7.9	7.1	5.6	4.6	4.5	4.9	5.5	6.3	8.0	8.5	(37)
(38)		5% WB	MCD BR	10.8	12.1	10.9	10.8	9.7	10.0	10.1	9.9	10.6	11.0	10.5	9.5	(38)
(39)			MCWBR	10.2	10.1	7.9	7.2	5.5	4.9	5.1	5.2	5.4	6.6	8.8	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.321	0.352	0.397	0.430	0.441	0.466	0.463	0.405	0.352	0.315	0.302	(40)	
(41)		taud	2.472	2.421	2.396	2.267	2.234	2.227	2.165	2.167	2.317	2.464	2.509	2.499	(41)	
(42)		Ebn at Noon	875	908	908	882	855	843	817	810	841	861	861	857	(42)	
(43)		Edh at Noon	81	96	109	132	139	140	148	144	117	92	77	74	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.08	2.78	3.77	4.97	5.58	6.42	6.22	5.64	4.74	3.48	2.35	1.74	(44)	
(45)		RadStd	0.22	0.31	0.36	0.30	0.49	0.42	0.41	0.31	0.30	0.37	0.26	0.17	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+78

Nomenclature: See separate page