

YOSEMITE VILLAGE 12 W, CA, USA

WMO: 745030

Lat: 37.7592N

Lon: 119.8208W

Elev: 6620

StdP: 11.50

Time Zone: -8.00 (NAP)

Period: 07-19

WBAN: 53150

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.0	19.6	-17.3	2.7	44.6	-8.3	4.5	44.5	17.6	34.0	15.2	34.0	2.2	N/A	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	79.9	56.6	77.8	54.9	76.0	54.1	59.8	74.9	58.0	73.6	56.5	72.5	5.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.3	77.6	69.1	51.0	71.2	67.8	48.9	65.7	65.0	29.5	74.6	28.1	73.1	27.0	72.8	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.0	8.8	7.3	13.0	83.9	1.9	2.2	11.6	85.4	10.5	86.7	9.4	88.0	8.0	89.5
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	39.5	36.5	38.9	43.2	49.6	60.5	67.8	67.3	62.6	52.4	44.5	37.1	(6)
	DBStd	14.28	9.41	10.21	8.79	9.56	9.43	8.52	5.05	5.07	8.04	8.50	10.05	9.47	(7)
	HDD50	2190	339	387	355	247	127	18	0	1	14	75	219	408	(8)
	HDD65	5780	792	797	810	654	482	178	31	33	129	395	615	864	(9)
	CDD50	2214	12	10	10	43	113	332	551	537	393	149	55	9	(10)
	CDD65	330	0	0	0	0	3	43	117	104	58	5	0	0	(11)
	CDH74	868	0	0	0	0	3	110	313	308	129	5	0	0	(12)
	CDH80	53	0	0	0	0	0	4	20	24	5	0	0	0	(13)
(14) Wind	WSAvg	3.6	3.6	3.8	4.1	3.9	3.7	3.6	3.2	3.4	3.5	3.4	3.4	3.5	(14)
(15) Precipitation	PrecAvg	40.5	8.1	6.6	5.5	3.5	2.2	0.6	0.2	0.1	0.3	2.4	3.6	7.4	(15)
	PrecMax	64.7	20.4	16.2	18.3	10.4	5.9	2.4	3.0	1.2	2.0	9.8	9.4	17.2	(16)
	PrecMin	21.1	0.6	0.4	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.9	(17)
	PrecStd	12.2	5.7	4.0	4.9	2.7	1.7	0.7	0.6	0.3	0.5	2.5	2.8	4.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.8	59.4	61.1	67.3	73.6	80.3	82.3	83.0	80.4	73.9	66.2	60.0	(19)
		MCWB	40.8	42.2	45.4	51.9	52.4	59.5	57.9	56.6	54.0	50.3	46.3	39.4	(20)
	2%	DB	56.5	56.4	56.7	63.3	69.2	77.3	79.7	79.7	77.3	69.1	63.0	56.3	(21)
		MCWB	39.2	40.9	42.9	48.2	51.4	56.3	57.1	55.1	52.8	47.7	44.7	37.0	(22)
	5%	DB	53.9	53.4	53.5	59.9	65.8	74.5	77.4	77.4	75.3	66.2	60.3	53.1	(23)
		MCWB	37.3	39.0	41.3	46.4	50.0	54.2	55.4	53.9	52.4	46.8	43.5	36.3	(24)
	10%	DB	51.3	50.6	50.7	56.9	62.5	72.0	75.4	75.3	72.9	63.5	57.2	50.2	(25)
		MCWB	36.2	38.0	39.3	44.5	47.7	52.8	54.8	53.3	51.9	45.9	41.5	35.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	45.9	47.3	56.2	55.5	63.0	62.0	59.8	58.1	53.1	48.1	42.7	(27)
		MCDB	52.1	56.3	57.1	62.3	67.6	77.9	77.4	76.4	71.7	67.1	61.9	49.4	(28)
	2%	WB	41.5	43.4	45.4	50.9	53.3	60.3	59.4	57.8	56.0	51.3	45.7	41.2	(29)
		MCDB	50.0	53.1	55.6	60.2	65.7	75.8	74.8	75.7	71.6	65.7	59.3	47.5	(30)
	5%	WB	40.2	41.7	43.8	48.1	51.3	57.9	57.9	56.1	54.4	49.9	43.7	39.5	(31)
		MCDB	48.8	51.5	52.9	58.6	64.1	72.8	73.8	73.8	70.8	63.9	56.8	46.9	(32)
	10%	WB	38.9	39.9	41.9	46.0	49.7	55.4	56.7	54.9	53.1	48.1	42.0	37.8	(33)
		MCDB	48.0	49.9	50.2	56.4	61.5	71.0	72.7	72.4	69.6	61.3	54.3	47.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	9.6	10.3	12.6	12.5	13.1	12.6	14.1	14.3	12.4	10.7	9.9	(35)
		MCDBR	10.3	10.8	12.0	13.8	13.8	13.1	12.7	14.4	14.3	12.8	11.1	10.9	(36)
		MCWBR	7.6	8.8	10.2	11.8	10.5	10.1	8.3	7.9	7.7	8.1	8.0	8.1	(37)
	5% WB	MCDBR	10.0	11.4	12.2	13.4	13.8	12.8	12.7	13.5	13.9	12.4	11.3	9.7	(38)
		MCWBR	8.3	9.4	10.6	12.3	11.4	10.6	8.7	8.2	8.1	8.8	9.0	8.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.268	0.275	0.300	0.291	0.303	0.297	0.309	0.290	0.291	0.273	0.271	0.265	(40)
	taud		2.471	2.465	2.400	2.490	2.493	2.525	2.508	2.553	2.559	2.610	2.551	2.510	(41)
	Ebn at Noon		295	306	306	314	310	310	305	310	306	305	293	289	(42)
	Edh at Noon		25	29	35	33	34	33	33	31	29	25	23	23	(43)
(44) All-Sky Solar Radiation	RadAvg		779	1062	1484	1914	2288	2639	2571	2353	1938	1398	935	692	(44)
	RadStd		101	136	142	163	169	141	121	91	74	97	56	95	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	-218	+266	+95

Nomenclature: See separate page