

MOUNTAIN VIEW MOFFETT, CA, USA

WMO: 745090

Lat: 37.417N

Lon: 122.050W

Elev: 39

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23244

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 36.4	(c) 38.8	(d) 21.1	(e) 15.9	(f) 52.3	(g) 25.4	(h) 19.4	(i) 51.1	(j) 20.5	(k) 56.5	(l) 18.2	(m) 55.5	(n) 1.3	(o) 140	(p) 0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 16.5	(c) 88.1	(d) 65.6	(e) 83.8	(f) 64.8	(g) 80.5	(h) 64.1	(i) 68.3	(j) 82.6	(k) 66.9	(l) 79.9	(m) 65.8	(n) 77.5	(o) 9.7	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.2	86.9	74.2	61.6	81.9	71.9	60.8	79.8	71.1	32.5	81.9	31.4	79.9	30.5	77.6	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	17.0	15.4	31.3	96.2	2.3	4.2	29.6	99.2	28.3	101.7	27.0	104.1	25.2	107.2
			28.7	70.4	2.4	2.0	27.0	71.9	25.6	73.1	24.2	74.2	22.5	75.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.3	51.4	53.3	56.1	58.8	62.0	66.0	67.8	68.1	67.9	63.6	56.5	51.0
	DBStd	7.71	4.34	4.49	4.58	4.93	4.59	4.53	3.65	3.71	4.71	4.57	4.66	4.85
	HDD50	108	35	17	5	1	0	0	0	0	0	0	6	44
	HDD65	2185	422	328	277	197	119	35	10	8	17	82	257	433
	CDD50	3852	79	109	195	264	372	481	552	562	538	422	202	76
	CDD65	451	0	0	1	10	25	66	97	105	105	39	3	0
	CDH74	2912	0	3	25	124	242	480	470	502	720	322	24	0
	CDH80	852	0	0	1	29	82	154	116	133	254	82	1	0
(14) Wind	WSAvg	5.5	3.9	4.9	5.4	6.2	6.9	7.2	7.3	6.7	5.4	4.5	3.7	4.3
(15) Precipitation	PrecAvg	13.9	2.8	2.2	2.3	1.0	0.2	0.1	0.0	0.0	0.2	0.8	2.0	2.0
	PrecMax	31.4	6.8	7.2	6.4	4.0	1.7	0.5	0.5	0.6	1.2	3.5	5.6	4.4
	PrecMin	6.2	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
	PrecStd	5.2	1.9	2.0	1.6	1.1	0.4	0.1	0.1	0.2	0.3	0.9	1.7	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.3	73.3	77.4	84.4	88.7	91.3	89.6	90.4	92.7	87.7	77.8	67.2
		MCWB	53.1	56.6	59.6	62.9	64.1	65.5	69.4	68.0	65.5	62.9	59.0	55.6
	2%	DB	64.9	68.2	72.1	77.2	80.7	84.2	83.0	83.3	87.3	81.6	71.6	63.9
		MCWB	53.4	55.3	57.3	59.8	63.1	65.1	67.1	66.8	64.8	61.0	58.6	54.8
	5%	DB	62.1	64.4	68.2	72.3	74.4	79.1	78.9	79.1	81.7	77.2	67.8	61.9
		MCWB	53.3	54.0	56.2	58.8	60.7	64.2	65.5	65.7	64.1	59.9	56.4	54.2
	10%	DB	59.4	61.5	65.0	68.1	70.7	75.1	75.6	75.7	77.2	73.1	64.7	59.7
		MCWB	52.3	53.0	55.3	56.6	59.0	62.5	64.4	64.5	63.5	59.6	55.5	53.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.8	59.9	62.0	64.9	67.5	69.3	70.5	70.1	69.5	66.8	62.9	60.4
		MCDB	63.9	66.9	74.2	79.9	85.0	86.6	85.6	84.7	84.1	79.0	72.2	63.6
	2%	WB	56.7	57.7	59.8	62.2	63.9	66.7	67.8	68.0	67.1	64.6	61.0	58.7
		MCDB	60.5	64.9	68.6	74.9	75.9	80.9	81.1	81.0	80.3	75.1	68.2	62.0
	5%	WB	54.9	56.0	58.1	59.9	61.7	65.0	66.2	66.3	65.7	62.9	59.3	56.6
		MCDB	59.3	62.4	65.5	69.9	73.1	77.2	77.7	77.6	78.6	72.6	64.9	59.9
	10%	WB	53.3	54.4	56.4	58.0	59.9	63.3	64.9	65.0	64.3	61.3	57.6	54.4
		MCDB	57.6	60.2	63.3	66.6	69.8	74.1	75.1	75.0	75.9	70.0	63.1	58.3
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	15.4	16.6	17.6	17.1	18.3	16.6	16.5	18.9	18.8	16.8	15.2
		MCDBR	19.5	20.8	22.1	24.7	24.0	24.4	21.6	21.7	26.8	26.1	21.3	17.3
		MCWBR	11.0	11.6	11.8	12.6	11.7	11.2	9.8	9.6	11.1	11.8	11.0	9.9
	5% WB	MCDBR	14.3	17.1	18.8	21.7	21.5	22.0	19.8	19.9	22.2	20.3	16.7	11.5
		MCWBR	9.2	10.3	11.0	11.8	11.0	10.5	9.4	9.3	10.0	10.0	10.0	7.9
(40) Clear-Sky Solar Irradiance	taub		0.324	0.333	0.338	0.359	0.370	0.362	0.366	0.348	0.353	0.335	0.322	0.324
	taud		2.541	2.516	2.492	2.407	2.396	2.426	2.423	2.470	2.442	2.533	2.550	2.550
	Ebn at Noon		275	286	294	292	289	290	288	292	285	281	273	266
	Edh at Noon		24	28	32	36	38	36	36	34	33	27	24	23
(44) All-Sky Solar Radiation	RadAvg		771	1069	1512	1961	2257	2466	2326	2082	1768	1311	909	680
	RadStd		101	125	132	157	144	102	75	88	68	80	55	95

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-283	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	-2.11	N/A	N/A	N/A	N/A	-194	+239	N/A

Nomenclature: See separate page