

BODEGA 6 WSW, CA, USA

WMO: 745180

Lat: 38.3208N

Lon: 123.0747W

Elev: 63

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 93245

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 38.4	(c) 40.5	(d) 24.4	(e) 18.6	(f) 48.9	(g) 29.5	(h) 23.6	(i) 46.7	(j) 16.2	(k) 54.2	(l) 14.7	(m) 53.3	(n) 2.8	(o) N/A	(p) 0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 9	(b) 10.3	(c) 68.2	(d) 60.0	(e) 65.8	(f) 59.1	(g) 63.9	(h) 58.5	(i) 62.2	(j) 66.1	(k) 60.8	(l) 64.4	(m) 59.8	(n) 63.0	(o) 4.4	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	78.5	63.4	59.2	75.2	62.3	58.1	72.4	61.3	27.9	66.1	27.0	64.8	26.2	63.2	68.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.9	(b) 12.9	(c) 11.3	(e) 33.5	(f) 79.8	(g) 2.1	(h) 6.4	(i) 31.9	(j) 84.4	(k) 30.7	(l) 88.1	(m) 29.5	(n) 91.7	(o) 27.9	(p) 96.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	50.7	50.5	51.1	51.6	52.7	54.9	56.3	57.4	57.3	56.1	53.3	49.9
	DBStd	4.22	3.69	4.10	3.07	2.77	1.94	2.26	2.64	2.91	3.22	3.78	3.81	4.11
	HDD50	176	35	40	24	12	2	0	0	0	0	1	10	52
	HDD65	4202	443	405	432	402	382	302	269	234	234	279	353	467
	CDD50	1453	56	54	57	60	85	148	197	231	218	189	108	50
	CDD65	4	0	0	0	0	0	0	0	0	2	2	0	0
	CDH74	22	0	0	0	4	0	0	0	0	5	10	3	0
	CDH80	6	0	0	0	1	0	0	0	0	1	4	0	0
Wind	WSAvg	4.8	5.0	5.7	5.4	5.7	5.5	5.0	4.1	3.9	4.0	4.0	4.3	5.0
Precipitation	PrecAvg	48.5	9.3	8.8	5.6	3.1	2.0	0.5	0.0	0.1	0.1	2.1	4.9	10.9
	PrecMax	75.2	28.3	27.0	17.2	10.5	7.0	2.5	0.2	1.3	0.5	5.7	12.6	24.6
	PrecMin	27.0	0.1	0.5	0.2	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.5
	PrecStd	14.4	6.7	6.5	5.0	2.6	2.2	0.7	0.0	0.3	0.1	1.6	3.6	7.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.8	66.3	62.1	64.6	63.6	66.0	68.2	68.6	71.6	71.1	68.5	62.2
		MCWB	52.6	55.5	53.6	56.8	55.0	59.7	61.6	62.0	61.4	54.1	56.7	52.7
	2%	DB	59.9	60.4	58.8	59.2	59.5	62.9	65.1	65.9	67.3	66.2	63.0	59.3
		MCWB	52.0	54.3	54.7	55.5	55.2	58.1	59.7	60.6	61.4	57.9	55.5	55.8
	5%	DB	57.2	58.1	57.3	57.4	58.2	60.9	62.5	63.8	64.5	63.6	60.2	57.6
		MCWB	52.4	54.3	54.1	54.2	54.3	56.6	58.3	59.4	59.8	57.8	55.0	54.0
	10%	DB	55.7	56.3	56.0	56.2	56.9	59.4	60.7	62.0	62.6	61.6	58.5	56.1
		MCWB	52.4	53.2	53.4	53.2	53.4	55.4	57.2	58.4	58.7	57.2	54.4	52.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.5	58.2	57.4	58.7	57.5	60.6	62.4	63.0	64.8	62.2	60.0	59.3
		MCDB	57.5	62.1	58.7	63.0	62.2	64.4	67.5	67.0	68.3	65.6	63.5	59.8
	2%	WB	55.4	56.5	56.3	56.6	56.0	58.9	60.4	61.3	62.7	60.7	58.5	57.8
		MCDB	56.6	59.4	57.7	58.6	59.6	62.8	64.6	65.1	66.0	63.8	60.7	58.8
	5%	WB	54.4	55.2	55.1	55.2	55.1	57.4	59.2	60.0	60.9	59.7	57.2	56.3
		MCDB	56.0	57.7	56.7	57.0	58.1	60.4	62.6	63.2	64.4	62.4	58.9	57.2
	10%	WB	53.4	54.0	54.1	54.0	54.1	56.1	58.0	58.9	59.3	58.6	56.1	54.7
		MCDB	55.3	56.2	55.8	56.0	56.9	58.8	60.8	61.8	62.6	61.2	57.9	55.7
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.0	9.4	9.4	9.2	9.9	9.6	9.3	10.3	10.6	10.8	10.2
		MCDBR	12.8	12.4	10.5	10.5	10.6	11.1	10.8	10.7	12.4	13.8	13.4	11.1
		MCWBR	8.3	8.4	8.0	7.8	7.3	7.2	6.4	6.2	7.4	8.0	8.5	8.2
	5% WB	MCDBR	8.6	10.0	9.0	9.7	10.0	10.5	10.3	10.1	11.1	10.8	9.5	6.3
		MCWBR	7.1	7.4	7.5	7.6	7.2	6.9	6.2	6.2	7.1	7.1	7.3	6.2
Clear-Sky Solar Irradiance	taub	0.320	0.327	0.333	0.355	0.358	0.351	0.357	0.337	0.337	0.329	0.316	0.320	
	taud	2.568	2.548	2.534	2.436	2.460	2.483	2.469	2.530	2.512	2.580	2.588	2.567	
	Ebn at Noon	275	287	295	293	292	293	290	295	290	283	274	266	
	Edh at Noon	23	27	30	35	35	35	35	32	30	26	23	22	
All-Sky Solar Radiation	RadAvg	722	1017	1440	1900	2211	2414	2218	1951	1683	1239	853	621	
	RadStd	109	134	133	142	152	119	111	103	93	89	65	98	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	N/A	N/A	-2.14	N/A	N/A	N/A	N/A	N/A	+229	N/A

Nomenclature: See separate page