

CORTEZ 8 SE, CO, USA

WMO: 745230

Lat: 37.2553N

Lon: 108.5035W

Elev: 2449

StdP: 75.16

Time Zone: -7.00 (NAM)

Period: 05-19

WBAN: 03061

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.6	-11.5	-22.6	0.7	-3.9	-20.3	0.8	-2.8	5.6	-3.7	4.9	-3.3	2.1	N/A	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	28.8	12.1	27.6	11.8	26.3	11.4	14.7	22.9	14.0	22.8	13.5	22.2	2.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	12.1	16.0	11.2	11.2	16.1	10.2	10.5	16.5	50.1	23.0	48.0	22.8	46.1	22.4	17.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.9	4.4	3.9	DB	-16.8	31.3	2.4	0.9	-18.5	32.0	-19.8	32.5	-21.2	33.1	-22.9	33.7	(4)
(5)			WB	-17.0	16.0	2.6	0.4	-18.9	16.3	-20.4	16.5	-21.9	16.8	-23.7	17.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-2.4	-1.1	3.4	6.9	11.5	18.9	20.7	19.7	16.1	9.3	3.7	-2.2	(6)
(7)		DBStd	9.34	4.18	4.76	4.87	4.84	4.77	3.56	2.29	2.43	3.70	4.72	5.08	4.75	(7)
(8)		HDD10.0	1710	386	311	209	113	42	1	0	0	6	69	193	379	(8)
(9)		HDD18.3	3703	644	544	463	342	213	36	6	15	82	281	440	638	(9)
(10)		CDD10.0	1255	0	0	5	21	89	269	333	300	188	47	3	0	(10)
(11)		CDD18.3	207	0	0	0	0	1	53	81	57	15	0	0	0	(11)
(12)		CDH23.3	1259	0	0	0	0	7	349	527	305	71	1	0	0	(12)
(13)		CDH26.7	206	0	0	0	0	0	56	108	38	4	0	0	0	(13)
(14)	Wind	WSAvg	2.0	2.1	2.2	2.2	2.4	2.1	2.0	1.8	1.6	1.8	2.0	2.0	2.0	(14)
(15)	Precipitation	PrecAvg	389	34	35	31	27	26	12	33	46	44	39	32	29	(15)
(16)		PrecMax	520	101	111	105	67	118	55	56	93	97	95	70	81	(16)
(17)		PrecMin	245	0	1	0	0	1	0	0	13	9	0	1	3	(17)
(18)		PrecStd	72	26	23	21	18	25	13	16	21	24	24	16	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.4	10.9	17.3	20.4	24.5	30.1	30.7	29.1	27.2	21.5	15.7	9.4	(19)
(20)			MCWB	1.4	2.8	5.4	6.4	8.2	11.3	12.7	12.0	11.5	8.6	5.2	1.4	(20)
(21)		2%	DB	5.8	9.0	14.8	17.9	22.4	28.3	29.1	27.8	25.3	19.1	13.9	7.1	(21)
(22)			MCWB	-0.2	1.6	4.4	5.7	7.7	11.2	12.5	11.9	10.6	7.3	4.4	0.7	(22)
(23)		5%	DB	4.2	7.1	12.4	16.2	20.7	26.8	27.9	26.6	23.8	17.6	12.1	5.4	(23)
(24)			MCWB	-1.0	0.8	3.0	5.0	7.2	10.5	12.4	11.7	10.0	6.7	3.3	-0.3	(24)
(25)		10%	DB	2.8	5.4	10.4	14.4	19.0	25.4	26.5	25.1	22.1	15.7	10.2	4.0	(25)
(26)			MCWB	-1.6	-0.2	2.0	4.1	6.4	9.6	12.3	11.7	9.6	6.0	2.4	-0.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	4.0	5.8	7.7	9.8	14.0	15.8	15.3	13.9	10.8	6.3	3.1	(27)
(28)			MCDWB	6.5	10.5	16.2	18.6	21.5	26.0	23.2	21.8	21.4	17.2	13.8	7.1	(28)
(29)		2%	WB	1.3	2.5	4.8	6.5	8.5	12.8	14.9	14.6	12.8	9.4	4.9	2.0	(29)
(30)			MCDWB	3.9	7.6	14.2	16.7	19.1	24.8	23.5	21.8	20.2	15.4	11.0	4.8	(30)
(31)		5%	WB	0.3	1.6	3.7	5.5	7.7	11.9	14.2	14.0	11.9	8.1	3.8	1.1	(31)
(32)			MCDWB	3.1	6.4	11.9	14.7	18.7	23.7	23.5	21.7	20.1	14.6	9.8	4.1	(32)
(33)		10%	WB	-0.7	0.7	2.6	4.6	6.9	11.0	13.8	13.3	11.2	7.2	2.9	0.1	(33)
(34)			MCDWB	2.3	5.2	10.0	13.3	17.5	22.5	22.9	21.4	19.1	14.1	9.0	3.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	6.9	8.7	10.7	10.6	11.0	11.7	10.9	10.2	9.4	8.1	6.5	(35)
(36)			MCDBR	7.1	7.9	9.9	11.4	11.4	11.7	12.7	11.6	11.0	10.0	8.9	7.3	(36)
(37)			MCWBR	4.5	4.6	5.1	5.5	5.3	5.1	4.5	4.4	4.5	4.9	4.7	4.4	(37)
(38)		5% WB	MCDBR	6.5	7.3	9.5	10.9	11.2	10.9	11.8	10.8	10.3	9.0	8.7	6.5	(38)
(39)			MCWBR	4.4	4.3	5.1	5.3	5.3	5.2	4.3	4.4	4.6	4.6	4.8	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.222	0.227	0.244	0.265	0.277	0.282	0.315	0.315	0.280	0.259	0.231	0.223	(40)	
(41)		taud	2.638	2.632	2.598	2.552	2.559	2.528	2.495	2.471	2.590	2.620	2.652	2.635	(41)	
(42)		Ebn at Noon	1009	1036	1035	1020	1003	993	957	954	980	981	987	985	(42)	
(43)		Edh at Noon	67	78	89	99	101	104	107	107	89	78	66	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.85	3.72	5.18	6.45	7.40	8.27	7.27	6.47	5.66	4.34	3.21	2.47	(44)	
(45)		RadStd	0.26	0.32	0.39	0.34	0.53	0.42	0.36	0.24	0.23	0.33	0.22	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page