

LA JUNTA 17 WSW, CO, USA

WMO: 745290

Lat: 37.8639N

Lon: 103.8224W

Elev: 1337

StdP: 86.26

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 03063

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-18.9	-15.6	-23.4	0.5	-10.7	-20.4	0.7	-6.2	9.5	7.3	8.0	8.5	1.4	N/A	0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	37.7	16.2	36.3	16.0	35.0	16.1	19.6	29.1	18.9	28.9	18.2	28.5	3.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	14.4	21.8	16.3	13.6	21.3	15.4	12.9	21.3	62.1	29.2	59.3	28.6	57.0	28.4	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.0	5.9	DB	-25.3	39.9	3.3	1.2	-27.7	40.8	-29.7	41.5	-31.5	42.1	-33.9	43.0	(4)
(5)			WB	-25.1	20.9	3.6	1.0	-27.6	21.7	-29.7	22.3	-31.7	22.9	-34.3	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-1.0	0.8	6.2	10.5	15.5	22.5	25.1	23.5	19.5	11.3	4.8	-1.2	(6)	
	DBStd	10.52	6.41	6.14	5.48	4.80	4.63	3.67	2.47	2.77	4.14	5.31	5.43	6.24	(7)	
	HDD10.0	1367	341	263	138	51	10	0	0	0	1	46	170	347	(8)	
	HDD18.3	3092	598	492	375	237	110	8	0	2	35	224	407	604	(9)	
	CDD10.0	1918	1	4	22	65	181	376	467	417	286	86	13	1	(10)	
	CDD18.3	603	0	0	0	2	22	134	209	161	70	5	0	0	(11)	
	CDH23.3	9737	1	6	51	173	665	2172	2891	2189	1301	264	24	1	(12)	
	CDH26.7	5139	0	1	6	36	271	1209	1701	1189	645	79	2	0	(13)	
(14) Wind	WSAvg	2.4	2.0	2.3	2.6	3.1	2.9	2.9	2.5	2.2	2.1	2.0	2.0	2.0	(14)	
(15) Precipitation	PrecAvg	386	12	10	24	41	47	45	62	59	29	23	18	13	(15)	
	PrecMax	466	28	32	61	120	122	96	131	119	57	74	51	90	(16)	
	PrecMin	226	1	0	1	7	12	11	17	19	8	0	1	3	(17)	
	PrecStd	63	7	8	17	30	33	23	35	25	15	23	15	21	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	24.0	27.5	30.3	34.7	39.7	39.2	38.4	36.5	31.5	26.0	20.7	(19)	
		MCWB	7.7	8.8	9.9	11.3	13.6	15.4	17.0	15.9	15.5	12.8	9.7	7.5	(20)	
	2%	DB	17.6	19.9	24.8	27.5	32.2	37.3	37.7	36.5	34.7	29.0	23.4	17.2	(21)	
		MCWB	6.1	7.0	8.9	10.7	12.9	15.2	16.8	16.1	15.0	11.7	9.2	5.9	(22)	
	5%	DB	14.0	17.1	22.2	25.4	29.9	35.5	36.5	35.0	32.9	26.7	20.2	14.1	(23)	
		MCWB	4.7	5.9	8.0	10.2	13.0	15.1	16.7	16.4	15.0	11.6	7.7	4.5	(24)	
	10%	DB	10.7	13.2	18.9	22.8	27.4	33.5	35.1	33.2	30.8	23.6	16.8	10.7	(25)	
		MCWB	3.2	4.1	6.9	9.4	12.3	15.4	17.2	16.6	14.3	10.6	6.5	3.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	9.1	10.9	13.1	16.6	19.4	20.8	20.7	18.4	15.5	10.5	8.0	(27)	
		MCDB	19.1	22.8	24.2	23.3	26.5	31.5	30.3	28.9	28.1	23.9	23.4	19.5	(28)	
	2%	WB	6.2	7.6	9.6	12.0	15.2	18.2	19.8	19.6	17.2	13.8	9.2	6.1	(29)	
		MCDB	16.2	19.7	24.0	23.1	26.1	29.8	29.4	28.2	27.1	23.8	21.7	16.1	(30)	
	5%	WB	4.9	6.3	8.6	11.1	14.1	17.6	19.1	18.7	16.5	12.5	7.9	4.8	(31)	
		MCDB	13.4	17.2	21.3	22.6	25.7	29.1	29.0	28.4	27.9	23.0	18.8	13.8	(32)	
	10%	WB	3.3	4.6	7.5	10.1	13.2	16.8	18.5	18.0	15.8	11.4	6.6	3.2	(33)	
		MCDB	10.1	13.6	18.9	21.6	24.2	28.8	28.7	28.0	27.5	22.2	16.5	10.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	17.9	18.1	19.7	18.8	18.5	19.3	18.2	17.9	19.3	19.8	19.8	17.8	(35)	
		MCDBR	22.8	24.3	24.7	23.6	23.0	21.9	20.9	20.6	22.1	24.3	24.9	23.3	(36)	
	5% WB	MCWBR	13.2	12.7	11.9	10.1	9.0	6.9	5.7	5.7	7.5	10.9	12.9	14.0	(37)	
		MCWBR	22.0	23.6	23.6	21.5	19.9	19.1	16.7	17.0	18.4	20.3	23.5	22.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.244	0.252	0.277	0.307	0.326	0.345	0.374	0.354	0.317	0.278	0.256	0.246	(40)	
	taud		2.606	2.605	2.523	2.435	2.440	2.406	2.390	2.426	2.494	2.595	2.581	2.592	(41)	
	Ebn at Noon		971	1001	994	973	952	930	899	913	935	954	945	944	(42)	
	Edh at Noon		70	80	96	111	113	117	118	111	98	80	71	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.83	3.70	5.01	6.14	7.00	7.59	7.35	6.60	5.60	4.24	3.12	2.47	(44)	
	RadStd		0.19	0.28	0.36	0.35	0.41	0.31	0.26	0.23	0.27	0.27	0.21	0.16	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+77	+41

Nomenclature: See separate page