

NUNN 7 NNE, CO, USA

WMO: 745340

Lat: 40.8066N

Lon: 104.7552W

Elev: 5390

StdP: 12.05

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 94074

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.9	1.5	-11.8	3.5	-3.5	-5.6	5.0	7.2	26.9	32.0	24.4	32.5	3.9	N/A	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.0	93.2	58.8	90.6	58.6	87.7	58.6	64.3	79.6	63.1	78.9	61.9	78.5	7.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	95.5	67.2	58.7	90.2	66.6	57.0	84.9	66.1	32.5	79.4	31.4	78.5	30.5	78.7	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.1	20.1	17.2	DB	-16.4	98.1	5.5	2.2	-20.3	99.6	-23.5	100.9	-26.6	102.1	-30.6	103.7	(4)
			WB	-16.8	67.6	6.5	1.4	-21.5	68.6	-25.3	69.5	-28.9	70.2	-33.6	71.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	28.5	28.9	39.0	44.8	53.3	64.7	70.9	68.9	61.0	47.6	36.6	26.8	(6)
		DBStd	17.81	11.14	11.58	9.57	8.52	8.29	6.22	4.64	5.03	7.30	9.55	10.40	11.33	(7)
		HDD50	3162	666	592	355	193	63	1	0	9	155	408	720		(8)
		HDD65	6766	1130	1011	807	605	366	78	10	24	159	540	851	1185	(9)
		CDD50	2321	1	1	13	38	167	443	649	585	337	80	7	0	(10)
		CDD65	450	0	0	0	0	4	70	194	144	38	0	0	0	(11)
		CDH74	7998	0	0	5	31	260	1493	2869	2270	973	96	1	0	(12)
		CDH80	3352	0	0	0	2	45	615	1365	975	341	9	0	0	(13)
(14)	Wind	WSAvg	6.7	6.8	7.3	7.9	8.6	7.3	6.2	5.5	5.6	5.8	6.4	6.4	6.5	(14)
(15)	Precipitation	PrecAvg	14.1	0.3	0.4	0.9	1.4	2.3	2.0	1.9	1.5	1.3	0.9	0.6	0.3	(15)
(16)		PrecMax	18.9	0.9	0.7	3.6	3.5	5.9	4.6	3.7	5.2	5.6	2.4	1.3	1.3	(16)
(17)		PrecMin	8.5	0.0	0.0	0.0	0.1	1.0	0.6	0.7	0.2	0.1	0.0	0.2	0.0	(17)
(18)		PrecStd	2.7	0.2	0.2	0.9	0.9	1.3	1.1	0.8	0.9	1.1	0.6	0.3	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	62.7	65.5	74.1	78.0	84.9	95.9	96.5	94.7	91.5	81.3	71.2	59.8		(19)
(20)		MCWB	41.4	43.6	47.4	49.8	56.0	58.0	59.3	57.9	56.9	52.8	46.1	40.8		(20)
(21)		DB	55.8	58.2	68.6	73.4	80.5	91.4	93.6	91.4	87.2	76.7	65.9	54.5		(21)
(22)		MCWB	39.0	40.0	44.9	48.3	53.3	57.0	59.8	58.5	55.7	51.4	45.1	38.6		(22)
(23)		DB	50.9	53.1	63.6	68.7	76.8	87.0	91.1	88.9	84.3	72.4	60.9	49.8		(23)
(24)		MCWB	37.1	38.4	43.2	46.9	52.7	57.9	60.1	58.1	54.9	49.2	42.7	36.2		(24)
(25)		DB	45.9	47.7	58.4	63.9	71.8	83.0	88.1	86.0	80.2	66.9	55.3	44.5		(25)
(26)		MCWB	34.7	35.5	41.2	45.4	52.4	57.7	60.2	58.2	54.8	47.5	40.4	33.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	42.3	44.4	48.2	51.4	59.9	65.7	66.6	65.0	62.8	55.1	47.4	41.6		(27)
(28)		MCDB	59.0	64.2	71.5	71.9	73.0	80.7	81.2	78.7	79.2	72.6	66.5	58.7		(28)
(29)		WB	39.6	41.3	46.0	49.6	57.1	63.0	64.9	63.0	60.4	53.1	45.3	39.1		(29)
(30)		MCDB	54.0	58.1	67.0	68.2	69.6	78.4	80.2	79.3	76.9	70.3	64.3	53.6		(30)
(31)		WB	37.6	39.1	44.0	48.0	55.0	61.1	63.8	61.8	58.5	50.8	43.0	36.9		(31)
(32)		MCDB	50.3	53.8	62.6	65.2	69.4	77.4	79.3	79.0	74.0	67.0	59.0	49.2		(32)
(33)		WB	35.3	36.4	41.9	46.1	53.1	59.6	62.6	60.5	57.0	48.7	40.7	34.4		(33)
(34)		MCDB	46.3	48.3	57.8	62.1	66.9	75.8	78.6	78.3	73.0	64.5	54.5	44.4		(34)
(35)	Mean Daily Temperature Range	MDBR	26.1	26.3	28.6	27.4	26.5	30.5	31.0	31.1	30.6	28.4	27.5	25.0		(35)
(36)		5% DB	32.1	33.5	37.2	37.7	35.7	38.9	37.1	36.5	37.8	37.7	34.9	31.4		(36)
(37)		MCWBR	19.4	18.7	17.9	16.6	14.3	13.5	10.4	11.3	13.4	16.2	17.9	18.6		(37)
(38)		5% WB	32.0	33.1	35.8	34.3	29.7	32.5	29.4	31.5	29.7	32.4	33.9	31.0		(38)
(39)		MCWBR	19.1	18.4	17.5	15.9	13.8	13.4	10.6	10.8	11.9	14.7	17.5	18.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.239	0.246	0.269	0.295	0.320	0.324	0.352	0.345	0.308	0.269	0.252	0.242		(40)
(41)		taud	2.594	2.585	2.528	2.479	2.466	2.477	2.437	2.447	2.532	2.620	2.577	2.569		(41)
(42)		Ebn at Noon	304	315	315	311	303	300	291	291	297	302	294	292		(42)
(43)		Edh at Noon	21	25	30	33	35	34	36	34	29	23	21	20		(43)
(44)	All-Sky Solar Radiation	RadAvg	757	1058	1456	1732	1945	2283	2194	1929	1626	1153	821	644		(44)
(45)		RadStd	34	65	105	116	163	117	88	57	88	81	47	42		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page