

COSHOCTON 8 NNE, OH, USA

WMO: 745710

Lat: 40.3667N

Lon: 81.7829W

Elev: 341

StdP: 97.29

Time Zone: -5.00 (NAE)

Period: 06-16

WBAN: 54851

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.2	-13.5	-20.8	0.6	-15.5	-18.4	0.8	-12.8	8.2	-0.1	7.5	-2.3	2.7	N/A	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	30.6	22.3	29.4	21.8	28.3	21.3	24.1	29.0	23.2	27.4	22.5	26.4	2.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	18.1	26.7	21.9	17.3	25.5	21.2	16.5	24.8	74.3	29.0	70.9	27.7	67.9	26.1	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.8	5.9	5.2	-19.9	32.0	3.7	1.9	-22.5	33.4	-24.7	34.5	-26.7	35.5	-29.4	36.9		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-3.0	-2.6	4.9	10.8	16.5	20.5	22.2	21.7	18.1	11.8	5.8	1.3	(6)
(7)		DBStd	10.17	6.38	6.33	6.62	5.30	4.63	2.97	2.84	2.64	3.82	4.72	5.45	5.77	(7)
(8)		HDD10.0	1463	405	353	189	53	5	0	0	0	1	35	147	275	(8)
(9)		HDD18.3	3173	661	586	419	232	92	14	4	4	49	209	376	528	(9)
(10)		CDD10.0	1732	3	1	29	76	207	316	378	362	243	90	21	6	(10)
(11)		CDD18.3	399	0	0	1	4	36	79	123	108	43	6	0	0	(11)
(12)		CDH23.3	2762	0	0	7	47	257	533	887	710	282	38	0	0	(12)
(13)		CDH26.7	653	0	0	0	4	40	118	251	167	67	6	0	0	(13)
(14)	Wind	WSAvg	2.3	3.0	3.0	2.9	2.9	2.0	1.8	1.7	1.6	1.8	2.2	2.5	2.8	(14)
(15)	Precipitation	PrecAvg	1042	79	56	80	93	110	111	110	95	81	75	72	79	(15)
(16)		PrecMax	1390	191	122	187	140	201	211	272	169	174	142	129	192	(16)
(17)		PrecMin	702	40	29	25	48	46	28	48	25	33	26	28	29	(17)
(18)		PrecStd	159	35	24	35	27	46	49	53	42	37	32	25	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.2	15.7	24.2	27.4	29.6	31.0	33.2	31.7	30.8	27.7	20.6	17.5	(19)
(20)		MCWB	13.9	9.4	15.5	16.0	21.9	21.7	23.4	22.0	21.7	16.8	14.1	14.8	(20)	
(21)		2%	DB	13.5	12.7	20.7	24.6	27.8	29.5	30.7	30.1	28.8	23.9	18.6	14.9	(21)
(22)		MCWB	10.7	8.3	14.0	15.4	20.0	21.3	23.1	21.8	21.8	17.0	12.3	12.6	(22)	
(23)		5%	DB	9.6	10.0	17.9	22.3	26.3	28.1	29.4	28.7	26.5	21.8	16.4	12.8	(23)
(24)		MCWB	7.4	6.0	11.9	14.0	19.3	20.8	22.2	21.5	20.8	15.8	10.9	10.6	(24)	
(25)		10%	DB	6.2	6.5	15.3	19.9	24.6	26.6	28.0	27.1	24.6	19.7	14.4	10.5	(25)
(26)		MCWB	4.2	3.3	10.7	12.9	18.5	20.1	21.6	21.1	19.2	14.8	9.6	8.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	11.8	16.9	17.9	22.9	24.0	25.7	24.6	24.0	20.0	16.3	15.5	(27)
(28)		MDCB	16.2	13.9	23.7	24.0	28.6	29.1	30.7	28.9	29.3	22.6	20.1	16.9	(28)	
(29)		2%	WB	10.9	8.9	14.9	16.5	21.3	22.8	24.6	23.5	22.5	17.9	13.4	13.5	(29)
(30)		MDCB	12.2	12.9	18.9	21.7	26.2	27.3	29.6	27.4	26.2	21.1	16.0	14.9	(30)	
(31)		5%	WB	7.0	5.9	13.5	15.4	20.4	21.9	23.7	22.8	21.4	16.3	11.9	11.4	(31)
(32)		MDCB	8.6	9.6	17.1	20.0	25.3	26.5	28.3	26.3	25.1	20.1	15.5	12.9	(32)	
(33)		10%	WB	3.4	3.3	11.1	14.1	19.4	21.2	22.7	21.9	20.3	14.9	10.3	8.9	(33)
(34)		MDCB	5.9	5.9	14.5	17.6	24.0	25.1	26.6	25.3	23.5	18.7	13.8	10.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	7.5	7.8	9.4	10.4	10.2	9.7	9.4	9.6	9.7	9.1	8.3	7.0	(35)	
(36)		5% DB	MDCDBR	10.4	11.3	12.4	13.2	11.8	11.5	10.8	11.2	11.2	12.0	10.9	9.9	(36)
(37)		MCWBR	10.2	9.1	7.5	7.6	5.7	5.8	4.8	4.6	4.7	6.6	7.4	7.8	(37)	
(38)		5% WB	MDCDBR	10.1	11.6	10.9	11.3	10.3	9.8	9.7	9.1	9.1	10.8	9.7	8.2	(38)
(39)		MCWBR	9.9	9.5	6.8	7.6	5.4	5.6	5.0	4.4	4.5	6.9	7.7	7.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.303	0.324	0.350	0.389	0.428	0.454	0.458	0.448	0.389	0.359	0.320	0.303	(40)	
(41)		taud	2.446	2.367	2.366	2.279	2.192	2.161	2.166	2.183	2.323	2.404	2.488	2.477	(41)	
(42)		Ebn at Noon	860	888	901	884	853	828	820	818	848	837	835	832	(42)	
(43)		Edh at Noon	79	99	111	129	144	149	147	141	114	95	76	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.54	2.39	3.37	4.58	5.40	5.88	5.81	5.34	4.34	2.93	1.95	1.32	(44)	
(45)		RadStd	0.14	0.32	0.33	0.44	0.45	0.44	0.39	0.28	0.39	0.27	0.27	0.15	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	+68

Nomenclature: See separate page