

OCEAN CITY, MD, USA

WMO: 745946

Lat: 38.308N

Lon: 75.124W

Elev: 4

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 00-19

WBAN: 93786

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.0	-7.0	-18.0	0.8	-7.2	-15.6	1.0	-5.0	11.6	1.1	10.4	0.6	3.7	330	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	32.3	24.8	30.9	24.6	29.5	24.1	26.5	30.3	25.7	29.2	25.2	28.4	3.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.3	20.5	28.5	24.8	19.8	27.9	24.1	19.0	27.1	82.3	30.2	79.2	29.3	76.6	28.3	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.5	7.6	-12.9	36.0	4.0	1.7	-15.8	37.2	-18.1	38.3	-20.3	39.2	-23.2	40.5		
(5)			-13.8	27.6	3.3	0.7	-16.3	28.1	-18.2	28.5	-20.1	28.9	-22.5	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	2.3	3.5	7.0	12.1	17.2	22.3	25.1	24.2	21.3	15.3	9.4	5.4	(6)
(7)		DBStd	8.98	5.52	4.91	4.73	4.44	4.13	3.40	2.76	2.72	3.23	4.46	4.46	4.76	(7)
(8)		HDD10.0	808	244	190	119	26	1	0	0	0	0	6	64	157	(8)
(9)		HDD18.3	2332	497	416	353	193	73	6	0	0	11	115	269	400	(9)
(10)		CDD10.0	2201	6	7	25	89	224	370	467	440	338	172	46	16	(10)
(11)		CDD18.3	683	0	0	1	7	38	126	209	182	99	22	1	0	(11)
(12)		CDH23.3	5126	0	0	6	42	176	884	1896	1505	544	74	1	0	(12)
(13)		CDH26.7	1342	0	0	1	10	32	245	566	388	91	8	0	0	(13)
(14)	Wind	WSAvg	3.5	3.9	3.9	4.1	4.0	3.5	3.2	2.9	2.8	3.4	3.6	3.5	3.5	(14)
(15)	Precipitation	PrecAvg	1115	82	74	109	84	84	91	101	112	106	88	84	97	(15)
(16)		PrecMax	1523	188	169	229	141	163	203	184	304	219	166	187	198	(16)
(17)		PrecMin	852	36	14	7	29	21	35	25	17	12	1	3	42	(17)
(18)		PrecStd	181	34	39	49	29	40	40	44	63	58	50	52	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	19.1	22.3	28.1	30.0	33.6	35.0	34.5	31.2	27.4	22.0	19.0	(19)
(20)			MCWB	14.2	13.0	14.8	18.9	22.8	24.5	26.1	25.8	24.2	21.4	18.2	15.3	(20)
(21)		2%	DB	14.6	15.3	18.3	23.7	27.1	31.2	32.4	31.6	28.8	25.2	19.3	16.6	(21)
(22)			MCWB	12.2	11.3	13.3	17.5	21.3	23.6	25.4	25.1	23.6	21.4	16.5	14.5	(22)
(23)		5%	DB	12.5	12.7	15.9	21.1	25.2	29.3	31.0	30.0	27.4	23.7	17.8	14.8	(23)
(24)			MCWB	10.4	9.5	12.2	16.6	20.5	23.2	24.9	24.6	23.0	20.5	15.4	13.0	(24)
(25)		10%	DB	10.6	11.0	13.7	18.6	23.4	27.7	29.6	28.7	26.2	22.3	16.7	13.0	(25)
(26)			MCWB	8.7	8.6	10.7	14.4	19.7	22.7	24.5	24.1	22.3	19.4	14.6	11.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.0	15.0	16.5	20.3	24.0	26.3	27.7	27.0	25.8	24.0	19.2	16.8	(27)
(28)			MCDWB	16.9	17.6	21.3	24.9	28.0	30.3	32.1	31.1	29.1	25.8	20.7	17.9	(28)
(29)		2%	WB	12.8	12.4	14.5	18.7	22.6	25.2	26.7	26.3	25.0	22.8	17.5	14.9	(29)
(30)			MCDWB	14.4	14.2	17.3	22.7	25.8	29.3	30.6	30.0	27.6	24.7	18.5	16.1	(30)
(31)		5%	WB	11.0	10.5	12.9	17.1	21.5	24.4	25.9	25.6	24.3	21.3	16.1	13.4	(31)
(32)			MCDWB	12.0	12.3	15.1	20.4	24.5	28.0	29.4	28.9	26.5	22.9	17.4	14.5	(32)
(33)		10%	WB	8.9	8.7	11.3	15.5	20.4	23.7	25.3	25.1	23.5	20.0	14.9	11.8	(33)
(34)			MCDWB	10.1	10.6	13.3	18.0	22.9	26.8	28.5	28.0	25.4	21.7	16.4	12.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	9.0	8.7	8.8	8.1	7.8	7.7	7.8	7.8	9.0	9.5	8.9	(35)
(36)			MCDBR	10.4	11.0	11.0	11.8	10.3	9.7	9.0	8.8	8.4	9.4	9.6	9.6	(36)
(37)			MCWBR	8.7	8.6	7.7	6.4	5.7	4.5	4.0	4.1	4.9	6.1	7.6	8.5	(37)
(38)		5% WB	MCDWR	9.6	10.4	10.0	10.1	9.0	8.4	7.8	7.4	6.7	7.3	8.5	8.8	(38)
(39)			MCWBR	8.9	9.0	8.0	6.5	5.5	4.4	4.0	3.9	4.2	5.5	7.7	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.324	0.356	0.394	0.442	0.482	0.503	0.500	0.409	0.363	0.331	0.319	(40)	
(41)		taud	2.501	2.489	2.434	2.342	2.242	2.176	2.133	2.129	2.368	2.493	2.529	2.536	(41)	
(42)		Ebn at Noon	861	906	905	885	844	808	786	778	838	849	841	836	(42)	
(43)		Edh at Noon	79	90	105	123	138	148	153	150	112	90	76	72	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.14	2.98	4.06	5.19	5.88	6.41	6.22	5.58	4.55	3.43	2.44	1.89	(44)	
(45)		RadStd	0.19	0.30	0.34	0.37	0.62	0.49	0.31	0.37	0.43	0.33	0.22	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (62 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+143	+89

Nomenclature: See separate page