

BICYCLE LAKE AAF, CA, USA

WMO: 746110

Lat: 35.283N

Lon: 116.633W

Elev: 76

StdP: 100.42

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 03182

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-0.8	1.0	-21.9	0.5	7.2	-19.8	0.7	7.7	17.8	10.4	15.4	8.7	1.9	310	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	41.0	18.7	39.5	18.1	38.1	17.6	20.6	32.9	20.0	33.4	19.4	33.9	4.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.3	25.4	14.9	10.7	26.6	12.6	9.2	28.2	59.3	32.3	57.1	33.2	55.1	34.2	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.8	12.4	10.9	DB	-3.3	42.9	2.4	1.4	-5.1	43.9	-6.5	44.7	-7.9	45.4	-9.6	46.4	(4)
(5)			WB	-7.1	21.6	1.9	0.8	-8.4	22.1	-9.5	22.6	-10.6	23.0	-11.9	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	10.1	11.7	15.1	18.7	21.5	28.4	31.2	30.6	26.8	20.0	13.5	8.9	(6)	
	DBStd	8.56	3.46	4.43	4.01	4.01	4.38	3.69	2.64	2.40	3.71	3.81	4.10	3.28	(7)	
	HDD10.0	160	43	33	6	1	0	0	0	0	0	1	15	62	(8)	
	HDD18.3	1092	256	187	114	43	21	1	0	0	1	25	152	293	(9)	
	CDD10.0	3716	46	81	164	262	357	551	657	638	503	311	120	26	(10)	
	CDD18.3	1607	0	1	14	54	119	301	399	379	254	77	7	0	(11)	
	CDH23.3	22506	0	9	143	602	1453	4352	6138	5673	3310	762	65	0	(12)	
(13)	CDH26.7	13048	0	0	26	198	651	2672	3947	3542	1778	230	4	0	(13)	
(14)	Wind	WSAvg	4.1	2.9	3.9	4.7	5.2	4.9	4.3	4.1	3.9	3.6	3.3	3.3	(14)	
(15) Precipitation	PrecAvg	123	18	28	13	5	2	1	8	5	8	7	9	16	(15)	
	PrecMax	222	78	93	74	30	14	7	37	17	48	54	55	76	(16)	
	PrecMin	29	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	60	24	28	17	7	4	2	10	5	13	12	12	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.3	24.5	29.3	33.5	36.3	42.8	42.9	41.3	38.8	32.8	27.1	20.3	(19)	
		MCWB	9.7	10.4	12.7	14.7	15.7	18.2	19.6	18.8	18.2	15.1	12.4	9.3	(20)	
	2%	DB	19.1	22.9	27.0	31.1	34.5	40.3	41.3	39.9	36.8	30.9	25.2	18.4	(21)	
		MCWB	8.7	10.0	12.0	13.7	14.9	17.6	19.0	18.4	17.5	14.6	11.2	9.0	(22)	
	5%	DB	17.5	21.2	24.7	28.9	32.5	38.6	39.9	38.5	35.6	29.1	23.4	16.8	(23)	
		MCWB	7.8	9.4	10.8	12.7	14.1	17.0	18.6	18.0	17.2	13.7	10.4	8.2	(24)	
	10%	DB	15.9	19.2	22.6	26.9	30.4	37.0	38.3	37.4	34.2	27.6	21.2	15.0	(25)	
		MCWB	7.0	8.7	10.1	12.0	13.6	16.4	18.0	17.5	16.4	12.9	9.8	7.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	13.4	13.5	15.3	16.2	19.3	21.4	21.5	20.2	17.8	13.0	12.1	(27)	
		MCDB	17.3	19.7	24.9	31.5	35.0	38.7	32.4	31.6	31.5	25.5	24.7	16.8	(28)	
	2%	WB	10.2	11.3	12.4	14.1	15.3	18.5	20.7	20.5	19.6	16.3	12.2	10.9	(29)	
		MCDB	15.0	18.6	24.4	29.1	33.2	38.3	33.4	32.1	31.5	25.5	23.2	15.4	(30)	
	5%	WB	9.5	10.1	11.6	13.2	14.6	17.7	20.2	19.9	18.9	15.1	11.3	9.9	(31)	
		MCDB	14.5	19.2	23.1	27.1	30.9	36.7	34.0	33.1	31.4	26.1	21.2	14.7	(32)	
	10%	WB	8.6	9.2	10.7	12.4	13.9	16.9	19.6	19.1	18.2	14.1	10.3	8.5	(33)	
		MCDB	14.3	18.1	21.0	25.1	29.1	35.0	34.5	34.0	31.0	25.3	19.5	13.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	10.5	11.4	12.8	13.2	14.6	13.0	13.1	12.5	12.2	11.7	9.9	(35)	
		MCDBR	11.6	12.4	13.5	15.0	15.0	15.8	14.7	14.0	13.3	13.5	15.1	12.8	(36)	
	5% WB	MCWBR	6.4	5.8	5.7	6.0	5.3	5.0	4.9	4.9	5.0	6.0	7.6	7.5	(37)	
		MCWBR	10.7	11.2	12.8	14.0	14.9	15.2	11.5	11.8	11.4	11.1	13.2	9.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.289	0.299	0.311	0.349	0.365	0.361	0.397	0.383	0.356	0.326	0.292	0.290	(40)	
		taud	2.523	2.508	2.467	2.347	2.331	2.359	2.336	2.358	2.409	2.473	2.542	2.540	(41)	
	Ebn at Noon	Ebn at Noon	923	951	964	934	918	917	881	890	901	905	912	900	(42)	
		Edh at Noon	80	91	104	123	127	124	126	121	109	93	78	75	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	3.18	4.19	5.67	7.07	7.98	8.55	7.80	7.29	6.33	4.81	3.57	2.86	(44)	
	RadStd	RadStd	0.23	0.34	0.22	0.21	0.28	0.29	0.33	0.25	0.20	0.22	0.14	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.59	N/A	-1.96	N/A	N/A	N/A	N/A	-87	+192	+102

Nomenclature: See separate page