

CREECH AFB, NV, USA

WMO: 746141

Lat: 36.583N

Lon: 115.683W

Elev: 3133

StdP: 13.11

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 23141

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.8	24.9	-10.4	3.5	49.5	-5.2	4.7	54.3	26.7	54.6	23.0	48.9	2.3	250	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.7	104.5	63.9	102.1	63.2	100.0	62.9	70.4	93.5	68.4	90.8	67.1	90.0	9.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.2	101.0	78.0	61.3	90.9	78.9	58.2	81.2	81.8	36.2	93.2	34.4	89.7	33.2	89.6	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.9	23.2	19.1	16.2	107.9	2.2	1.2	14.6	108.8	13.3	109.5	12.1	110.2	10.4	111.1		
			12.3	71.3	2.3	2.0	10.6	72.7	9.3	73.9	8.0	75.0	6.3	76.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.8	42.4	46.5	53.8	61.2	68.6	80.8	86.2	83.5	75.6	62.5	50.3	41.1	(6)
	DBStd	16.70	5.96	6.42	6.56	6.95	7.12	5.92	4.21	3.96	6.49	6.19	6.76	5.73	(7)
	HDD50	776	242	130	37	5	0	0	0	0	0	2	79	281	(8)
	HDD65	3077	702	518	348	150	47	1	0	0	8	121	440	742	(9)
	CDD50	5450	5	32	157	341	576	925	1122	1040	768	391	89	4	(10)
	CDD65	2276	0	0	2	37	159	475	657	575	326	45	0	0	(11)
	CDH74	35486	0	2	133	711	2376	7696	10534	8664	4579	758	33	0	(12)
	CDH80	20938	0	0	19	193	1032	4794	6846	5389	2462	202	1	0	(13)
(14) Wind	WSAvg	6.3	4.4	5.7	6.6	7.9	8.3	7.7	7.6	7.0	6.5	5.0	4.3	4.1	(14)
(15) Precipitation	PrecAvg	7.2	1.0	1.3	0.7	0.4	0.2	0.2	0.6	0.5	0.5	0.6	0.4	0.9	(15)
	PrecMax	13.8	4.4	3.9	3.9	1.9	0.5	0.8	2.0	1.9	2.3	3.0	1.9	5.7	(16)
	PrecMin	2.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	2.6	1.1	1.1	0.9	0.4	0.1	0.2	0.4	0.4	0.6	0.7	0.4	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.6	73.4	82.9	89.6	96.3	107.1	108.4	104.1	100.1	89.4	77.9	65.5	(19)
		MCWB	46.0	47.8	52.2	55.1	57.7	61.6	69.3	65.0	61.7	58.1	52.2	45.3	(20)
	2%	DB	62.9	69.5	77.6	85.3	92.8	103.6	105.7	102.0	97.3	85.1	74.1	61.4	(21)
		MCWB	44.5	47.0	50.4	53.5	56.7	61.8	65.2	63.6	62.0	55.4	49.8	45.0	(22)
	5%	DB	59.8	65.7	73.9	81.7	89.9	101.0	102.9	100.2	95.1	81.8	70.3	57.3	(23)
		MCWB	43.4	45.7	48.6	52.0	55.5	61.3	64.2	63.5	61.3	54.1	48.4	42.6	(24)
	10%	DB	55.8	61.7	70.2	78.0	86.1	98.3	100.5	98.3	92.7	78.3	66.1	53.9	(25)
		MCWB	41.8	44.3	47.3	50.5	54.3	60.1	63.7	63.3	60.2	52.4	46.8	41.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.6	51.1	53.3	56.9	61.2	70.1	73.6	80.1	73.2	62.3	54.0	51.0	(27)
		MCDB	57.2	63.7	77.6	84.5	91.2	100.1	105.5	97.4	92.1	75.2	73.7	59.6	(28)
	2%	WB	47.9	48.5	51.4	54.8	58.6	66.1	70.2	70.4	66.2	59.7	51.6	48.3	(29)
		MCDB	56.5	63.9	73.5	81.4	87.6	97.6	94.4	90.8	89.0	75.5	70.7	55.8	(30)
	5%	WB	45.5	47.1	50.0	53.1	56.7	63.8	68.7	68.2	64.2	57.4	49.7	45.5	(31)
		MCDB	55.6	63.0	70.7	77.6	85.3	95.7	91.4	89.2	88.0	72.6	67.5	53.6	(32)
	10%	WB	43.2	45.2	48.1	51.4	55.2	61.5	67.6	66.6	62.4	55.6	47.6	42.9	(33)
		MCDB	54.3	60.2	68.5	74.7	83.0	93.1	91.0	88.3	85.6	71.5	65.0	51.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	26.1	25.6	26.9	26.8	26.3	30.2	26.7	27.8	28.5	27.8	28.7	23.8	(35)
		MCDBR	31.6	32.3	32.5	31.8	31.5	32.7	30.0	30.4	31.1	32.0	33.1	29.9	(36)
	5% WB	MCWBR	17.8	15.9	15.0	14.3	13.1	14.0	12.6	12.8	13.9	14.4	17.0	17.0	(37)
		MCWBR	26.0	28.6	30.0	28.9	29.6	31.5	24.4	25.6	26.0	24.5	30.5	22.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.261	0.269	0.279	0.307	0.324	0.322	0.354	0.348	0.312	0.291	0.265	0.263	(40)
		taud	2.612	2.598	2.564	2.467	2.445	2.467	2.446	2.448	2.533	2.580	2.617	2.614	(41)
	Ebn at Noon		303	312	316	309	304	302	292	292	300	299	299	295	(42)
		Edh at Noon	23	26	30	35	36	35	36	35	30	26	22	21	(43)
(44) All-Sky Solar Radiation	RadAvg		952	1254	1737	2179	2462	2697	2387	2226	1954	1456	1080	843	(44)
	RadStd		79	116	80	97	138	125	126	115	82	92	44	62	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (12 neighbors)	N/A	N/A	-2.43	N/A	N/A	N/A	N/A	-209	+347	+157

Nomenclature: See separate page