

LOS ALAMOS 13 W, NM, USA

WMO: 746330

Lat: 35.8584N

Lon: 106.5214W

Elev: 2657

StdP: 73.22

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 03062

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.4	-16.2	-23.7	0.6	-11.5	-21.4	0.8	-9.8	6.6	-1.9	6.2	-1.7	0.9	N/A	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	25.1	10.6	24.0	10.5	22.8	10.5	14.2	19.8	13.6	19.6	13.0	19.3	2.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	12.5	16.0	11.6	11.8	15.3	10.8	11.2	14.6	49.8	19.6	47.6	19.7	45.7	19.4	16.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.8	5.3	4.7	DB	-25.5	27.4	2.6	1.3	-27.4	28.4	-28.9	29.1	-30.3	29.9	-32.2	30.8	(4)
			WB	-25.4	16.1	2.7	0.6	-27.3	16.6	-28.9	17.0	-30.3	17.3	-32.3	17.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-5.0	-3.4	0.5	4.1	8.1	13.9	15.4	14.2	11.1	5.6	0.4	-4.3
	DBStd	8.03	4.47	4.54	4.07	3.71	3.70	2.60	1.54	1.62	2.56	3.45	3.99	4.94
	HDD10.0	2287	464	377	295	179	80	3	0	1	17	139	287	444
	HDD18.3	4832	722	610	553	427	317	135	92	127	216	393	537	703
	CDD10.0	496	0	0	0	1	21	119	167	132	52	4	0	0
	CDD18.3	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDH23.3	161	0	0	0	0	1	81	60	17	2	0	0	0
	CDH26.7	4	0	0	0	0	0	3	1	0	0	0	0	0
Wind	WSAvg	2.1	2.1	2.4	2.4	2.6	2.5	2.3	1.7	1.6	1.7	2.0	2.0	2.0
Precipitation	PrecAvg	468	32	30	33	30	26	26	68	76	50	38	25	35
	PrecMax	642	98	71	78	92	79	55	124	150	103	102	87	105
	PrecMin	326	0	2	3	5	1	8	21	30	9	0	0	5
	PrecStd	87	26	20	19	24	21	15	27	33	23	28	22	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	11.2	15.7	18.0	22.5	27.1	26.3	25.1	23.5	19.4	15.5	11.3
		MCWB	1.3	1.9	4.3	5.5	7.2	10.1	11.2	10.9	10.7	6.9	4.4	1.2
	2%	DB	7.0	9.1	13.1	16.1	20.5	25.5	25.0	23.7	21.9	17.6	13.6	8.6
		MCWB	-0.1	1.2	3.0	4.7	6.7	9.8	11.4	11.5	10.1	6.5	3.4	0.6
	5%	DB	4.9	7.3	10.8	14.7	18.9	24.1	23.9	22.5	20.4	16.2	11.6	6.3
		MCWB	-0.9	0.4	1.8	4.2	6.2	9.3	11.5	11.8	9.6	5.9	2.5	-0.6
	10%	DB	3.0	5.0	9.0	12.8	17.2	22.8	22.6	21.2	19.0	14.4	9.2	4.2
		MCWB	-1.8	-0.7	0.9	3.1	5.6	8.8	11.8	12.0	9.3	5.4	1.4	-1.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.8	2.9	4.9	6.8	9.9	13.8	15.4	15.1	13.3	11.2	5.4	2.9
		MCDB	7.0	9.5	14.5	15.8	17.2	21.5	19.8	19.9	18.0	14.4	12.0	7.9
	2%	WB	0.8	1.8	3.7	5.7	8.0	12.7	14.5	14.1	12.3	9.1	4.0	1.5
		MCDB	5.2	7.8	12.5	14.0	16.0	20.8	19.8	19.6	17.9	13.7	10.2	6.2
	5%	WB	-0.2	0.8	2.6	4.9	7.0	11.7	13.8	13.6	11.6	7.7	3.1	0.4
		MCDB	4.4	6.6	10.3	12.9	15.6	20.0	19.7	19.4	17.5	13.3	9.1	4.9
	10%	WB	-1.2	-0.1	1.6	3.9	6.1	10.7	13.2	13.0	10.9	6.5	2.0	-0.5
		MCDB	2.7	5.5	8.5	11.9	15.4	19.5	19.5	19.0	16.7	13.2	8.0	3.9
Mean Daily Temperature Range	5% DB	MDBR	13.4	12.2	12.6	13.6	14.2	16.2	14.3	13.9	14.6	14.6	14.6	12.7
		MCDBR	16.7	15.5	15.8	16.7	16.8	18.3	16.6	16.1	17.1	17.9	18.8	15.8
		MCWBR	11.0	8.4	8.0	7.8	7.5	7.8	6.6	7.2	8.1	9.2	10.3	9.8
	5% WB	MCDBR	14.5	13.2	15.1	15.2	15.6	16.0	13.3	13.5	13.8	14.4	15.7	13.4
		MCWBR	9.9	7.9	7.9	7.6	7.6	7.6	6.4	6.8	7.3	8.2	9.1	8.6
Clear-Sky Solar Irradiance	taub	0.213	0.217	0.234	0.248	0.263	0.274	0.309	0.297	0.269	0.242	0.224	0.216	
	taud	2.735	2.752	2.684	2.638	2.631	2.588	2.553	2.551	2.657	2.721	2.709	2.716	
	Ebn at Noon	1034	1059	1053	1040	1019	1002	964	975	997	1011	1009	1011	
	Edh at Noon	63	70	83	92	94	98	101	99	84	72	64	60	
All-Sky Solar Radiation	RadAvg	3.12	4.04	5.42	6.64	7.50	7.95	6.95	6.40	5.69	4.55	3.43	2.72	
	RadStd	0.25	0.34	0.38	0.33	0.44	0.40	0.35	0.27	0.26	0.35	0.22	0.17	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page