

SOCORRO 20 N, NM, USA

WMO: 746340

Lat: 34.3557N

Lon: 106.8859W

Elev: 4847

StdP: 12.30

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 03048

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 14.2	(c) 18.0	(d) -7.6	(e) 4.4	(f) 50.3	(g) -2.5	(h) 5.8	(i) 52.2	(j) 17.4	(k) 51.6	(l) 15.1	(m) 49.0	(n) 1.5	(o) N/A	(p) 0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 26.0	(c) 98.1	(d) 59.0	(e) 96.0	(f) 59.1	(g) 93.8	(h) 59.1	(i) 65.7	(j) 80.6	(k) 64.8	(l) 80.7	(m) 64.0	(n) 80.6	(o) 6.4	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.3	100.9	68.9	60.9	95.6	69.1	59.3	90.2	69.7	33.3	80.1	32.5	80.4	31.9	79.8	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.6	(b) 13.3	(c) 11.5	(e) 6.5	(f) 101.8	(g) 7.2	(h) 1.8	(i) 1.3	(j) 103.1	(k) -2.9	(l) 104.1	(m) -6.9	(n) 105.1	(o) -12.2	(p) 106.4		
(a) 15.6	(b) 13.3	(c) 11.5	(e) 2.9	(f) 67.6	(g) 8.5	(h) 1.5	(i) -3.2	(j) 68.7	(k) -8.2	(l) 69.5	(m) -13.0	(n) 70.4	(o) -19.2	(p) 71.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	36.9	42.8	51.6	58.7	67.2	77.9	79.9	77.2	70.9	59.0	46.1	37.1	(6)
(7)		DBStd	16.55	6.91	7.70	7.19	6.91	6.97	4.62	4.04	3.83	5.19	6.81	7.30	7.66	(7)
(8)		HDD50	1286	409	220	69	14	2	0	0	0	0	11	158	403	(8)
(9)		HDD65	3824	872	622	418	206	57	0	0	12	206	566	865	(9)	
(10)		CDD50	4518	2	18	118	275	534	838	928	844	627	289	41	4	(10)
(11)		CDD65	1583	0	0	1	17	125	388	463	379	190	20	0	0	(11)
(12)		CDH74	20123	0	5	93	441	1976	5494	5507	4101	2118	384	4	0	(12)
(13)		CDH80	9747	0	0	6	71	773	3051	2961	1994	825	66	0	0	(13)
(14)	Wind	WSAvg	4.8	3.9	4.8	5.5	6.4	5.9	5.4	4.7	4.3	4.3	4.2	3.9	3.8	(14)
(15)	Precipitation	PrecAvg	10.0	0.4	0.3	0.6	0.4	0.6	0.6	1.9	1.7	1.3	0.9	0.4	0.6	(15)
(16)		PrecMax	13.3	3.5	1.6	2.3	2.4	2.7	2.6	4.0	3.4	3.5	2.4	1.4	2.6	(16)
(17)		PrecMin	4.4	0.0	0.0	0.0	0.0	0.0	0.1	0.3	0.7	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.4	0.7	0.4	0.6	0.7	0.7	0.6	0.9	0.9	0.9	0.7	0.4	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.2	73.9	80.4	85.5	94.3	101.3	100.5	97.9	93.4	85.6	74.3	65.6	(19)
(20)			MCWB	43.3	47.3	49.5	51.7	54.5	58.1	60.4	59.8	59.4	54.7	48.5	45.0	(20)
(21)		2%	DB	59.3	68.4	76.9	82.1	90.9	98.5	98.2	95.4	90.8	81.7	70.6	60.9	(21)
(22)			MCWB	41.8	45.2	47.8	50.2	53.8	57.8	60.6	60.9	59.0	54.2	47.7	42.9	(22)
(23)		5%	DB	55.8	64.2	73.1	79.1	87.7	96.2	96.0	93.1	88.2	78.5	66.5	56.6	(23)
(24)			MCWB	40.1	43.2	46.4	49.2	52.6	57.0	61.2	61.2	58.6	53.1	46.3	41.3	(24)
(25)		10%	DB	51.9	59.7	69.2	76.2	84.5	93.7	93.5	90.6	85.3	75.0	62.3	52.4	(25)
(26)			MCWB	38.1	41.5	44.8	48.2	51.7	56.7	61.0	61.4	58.1	51.9	44.8	39.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	48.9	51.0	54.3	58.5	64.1	67.3	66.6	64.9	62.9	52.2	47.2	(27)
(28)			MCDWB	61.3	70.4	75.4	76.6	82.5	85.0	79.3	81.4	77.2	73.2	62.9	59.2	(28)
(29)		2%	WB	43.2	46.5	49.1	52.3	56.0	62.4	66.1	65.5	63.7	59.4	50.0	44.9	(29)
(30)			MCDWB	56.8	66.7	73.5	75.3	80.5	86.1	80.1	81.5	76.8	71.7	62.1	57.8	(30)
(31)		5%	WB	41.1	44.7	47.6	50.8	54.3	61.1	65.1	64.7	62.7	56.7	48.1	42.8	(31)
(32)			MCDWB	53.3	63.4	71.0	74.5	79.5	85.7	80.7	80.9	76.5	71.2	62.3	54.5	(32)
(33)		10%	WB	39.2	42.8	46.1	49.6	52.9	59.9	64.3	63.9	61.6	54.4	45.9	40.8	(33)
(34)			MCDWB	50.6	59.8	68.7	73.6	78.6	85.1	81.0	80.4	76.2	69.6	61.2	51.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	26.9	29.0	29.9	29.1	29.1	30.5	26.0	25.6	26.5	28.1	28.6	25.5	(35)
(36)			MCDBR	32.5	36.2	35.6	32.8	32.8	33.0	29.0	28.9	30.1	31.9	33.7	31.1	(36)
(37)			MCWBR	19.1	18.0	16.8	13.4	12.8	11.6	7.1	7.5	9.6	13.5	16.3	17.4	(37)
(38)		5% WB	MCDWB	28.9	34.0	33.5	30.4	30.2	28.7	24.0	24.2	22.3	25.0	27.2	26.9	(38)
(39)			MCWBR	16.5	17.0	15.6	12.3	11.6	9.3	6.0	6.2	7.2	10.8	14.3	15.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.241	0.248	0.270	0.291	0.308	0.329	0.370	0.346	0.312	0.278	0.254	0.244	(40)	
(41)		taud	2.638	2.619	2.540	2.462	2.464	2.399	2.395	2.427	2.517	2.585	2.599	2.624	(41)	
(42)		Ebn at Noon	317	324	321	316	309	301	288	294	302	307	308	309	(42)	
(43)		Edh at Noon	23	26	31	35	36	38	38	36	31	27	23	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1064	1377	1814	2213	2463	2515	2238	2063	1842	1507	1165	946	(44)	
(45)		RadStd	87	111	106	106	124	129	114	71	75	119	67	55	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+279	+157
(47) Regional (12 neighbors)		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+166	+94

Nomenclature: See separate page