

CHAPEL HILL, NC, USA

WMO: 746939

Lat: 35.933N

Lon: 79.064W

Elev: 156

StdP: 99.46

Time Zone: -5.00 (NAE)

Period: 01-18

WBAN: 93785

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-4.7	-17.9	0.8	-3.7	-15.3	1.0	-1.5	7.6	3.4	7.0	3.3	1.8	300	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	34.6	23.5	33.3	23.4	32.2	23.0	25.3	31.7	24.7	30.6	24.2	29.7	2.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.7	27.4	23.0	18.0	26.9	22.6	17.6	26.6	77.8	31.7	75.4	30.7	73.4	29.7	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	5.5	4.8	-10.1	36.8	2.2	1.8	-11.7	38.1	-13.0	39.2	-14.3	40.2	-15.9	41.5		
(5)			-11.4	26.1	2.1	0.6	-12.9	26.5	-14.1	26.9	-15.3	27.2	-16.8	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	4.8	6.5	10.8	15.9	19.8	24.4	26.2	25.7	22.2	16.2	10.8	7.1
	DBStd	8.61	5.65	5.27	5.50	4.59	3.86	2.74	2.20	2.44	3.10	4.33	4.60	5.09
	HDD10.0	540	180	124	59	7	0	0	0	0	0	6	44	120
	HDD18.3	1804	421	333	241	99	32	1	0	0	6	94	229	348
	CDD10.0	2695	18	26	83	184	303	432	503	486	366	197	68	31
	CDD18.3	918	0	1	6	27	77	182	244	227	122	27	3	1
	CDH23.3	8134	1	4	53	265	644	1688	2324	2057	889	190	16	2
	CDH26.7	3246	0	0	4	58	187	710	1049	897	304	35	1	0
Wind	WSAvg	1.7	1.9	2.0	2.1	2.0	1.7	1.5	1.3	1.3	1.7	1.6	1.7	1.7
Precipitation	PrecAvg	1186	101	93	111	84	104	105	108	116	99	90	86	83
	PrecMax	1556	227	172	202	187	194	258	214	230	610	257	319	182
	PrecMin	846	30	14	39	18	28	22	7	20	2	7	14	8
	PrecStd	181	49	40	47	41	42	57	51	48	100	59	60	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.4	23.7	27.2	30.9	31.8	35.2	36.9	36.6	33.8	29.6	25.2	22.9
		MCWB	15.9	17.0	16.8	19.4	21.7	23.3	24.1	23.6	21.2	20.3	17.9	16.7
	2%	DB	18.7	20.9	24.8	28.3	30.3	33.7	34.6	34.4	31.8	27.4	22.9	20.6
		MCWB	14.4	14.1	15.9	18.2	20.9	23.0	24.2	23.5	21.9	19.8	16.4	16.9
	5%	DB	16.7	18.3	22.6	26.5	28.9	32.3	33.1	32.8	30.1	25.5	21.0	18.1
		MCWB	12.7	13.1	14.7	17.3	20.7	22.8	24.0	23.3	21.2	18.9	16.4	15.0
	10%	DB	14.0	15.8	20.0	24.4	27.2	30.9	32.0	31.4	28.1	23.5	18.9	16.0
		MCWB	10.2	10.6	13.5	16.6	19.8	22.3	23.7	23.0	20.8	18.4	14.8	12.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.7	18.3	18.5	22.0	23.6	25.2	26.0	26.0	24.6	23.9	20.6	19.2
		MCDB	19.7	22.3	23.9	26.8	29.3	31.8	33.3	31.8	29.4	26.7	21.6	21.3
	2%	WB	15.6	16.3	17.5	20.2	22.2	24.4	25.4	25.2	23.8	22.2	18.7	17.5
		MCDB	18.0	19.3	22.0	25.4	27.9	30.7	32.3	31.0	28.1	24.7	21.2	19.4
	5%	WB	13.7	14.1	16.4	18.9	21.4	23.9	24.9	24.6	22.9	20.7	17.3	15.7
		MCDB	16.0	17.4	21.1	24.0	26.8	29.9	31.3	30.0	26.8	23.7	19.8	18.2
	10%	WB	10.7	11.1	15.1	17.8	20.7	23.3	24.3	24.0	22.2	19.2	15.5	12.9
		MCDB	13.4	14.4	19.1	22.5	25.4	28.8	30.1	29.0	25.6	22.6	18.5	15.1
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.9	11.9	12.4	11.3	11.1	10.5	10.3	10.3	11.4	12.0	10.3
		MCDBR	12.9	13.4	13.8	14.4	12.8	12.7	12.1	12.4	12.8	12.9	13.3	12.1
		MCWBR	9.1	8.7	7.2	6.4	5.4	4.5	4.0	3.8	4.6	6.3	8.1	8.5
	5% WB	MCDBR	11.4	12.2	12.0	12.0	10.9	11.0	10.7	10.2	9.3	9.5	10.5	10.5
		MCWBR	9.4	9.4	7.7	6.4	5.1	4.5	4.0	3.8	4.3	5.6	7.8	8.4
Clear-Sky Solar Irradiance	taub	0.312	0.330	0.363	0.404	0.451	0.497	0.539	0.528	0.422	0.380	0.330	0.315	
	taud	2.501	2.444	2.390	2.274	2.175	2.089	1.989	2.005	2.299	2.392	2.494	2.526	
	Ebn at Noon	889	910	905	880	839	798	761	760	833	840	859	862	
	Edh at Noon	82	97	112	133	149	162	178	172	122	102	82	76	
All-Sky Solar Radiation	RadAvg	2.56	3.23	4.27	5.37	5.95	6.38	6.00	5.44	4.53	3.68	2.81	2.21	
	RadStd	0.17	0.39	0.30	0.40	0.47	0.45	0.37	0.28	0.40	0.47	0.22	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (60 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+146	+99

Nomenclature: See separate page