

CAMPO, CA, USA

WMO: 747186

Lat: 32.626N

Lon: 116.468W

Elev: 805

StdP: 92.02

Time Zone: -8.00 (NAP)

Period: 01-19

WBAN: 03164

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.5	-1.3	-19.2	0.8	11.3	-16.9	0.9	11.2	13.9	11.1	12.3	12.3	2.0	50	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.5	36.8	18.0	35.2	17.8	33.8	17.6	21.0	31.3	20.3	30.9	19.6	30.4	5.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	14.2	24.4	16.7	13.2	24.9	15.4	12.1	24.7	64.3	31.4	61.7	31.0	59.1	30.3	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.8	8.6	DB	-5.5	39.6	2.0	1.0	-6.9	40.3	-8.1	40.9	-9.2	41.4	-10.6	42.2	(4)
(5)			WB	-7.0	22.5	1.3	0.9	-7.9	23.1	-8.7	23.6	-9.4	24.1	-10.3	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.0	9.6	9.0	10.8	12.2	15.0	19.1	23.1	23.3	21.0	16.0	12.3	8.8	(6)	
	DBStd	6.24	3.71	3.57	3.32	3.29	3.51	3.41	2.98	2.88	3.57	3.56	3.66	3.59	(7)	
	HDD10.0	248	54	57	32	14	3	0	0	0	0	2	19	67	(8)	
	HDD18.3	1688	272	262	234	184	116	30	3	2	18	88	183	295	(9)	
	CDD10.0	2089	41	28	56	81	156	272	407	412	329	189	87	31	(10)	
	CDD18.3	487	0	0	0	2	11	52	152	156	97	17	1	0	(11)	
	CDH23.3	9494	14	23	83	177	496	1452	2388	2476	1681	574	123	9	(12)	
(13)	CDH26.7	4723	2	2	12	43	185	721	1302	1390	864	187	16	0	(13)	
(14)	Wind	WSAvg	3.7	4.1	3.9	3.9	3.8	3.6	3.4	3.3	3.3	3.5	3.8	3.8	(14)	
(15) Precipitation	PrecAvg	378	64	61	65	28	7	2	8	14	12	16	45	56	(15)	
	PrecMax	786	300	224	252	153	29	14	48	103	72	80	229	313	(16)	
	PrecMin	129	0	0	0	0	0	0	0	0	0	0	0	1	(17)	
	PrecStd	163	70	54	53	33	8	3	14	24	18	20	47	61	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	26.0	28.1	30.5	33.4	37.9	38.6	38.3	36.3	32.5	28.4	24.7	(19)	
		MCWB	11.5	11.9	13.1	13.4	15.4	17.3	18.7	18.7	16.9	13.8	12.2	10.5	(20)	
	2%	DB	22.4	23.6	25.9	27.7	31.1	35.3	36.4	36.7	34.8	30.8	26.6	22.1	(21)	
		MCWB	9.5	10.3	12.2	12.5	14.9	16.9	18.7	18.3	17.4	14.1	11.6	9.5	(22)	
	5%	DB	20.4	21.0	23.2	25.2	28.7	32.9	34.5	35.2	33.3	28.9	24.6	19.8	(23)	
		MCWB	8.7	9.3	11.3	12.3	14.6	16.3	18.5	18.1	17.2	13.6	11.1	8.7	(24)	
	10%	DB	18.0	18.1	21.1	22.8	26.1	31.1	32.9	33.5	32.1	26.9	22.4	17.3	(25)	
		MCWB	7.9	8.5	10.7	11.5	13.9	15.6	18.1	17.8	16.7	13.0	10.1	7.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.4	13.9	14.9	15.8	18.0	20.1	21.9	21.9	21.3	18.4	14.3	13.1	(27)	
		MCDB	19.3	20.6	24.2	24.7	28.8	31.6	31.4	31.8	30.3	24.9	20.9	18.3	(28)	
	2%	WB	11.4	11.8	13.4	14.4	16.8	18.8	21.0	20.9	20.3	16.7	13.1	11.7	(29)	
		MCDB	17.6	19.1	22.5	23.5	27.2	31.5	31.6	31.5	29.6	24.8	21.6	17.2	(30)	
	5%	WB	10.3	10.6	12.3	13.3	15.7	17.8	20.2	20.2	19.5	15.3	12.2	10.6	(31)	
		MCDB	16.3	18.2	20.9	22.4	25.7	29.8	31.2	31.1	28.7	24.1	21.4	15.6	(32)	
	10%	WB	9.3	9.6	11.3	12.3	14.7	16.8	19.5	19.4	18.2	14.2	11.3	9.4	(33)	
		MCDB	15.1	15.9	19.2	20.9	24.4	28.3	30.6	30.5	27.8	23.9	20.1	14.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	13.8	15.8	16.7	17.2	20.6	19.3	19.5	19.2	17.4	15.7	13.4	(35)	
		MCDBR	17.9	19.9	21.3	22.4	23.0	23.6	20.7	21.1	20.7	21.4	19.9	18.5	(36)	
	5% WB	MCWBR	9.2	10.5	11.1	11.0	10.8	10.5	8.5	8.6	8.7	10.0	9.8	9.7	(37)	
		MCWBR	14.6	17.2	19.2	19.6	20.6	21.5	17.3	17.2	16.4	18.2	17.7	13.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.282	0.288	0.299	0.308	0.326	0.332	0.361	0.363	0.326	0.324	0.286	0.287	(40)	
		taud	2.559	2.557	2.513	2.494	2.463	2.448	2.451	2.428	2.508	2.481	2.578	2.574	(41)	
	Ebn at Noon		951	976	984	980	958	946	917	914	941	920	938	925	(42)	
		Edh at Noon	81	89	101	108	112	114	113	114	100	95	79	76	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.44	4.27	5.73	6.98	7.71	8.31	7.60	7.14	6.25	4.92	3.77	3.11	(44)	
	RadStd		0.23	0.38	0.29	0.27	0.42	0.32	0.38	0.29	0.24	0.30	0.17	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.58	N/A	-1.55	+0.63	N/A	N/A	N/A	-90	+212	+116

Nomenclature: See separate page