

BLYTHE, CA, USA

WMO: 747188

Lat: 33.619N

Lon: 114.714W

Elev: 395

StdP: 14.49

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23158

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	36.9	39.7	-1.3	5.2	55.6	2.9	6.5	57.6	28.1	60.4	25.4	60.8	3.9	350	0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.3	113.0	71.5	110.8	71.0	108.7	70.5	77.9	98.2	76.9	97.5	75.9	96.9	10.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.1	124.7	85.2	71.4	117.7	86.6	69.2	108.9	89.5	41.5	97.6	40.4	96.9	39.4	96.7	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.3	20.5	18.2	DB	30.2	117.6	2.8	2.7	28.2	119.6	26.6	121.2	25.0	122.7	22.9	124.7	(4)
(5)			WB	23.9	80.1	2.9	1.6	21.8	81.2	20.1	82.2	18.4	83.0	16.3	84.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	56.2	59.3	66.2	72.2	80.5	89.5	95.3	94.8	88.1	75.5	63.5	54.4	(6)	
	DBStd	15.43	5.19	5.71	6.38	6.56	6.83	5.87	4.14	4.10	5.66	6.54	6.23	5.11	(7)	
	HDD50	31	11	3	0	0	0	0	0	0	0	0	1	16	(8)	
	HDD65	961	276	171	64	15	1	0	0	0	0	6	100	328	(9)	
	CDD50	9048	202	264	503	665	945	1184	1404	1388	1143	790	406	154	(10)	
	CDD65	4502	2	12	102	230	480	734	939	923	693	332	54	1	(11)	
	CDH74	72798	46	248	1445	3239	7313	12566	16492	15961	10713	4076	677	22	(12)	
(13)	CDH80	48531	2	36	550	1603	4473	8804	12105	11595	7051	2116	195	1	(13)	
(14)	Wind	WSAvg	7.7	6.4	7.0	7.5	9.0	8.9	9.2	9.5	8.5	7.1	6.7	6.1	6.4	(14)
(15) Precipitation	PrecAvg	3.5	0.5	0.5	0.4	0.1	0.0	0.0	0.2	0.6	0.4	0.2	0.2	0.3	(15)	
	PrecMax	9.2	2.3	3.0	2.2	1.0	0.1	0.1	1.2	2.1	2.1	1.9	0.9	2.2	(16)	
	PrecMin	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	1.9	0.6	0.7	0.6	0.2	0.0	0.0	0.3	0.6	0.6	0.4	0.2	0.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.3	84.1	94.1	100.7	109.1	115.7	116.6	114.5	110.3	102.1	89.5	76.9	(19)	
		MCWB	54.1	56.8	59.8	62.7	67.9	69.2	73.2	72.4	70.3	66.7	58.8	55.6	(20)	
	2%	DB	74.9	80.7	89.7	96.9	104.7	111.5	113.3	112.3	107.6	97.8	85.5	72.6	(21)	
		MCWB	52.8	55.8	58.5	61.3	65.7	68.5	71.8	72.3	70.4	65.2	58.2	53.2	(22)	
	5%	DB	71.9	77.1	86.2	93.1	101.3	108.8	110.8	109.9	105.3	94.7	81.6	69.6	(23)	
		MCWB	51.9	54.3	57.4	60.0	63.8	67.6	71.8	72.1	70.0	63.5	57.2	51.8	(24)	
	10%	DB	68.6	73.1	82.5	89.3	98.0	106.4	108.5	107.8	102.5	91.2	77.6	66.3	(25)	
		MCWB	50.7	53.0	56.0	58.3	62.8	67.1	71.2	71.9	69.7	62.3	55.5	49.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.6	61.4	62.2	65.0	70.5	75.3	78.9	79.5	78.7	73.2	63.8	59.5	(27)	
		MCDB	70.0	75.7	85.5	96.1	104.6	104.4	100.6	100.1	95.6	88.8	78.4	69.9	(28)	
	2%	WB	57.1	58.9	60.3	62.6	67.6	73.2	77.4	78.1	77.0	69.4	60.5	57.0	(29)	
		MCDB	66.6	72.2	82.9	91.8	100.1	102.8	99.1	98.7	94.1	88.5	78.1	66.6	(30)	
	5%	WB	55.0	56.8	58.9	61.0	65.5	71.2	76.4	77.2	75.6	67.2	58.7	54.7	(31)	
		MCDB	65.7	70.2	81.6	89.5	96.9	100.8	98.4	97.9	93.1	87.3	77.8	64.7	(32)	
	10%	WB	52.7	54.9	57.3	59.4	63.8	69.1	75.3	76.2	74.3	64.6	56.9	52.3	(33)	
		MCDB	64.3	69.2	79.1	86.5	94.6	101.3	97.9	97.4	92.7	86.1	75.7	62.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.1	24.8	27.2	28.1	28.8	30.2	25.3	24.6	26.1	27.3	26.2	23.3	(35)	
		MCDBR	28.2	30.1	32.5	33.5	32.5	32.4	28.0	27.1	28.6	30.8	30.8	26.9	(36)	
		MCWBR	14.9	14.6	13.7	14.1	12.8	11.9	9.7	9.6	11.1	13.4	15.3	14.8	(37)	
	5% WB	MCDBR	22.1	24.8	29.5	31.1	30.1	28.0	21.8	21.8	22.0	25.0	27.0	22.4	(38)	
		MCWBR	12.3	12.4	12.5	13.1	12.2	11.4	8.1	8.4	9.6	11.6	14.4	12.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.279	0.282	0.298	0.322	0.335	0.338	0.383	0.377	0.341	0.307	0.285	0.280	(40)	
	taud		2.572	2.586	2.511	2.431	2.415	2.417	2.399	2.406	2.477	2.536	2.576	2.585	(41)	
	Ebn at Noon		301	311	312	306	301	298	284	285	293	297	296	295	(42)	
	Edh at Noon		25	27	32	36	37	37	38	37	33	28	24	23	(43)	
(44) All-Sky Solar Radiation	RadAvg		1086	1404	1871	2298	2574	2684	2410	2238	1975	1574	1192	980	(44)	
	RadStd		57	97	66	63	64	88	93	88	66	64	51	56	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (13 neighbors)	+0.68	N/A	-3.24	N/A	-0.72	N/A	N/A	N/A	+277	+173	(47)

Nomenclature: See separate page