

BLYTHE, CA, USA

WMO: 747188

Lat: 33.619N

Lon: 114.714W

Elev: 120

StdP: 99.89

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23158

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	2.7	4.3	-18.5	0.7	13.1	-16.2	0.9	14.2	12.6	15.8	11.3	16.0	1.7	350	0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	45.0	21.9	43.8	21.7	42.6	21.4	25.5	36.8	24.9	36.4	24.4	36.1	4.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	17.8	29.6	21.9	16.8	30.3	20.7	15.6	31.9	78.7	36.4	76.1	36.1	73.8	35.9	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.9	9.2	8.2	-1.0	47.6	1.6	1.5	-2.1	48.7	-3.0	49.6	-3.9	50.4	-5.0	51.5
			-4.5	26.7	1.6	0.9	-5.7	27.4	-6.6	27.9	-7.5	28.4	-8.7	29.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	13.4	15.2	19.0	22.3	26.9	31.9	35.2	34.9	31.2	24.2	17.5	12.5		
	DBStd	8.57	2.88	3.17	3.55	3.65	3.79	3.26	2.30	2.28	3.14	3.63	3.46	2.84		
	HDD10.0	17	6	2	0	0	0	0	0	0	0	0	1	9		
	HDD18.3	534	153	95	36	8	1	0	0	0	0	3	56	182		
	CDD10.0	5027	112	147	279	369	525	658	780	771	635	439	226	86		
	CDD18.3	2501	1	7	57	128	267	408	522	513	385	184	30	1		
	CDH23.3	40443	26	138	803	1799	4063	6981	9162	8867	5952	2264	376	12		
(13)	CDH26.7	26962	1	20	306	891	2485	4891	6725	6442	3917	1176	108	1		
(14)	Wind	WSAvg	3.4	2.9	3.1	3.4	4.0	4.1	4.3	3.8	3.2	3.0	2.7	2.8		
(15) Precipitation	PrecAvg	88	12	13	11	2	0	0	5	14	11	4	4	8		
	PrecMax	233	59	77	55	25	3	2	30	53	54	48	22	56		
	PrecMin	29	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	47	15	19	14	6	1	0	8	16	15	11	6	13		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.7	28.9	34.5	38.2	42.9	46.5	47.0	45.9	43.5	38.9	32.0	24.9		
		MCWB	12.3	13.8	15.4	17.1	20.0	20.7	22.9	22.5	21.3	19.3	14.9	13.1		
	2%	DB	23.8	27.0	32.0	36.1	40.4	44.1	45.2	44.6	42.0	36.6	29.7	22.5		
		MCWB	11.6	13.2	14.7	16.3	18.7	20.3	22.1	22.4	21.3	18.5	14.6	11.8		
	5%	DB	22.2	25.1	30.1	33.9	38.5	42.7	43.8	43.3	40.7	34.8	27.5	20.9		
		MCWB	11.1	12.4	14.1	15.6	17.7	19.8	22.1	22.3	21.1	17.5	14.0	11.0		
	10%	DB	20.3	22.9	28.0	31.8	36.7	41.3	42.5	42.1	39.1	32.9	25.3	19.1		
		MCWB	10.4	11.6	13.4	14.6	17.1	19.5	21.8	22.1	20.9	16.8	13.1	9.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.3	16.3	16.8	18.4	21.4	24.0	26.0	26.4	26.0	22.9	17.7	15.3		
		MCDB	21.1	24.3	29.7	35.6	40.3	40.2	38.1	37.8	35.4	31.6	25.8	21.1		
	2%	WB	14.0	15.0	15.7	17.0	19.8	22.9	25.2	25.6	25.0	20.8	15.8	13.9		
		MCDB	19.2	22.3	28.3	33.2	37.8	39.3	37.3	37.1	34.5	31.4	25.6	19.2		
	5%	WB	12.8	13.8	15.0	16.1	18.6	21.8	24.7	25.1	24.2	19.5	14.9	12.6		
		MCDB	18.7	21.2	27.5	31.9	36.1	38.2	36.9	36.6	33.9	30.7	25.4	18.2		
	10%	WB	11.5	12.7	14.0	15.2	17.7	20.6	24.1	24.5	23.5	18.1	13.8	11.3		
		MCDB	18.0	20.7	26.1	30.3	34.8	38.5	36.6	36.3	33.7	30.0	24.3	17.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	13.8	15.1	15.6	16.0	16.8	14.0	13.7	14.5	15.2	14.5	12.9		
		MCDBR	15.7	16.7	18.1	18.6	18.1	18.0	15.5	15.1	15.9	17.1	17.1	15.0		
		MCWBR	8.3	8.1	7.6	7.8	7.1	6.6	5.4	5.3	6.1	7.4	8.5	8.2		
	5% WB	MCDBR	12.3	13.8	16.4	17.3	16.7	15.6	12.1	12.1	12.2	13.9	15.0	12.5		
		MCWBR	6.9	6.9	6.9	7.3	6.8	6.3	4.5	4.6	5.3	6.4	8.0	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.279	0.282	0.298	0.322	0.335	0.338	0.383	0.377	0.341	0.307	0.285	0.280		
	taud		2.572	2.586	2.511	2.431	2.415	2.417	2.399	2.406	2.477	2.536	2.576	2.585		
	Ebn at Noon		949	980	983	965	948	941	896	899	923	936	934	929		
	Edh at Noon		78	86	100	114	117	117	119	116	103	89	77	73		
(44) All-Sky Solar Radiation	RadAvg		3.42	4.43	5.90	7.25	8.11	8.46	7.60	7.06	6.23	4.96	3.76	3.09		
	RadStd		0.18	0.31	0.21	0.20	0.20	0.28	0.29	0.28	0.21	0.20	0.16	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.38	N/A	-1.80	N/A	-0.40	N/A	N/A	N/A	+154	+96

Nomenclature: See separate page