

MULESHOE 19 S, TX, USA

WMO: 747270

Lat: 33.9557N

Lon: 102.7740W

Elev: 3742

StdP: 12.81

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03054

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.8	16.2	-0.8	6.0	33.4	3.1	7.4	37.2	23.5	56.7	21.5	55.3	3.9	N/A	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.1	98.9	63.1	96.1	64.0	93.8	64.4	70.6	85.4	69.4	84.6	68.5	83.7	10.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	114.1	74.1	65.7	109.2	73.5	64.5	104.5	72.8	37.0	85.4	35.9	84.4	35.1	82.8	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	18.4	16.1	DB	2.8	103.7	5.4	1.8	-1.1	105.0	-4.3	106.1	-7.3	107.1	-11.2	108.4	(4)
(5)			WB	1.8	72.2	6.3	1.1	-2.7	73.0	-6.4	73.6	-10.0	74.2	-14.6	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.4	38.8	42.6	50.9	57.7	66.1	76.4	77.1	76.2	69.4	58.5	47.3	39.1
	DBStd	16.00	9.22	9.99	8.93	8.17	7.90	4.79	4.05	4.47	5.56	8.15	8.84	9.24
	HDD50	1249	358	239	97	26	4	0	0	0	0	24	151	350
	HDD65	3786	811	627	439	241	82	1	0	0	24	226	533	802
	CDD50	4332	13	32	126	256	504	792	841	814	583	288	69	14
	CDD65	1388	0	0	2	20	117	343	376	349	157	24	0	0
	CDH74	19078	4	48	274	798	2123	4650	4615	3994	1882	591	95	4
	CDH80	9442	0	6	55	256	1000	2611	2473	2089	777	166	9	0
Wind	WSAvg	7.0	7.0	7.7	8.0	8.7	8.1	7.6	6.0	5.5	5.5	6.1	6.5	6.9
Precipitation	PrecAvg	18.0	0.6	0.5	1.1	1.0	2.0	2.2	2.3	2.6	2.3	1.5	0.8	0.7
	PrecMax	40.5	1.7	2.3	3.9	3.7	6.1	6.3	6.2	6.3	10.3	3.7	3.9	3.3
	PrecMin	8.1	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.5	0.0	0.0	0.0	0.0
	PrecStd	6.4	0.6	0.6	1.1	1.0	1.7	1.8	1.5	1.5	2.2	1.2	0.9	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.7	80.0	85.4	90.3	97.4	102.8	101.4	100.3	94.7	88.7	81.4	73.3
		MCWB	48.3	51.0	53.1	54.9	58.0	60.9	64.8	64.7	64.1	58.8	52.9	48.0
	2%	DB	68.8	74.2	80.9	86.3	93.7	99.6	97.3	96.7	91.3	84.7	77.1	68.1
		MCWB	46.2	48.6	51.6	53.3	56.6	61.7	65.0	65.6	63.2	58.4	51.5	47.4
	5%	DB	63.9	69.6	76.8	82.8	90.3	96.6	94.5	94.2	88.3	81.0	72.1	63.4
		MCWB	43.9	47.2	50.6	53.1	56.5	62.8	66.0	66.1	63.3	57.7	49.8	45.3
	10%	DB	58.6	64.1	71.9	78.8	86.1	93.4	91.9	91.1	84.6	76.6	66.8	57.7
		MCWB	42.0	45.0	48.7	53.0	56.8	64.1	66.4	66.3	63.8	56.5	48.0	42.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	53.5	59.1	61.4	67.7	70.9	72.9	71.5	70.1	68.0	57.4	52.3
		MCDB	68.7	70.9	72.6	74.1	78.0	89.4	84.1	86.2	82.5	76.0	67.3	61.5
	2%	WB	47.5	50.8	55.5	59.1	65.2	69.2	71.0	70.3	68.5	65.5	54.8	49.3
		MCDB	66.0	72.0	68.1	70.1	77.9	85.8	85.0	85.5	81.0	72.1	64.6	62.1
	5%	WB	44.8	48.3	52.9	56.9	63.4	68.2	69.4	69.2	67.5	62.7	52.2	46.8
		MCDB	62.3	69.2	71.1	72.3	76.6	85.0	84.6	84.8	80.1	72.2	66.7	61.5
	10%	WB	42.4	45.8	50.8	54.7	61.6	67.2	68.4	68.2	66.3	59.9	49.9	44.0
		MCDB	57.5	64.3	70.1	73.6	75.9	83.9	83.8	84.0	78.0	70.6	65.4	57.3
Mean Daily Temperature Range	5% DB	MDBR	31.4	32.2	32.8	33.0	30.7	30.6	27.1	26.9	26.7	29.7	32.3	29.4
		MCDBR	39.9	41.8	40.3	40.3	38.0	36.2	31.5	31.6	33.1	36.5	40.5	38.4
		MCWBR	21.1	21.3	18.5	16.7	15.2	10.6	8.7	9.1	11.3	15.0	19.4	20.9
	5% WB	MCDBR	36.3	40.6	36.4	33.3	30.0	28.6	26.0	26.5	24.2	25.1	33.4	33.4
	MCWBR	19.7	20.8	18.3	15.6	14.1	9.9	8.6	8.5	9.1	12.2	18.1	19.5	
Clear-Sky Solar Irradiance	taub	0.254	0.263	0.293	0.321	0.333	0.374	0.380	0.368	0.339	0.308	0.284	0.263	
	taud	2.590	2.574	2.491	2.406	2.436	2.367	2.396	2.401	2.455	2.515	2.512	2.551	
	Ebn at Noon	312	318	313	306	301	288	285	288	293	296	295	300	
	Edh at Noon	24	27	32	37	36	39	38	37	33	29	26	24	
All-Sky Solar Radiation	RadAvg	1072	1341	1737	2144	2336	2453	2330	2125	1789	1418	1120	928	
	RadStd	92	108	123	135	154	128	105	95	116	143	104	64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+171	N/A

Nomenclature: See separate page