

FT WORTH MEACHAM, TX, USA

WMO: 747390

Lat: 32.819N

Lon: 97.361W

Elev: 687

StdP: 14.33

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13961

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	26.8	8.3	8.6	30.8	12.2	10.5	35.0	26.3	49.0	24.1	52.8	9.4	0	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.0	101.6	74.0	99.4	74.6	97.3	74.6	78.7	92.0	77.8	91.3	77.0	90.2	10.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.3	135.9	83.8	74.3	131.4	82.9	73.3	127.1	82.1	42.7	91.9	41.6	91.5	40.7	90.1	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.8	20.7	18.9	16.0	105.1	3.3	3.2	13.6	107.4	11.7	109.3	9.8	111.1	7.4	113.5		
			14.1	80.6	3.2	2.3	11.8	82.3	10.0	83.6	8.2	84.9	5.8	86.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	46.8	50.6	58.0	65.7	74.1	82.1	85.7	86.0	78.6	67.8	57.1	48.2
	DBStd	16.10	10.33	10.93	9.70	7.59	6.74	4.60	4.18	4.65	6.72	8.51	9.27	9.68
	HDD50	533	184	115	40	3	0	0	0	0	0	3	38	150
	HDD65	2193	567	412	255	82	13	0	0	0	4	71	264	525
	CDD50	6664	85	133	286	473	748	962	1106	1114	857	555	250	95
	CDD65	2851	3	10	36	102	296	512	641	649	411	158	27	6
	CDH74	33824	30	90	271	800	2827	6139	8699	8808	4553	1397	176	34
	CDH80	17213	2	18	49	193	1092	3106	4971	5079	2199	471	29	4
Wind	WSAvg	9.5	9.5	10.1	11.0	11.3	10.6	10.1	8.9	8.1	7.8	8.8	9.1	9.1
Precipitation	PrecAvg	35.3	2.1	2.1	2.9	3.7	4.4	3.3	2.2	2.3	2.9	4.0	2.9	2.4
	PrecMax	56.8	5.7	7.0	6.2	7.8	13.5	12.4	5.0	7.2	10.5	10.8	9.5	9.9
	PrecMin	14.5	0.2	0.0	0.0	0.6	0.5	0.4	0.0	0.6	0.6	0.5	0.1	0.4
	PrecStd	9.6	1.3	1.8	1.7	1.8	2.7	2.8	1.5	1.8	2.2	2.8	2.4	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.0	82.2	84.9	89.6	96.7	100.5	104.2	105.2	101.0	93.0	83.8	78.3
		MCWB	57.7	60.5	64.0	69.0	73.6	75.6	73.9	72.4	73.7	71.5	66.7	62.8
	2%	DB	72.4	76.2	80.5	84.8	92.5	97.9	101.2	102.0	97.2	89.0	78.8	72.7
		MCWB	58.1	60.9	64.7	68.4	73.3	75.4	74.5	73.5	73.6	70.2	64.8	60.6
	5%	DB	68.0	72.1	76.8	81.7	89.3	95.3	99.2	99.7	93.9	85.1	75.1	68.6
		MCWB	57.1	59.5	62.7	67.3	72.4	74.8	74.9	74.2	72.7	68.4	64.1	58.6
	10%	DB	63.7	68.0	73.0	78.7	86.2	92.8	96.8	97.3	90.9	81.8	71.8	64.0
		MCWB	54.9	58.6	61.4	65.7	72.1	74.6	75.0	74.4	72.3	67.4	62.2	55.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.9	67.7	70.1	74.1	78.4	81.2	79.9	79.4	78.2	76.2	71.4	67.3
		MCDB	70.7	74.7	79.4	83.7	89.4	93.0	94.9	93.5	91.3	84.6	77.7	73.3
	2%	WB	62.9	65.5	67.6	71.8	76.5	78.9	78.4	77.8	76.7	73.9	68.3	64.5
		MCDB	67.6	70.8	75.2	80.4	86.6	91.1	93.0	92.0	89.2	82.5	74.4	70.5
	5%	WB	59.8	62.9	65.9	70.2	75.0	77.5	77.5	77.0	75.4	72.3	66.2	60.7
		MCDB	65.7	68.9	73.4	77.7	84.4	89.7	92.2	91.0	87.1	80.6	72.5	65.5
	10%	WB	55.2	59.6	63.9	68.7	73.5	76.4	76.8	76.1	74.5	70.6	63.9	57.1
		MCDB	62.2	66.7	70.9	75.6	83.0	88.0	90.7	89.9	85.7	78.6	70.1	62.9
Mean Daily Temperature Range	5% DB	MDBR	20.4	20.3	20.4	20.5	19.2	19.2	19.9	20.0	19.9	20.6	19.7	19.3
		MCDBR	26.7	25.6	24.1	23.2	21.9	21.7	22.3	22.6	22.5	23.5	22.8	24.5
		MCWBR	16.1	15.2	13.2	11.9	8.3	6.3	5.7	5.7	6.7	10.2	12.6	14.9
	5% WB	MCDBR	21.7	21.4	19.5	18.8	18.9	18.9	19.7	19.6	18.8	18.8	19.1	20.2
		MCWBR	16.1	16.0	12.7	11.8	9.2	7.2	6.2	5.9	6.6	9.7	13.6	15.8
Clear-Sky Solar Irradiance	taub	0.311	0.324	0.355	0.392	0.423	0.434	0.437	0.435	0.399	0.358	0.335	0.317	
	taud	2.501	2.474	2.405	2.328	2.301	2.304	2.335	2.323	2.371	2.471	2.474	2.487	
	Ebn at Noon	289	296	293	285	275	271	269	269	275	279	277	279	
	Edh at Noon	27	31	36	40	42	42	40	40	36	31	28	26	
All-Sky Solar Radiation	RadAvg	928	1095	1436	1738	1872	2104	2142	1962	1644	1290	981	815	
	RadStd	93	173	109	142	184	199	146	124	140	192	126	104	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page