

GAINESVILLE, FL, USA

WMO: 747560

Lat: 29.692N

Lon: 82.276W

Elev: 123

StdP: 14.63

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12816

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.6	33.3	15.9	12.3	40.7	20.5	15.5	42.1	20.5	64.1	18.6	62.3	3.4	320	0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	94.0	76.0	92.4	75.8	90.9	75.6	79.4	88.1	78.5	87.0	78.0	86.4	7.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	142.5	82.8	76.4	138.2	82.1	75.5	134.3	81.4	42.9	87.8	42.1	87.4	41.3	86.5	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.2	16.2	13.9	DB	23.3	97.9	3.3	3.1	21.0	100.1	19.0	102.0	17.1	103.7	14.7	106.0
			WB	21.4	81.2	3.5	1.3	18.9	82.1	16.8	82.8	14.8	83.6	12.3	84.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.6	54.9	58.7	63.1	68.9	75.3	79.9	81.3	81.2	78.7	71.6	62.7	57.8
	DBStd	11.37	9.33	8.83	7.63	5.93	4.63	3.14	2.29	2.28	3.10	6.49	7.61	9.07
	HDD50	124	58	23	7	0	0	0	0	0	0	5	31	
	HDD65	1108	331	210	127	32	2	0	0	0	23	128	255	
	CDD50	7264	210	266	412	566	784	898	969	967	861	670	387	274
	CDD65	2771	17	33	67	147	321	448	504	502	411	228	60	33
	CDH74	24573	126	242	615	1431	3190	4087	4694	4557	3347	1676	422	186
	CDH80	9524	12	31	105	403	1336	1819	2042	1918	1317	473	58	10
Wind	WSAvg	5.8	6.2	6.6	6.9	6.7	6.2	5.4	4.7	4.8	5.3	5.6	5.6	5.7
Precipitation	PrecAvg	49.1	3.1	4.1	3.7	2.0	2.7	7.1	6.4	7.0	5.6	2.4	2.1	2.6
	PrecMax	70.7	8.9	11.6	9.8	7.4	7.2	14.8	12.2	15.8	12.0	8.0	4.5	9.6
	PrecMin	34.3	0.4	0.3	0.6	0.1	0.2	2.2	1.5	2.5	2.0	0.0	0.2	0.2
	PrecStd	8.9	2.1	2.6	2.7	1.8	2.1	3.2	2.6	3.6	3.2	2.1	1.1	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.3	83.8	85.8	89.9	95.1	97.0	95.4	94.8	93.1	89.4	84.9	81.3
		MCWB	67.6	68.2	68.0	70.4	72.5	75.4	77.4	77.7	75.6	74.8	72.7	69.7
	2%	DB	77.6	80.1	82.9	86.9	91.9	94.0	93.2	92.8	90.8	87.1	81.5	78.8
		MCWB	65.9	66.8	66.9	69.3	71.6	75.8	76.8	77.3	75.0	73.6	69.6	68.5
	5%	DB	74.0	77.1	80.5	84.5	89.6	91.6	91.4	91.2	89.2	84.9	79.0	76.0
		MCWB	64.4	65.4	65.8	68.0	71.2	75.6	76.8	77.1	74.9	72.3	67.9	67.4
	10%	DB	70.4	73.4	77.6	82.1	87.3	89.4	89.8	89.4	87.5	82.7	76.0	72.4
		MCWB	62.8	63.4	64.1	66.9	70.8	75.2	76.6	77.0	74.8	71.2	66.1	65.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.8	71.3	72.6	73.9	76.7	80.0	80.6	80.5	79.1	77.9	74.8	72.5
		MCDB	76.8	78.4	79.4	82.6	86.7	89.5	89.7	89.2	86.1	84.3	81.0	77.5
	2%	WB	68.5	69.3	70.3	72.4	75.4	78.4	79.3	79.4	78.1	76.4	72.6	70.7
		MCDB	74.0	76.1	77.2	81.1	84.9	87.7	88.0	88.2	85.5	82.6	78.0	75.5
	5%	WB	66.3	67.5	68.7	71.0	74.2	77.5	78.4	78.5	77.2	75.2	70.6	69.1
		MCDB	71.6	74.0	75.7	79.7	83.6	86.7	86.9	87.0	84.8	81.3	75.3	73.6
	10%	WB	64.3	65.7	66.9	69.6	73.1	76.7	77.7	77.9	76.4	73.9	68.7	67.1
		MCDB	69.3	71.7	73.9	78.2	82.2	85.4	86.2	86.2	83.5	79.4	73.9	71.6
Mean Daily Temperature Range	5% DB	MDBR	23.5	23.4	24.6	24.4	23.3	19.1	17.9	17.0	17.3	20.4	23.1	22.3
		MCDBR	24.6	24.5	25.9	25.5	25.3	22.2	20.2	19.3	19.8	20.3	23.2	22.2
		MCWBR	14.2	12.4	11.8	10.4	8.7	7.4	7.1	6.8	7.3	8.8	12.4	12.8
	5% WB	MCDBR	20.5	20.7	20.7	21.6	20.9	19.0	17.8	17.2	16.3	16.2	18.8	18.9
		MCWBR	13.1	12.0	11.5	10.5	8.2	7.4	7.2	6.9	6.8	7.6	11.6	12.3
Clear-Sky Solar Irradiance	taub	0.332	0.346	0.367	0.385	0.425	0.459	0.502	0.478	0.425	0.390	0.354	0.339	
	taud	2.523	2.487	2.433	2.367	2.299	2.274	2.152	2.233	2.372	2.437	2.482	2.526	
	Ebn at Noon	287	292	292	289	276	265	253	259	270	273	276	279	
	Edh at Noon	28	32	36	39	42	43	49	44	37	33	29	27	
All-Sky Solar Radiation	RadAvg	1035	1231	1596	1921	2040	1842	1779	1690	1527	1379	1129	937	
	RadStd	72	125	136	124	131	126	128	117	124	109	64	79	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.77	N/A	N/A	N/A	N/A	N/A	-34	N/A	N/A	+139
(47)	Regional (41 neighbors)	+0.77	+1.35	N/A	N/A	N/A	N/A	-14	-104	+288	+207

Nomenclature: See separate page