

GAINESVILLE, FL, USA

WMO: 747560

Lat: 29.692N

Lon: 82.276W

Elev: 38

StdP: 100.88

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12816

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.4	(c) 0.7	(d) -9.0	(e) 1.8	(f) 4.8	(g) -6.4	(h) 2.2	(i) 5.6	(j) 9.2	(k) 17.9	(l) 8.3	(m) 16.9	(n) 1.5	(o) 320	(p) 0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	34.4	24.5	33.6	24.4	32.7	24.2	26.3	31.2	25.8	30.6	25.5	30.2	3.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.4	28.2	24.7	19.7	27.8	24.2	19.2	27.5	81.9	31.0	80.0	30.8	78.2	30.3	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.2	6.2	-4.8	36.6	1.8	1.7	-6.1	37.9	-7.2	38.9	-8.3	39.8	-9.6	41.1		
			-5.9	27.3	2.0	0.7	-7.3	27.8	-8.4	28.2	-9.5	28.7	-11.0	29.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	12.7	14.8	17.3	20.5	24.1	26.6	27.4	27.3	26.0	22.0	17.1	14.4		
	DBStd	6.32	5.18	4.90	4.24	3.29	2.57	1.74	1.27	1.27	1.72	3.61	4.23	5.04		
	HDD10.0	69	32	13	4	0	0	0	0	0	0	0	3	17		
	HDD18.3	616	184	117	71	18	1	0	0	0	0	13	71	142		
	CDD10.0	4036	117	148	229	314	436	499	538	537	478	372	215	152		
	CDD18.3	1539	9	18	37	82	178	249	280	279	228	127	33	18		
	CDH23.3	13652	70	134	342	795	1772	2271	2608	2532	1859	931	234	103		
	CDH26.7	5291	7	17	58	224	742	1011	1134	1066	732	263	32	6		
(14) Wind	WSAvg	2.6	2.8	2.9	3.1	3.0	2.8	2.4	2.1	2.1	2.4	2.5	2.5	2.5		
(15) Precipitation	PrecAvg	1247	80	104	94	52	69	180	162	179	141	62	54	66		
	PrecMax	1797	226	294	249	188	183	375	309	402	306	203	115	244		
	PrecMin	872	10	8	16	2	6	56	39	63	50	0	6	5		
	PrecStd	225	54	67	69	45	54	81	67	92	81	53	29	60		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.4	28.8	29.9	32.1	35.0	36.1	35.2	34.9	33.9	31.9	29.4	27.4		
		MCWB	19.8	20.1	20.0	21.3	22.5	24.1	25.2	25.4	24.2	23.8	22.6	20.9		
	2%	DB	25.3	26.7	28.3	30.5	33.3	34.4	34.0	33.8	32.7	30.6	27.5	26.0		
		MCWB	18.8	19.3	19.4	20.7	22.0	24.4	24.9	25.2	23.9	23.1	20.9	20.3		
	5%	DB	23.3	25.1	26.9	29.2	32.0	33.1	33.0	32.9	31.8	29.4	26.1	24.4		
		MCWB	18.0	18.6	18.8	20.0	21.8	24.2	24.9	25.1	23.8	22.4	19.9	19.6		
	10%	DB	21.3	23.0	25.3	27.8	30.7	31.9	32.1	31.9	30.8	28.1	24.5	22.4		
		MCWB	17.1	17.5	17.8	19.4	21.6	24.0	24.8	25.0	23.8	21.8	18.9	18.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	21.8	22.5	23.3	24.9	26.7	27.0	26.9	26.2	25.5	23.8	22.5		
		MCDB	24.9	25.8	26.3	28.1	30.4	31.9	32.0	31.8	30.1	29.1	27.2	25.3		
	2%	WB	20.3	20.7	21.3	22.5	24.1	25.8	26.3	26.3	25.6	24.7	22.6	21.5		
		MCDB	23.3	24.5	25.1	27.3	29.4	30.9	31.1	31.2	29.7	28.1	25.6	24.2		
	5%	WB	19.0	19.7	20.4	21.7	23.5	25.3	25.8	25.8	25.1	24.0	21.4	20.6		
		MCDB	22.0	23.3	24.3	26.5	28.7	30.4	30.5	30.5	29.3	27.4	24.1	23.1		
	10%	WB	17.9	18.7	19.4	20.9	22.8	24.8	25.4	25.5	24.7	23.3	20.4	19.5		
		MCDB	20.7	22.1	23.3	25.7	27.9	29.7	30.1	30.1	28.6	26.3	23.3	22.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	13.0	13.7	13.6	12.9	10.6	10.0	9.5	9.6	11.3	12.8	12.4		
		MCDBR	13.7	13.6	14.4	14.2	14.1	12.3	11.2	10.7	11.0	11.3	12.9	12.3		
		MCWBR	7.9	6.9	6.6	5.8	4.8	4.1	3.9	3.8	4.1	4.9	6.9	7.1		
	5% WB	MCDBR	11.4	11.5	11.5	12.0	11.6	10.5	9.9	9.6	9.1	9.0	10.4	10.5		
		MCWBR	7.3	6.7	6.4	5.8	4.5	4.1	4.0	3.8	3.8	4.2	6.5	6.9		
(40) Clear-Sky Solar Irradiance	taub		0.332	0.346	0.367	0.385	0.425	0.459	0.502	0.478	0.425	0.390	0.354	0.339		
	taud		2.523	2.487	2.433	2.367	2.299	2.274	2.152	2.233	2.372	2.437	2.482	2.526		
	Ebn at Noon		905	921	920	910	869	835	798	815	850	861	871	879		
	Edh at Noon		88	100	112	124	133	136	153	140	118	104	91	85		
(44) All-Sky Solar Radiation	RadAvg		3.26	3.88	5.03	6.05	6.43	5.81	5.61	5.33	4.81	4.35	3.56	2.95		
	RadStd		0.23	0.39	0.43	0.39	0.41	0.40	0.41	0.37	0.39	0.34	0.20	0.25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.43	N/A	N/A	N/A	N/A	N/A	-19	N/A	N/A	+77
(47) Regional (41 neighbors)		+0.43	+0.75	N/A	N/A	N/A	N/A	-8	-58	+160	+115

Nomenclature: See separate page