

GREENWOOD-LEFLORE, MS, USA

WMO: 747580

Lat: 33.496N

Lon: 90.087W

Elev: 133

StdP: 14.63

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13978

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.2	25.1	9.2	8.9	28.1	13.9	11.2	30.9	23.3	59.0	20.5	58.4	5.2	0	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	96.1	77.3	94.0	77.0	92.2	76.6	80.5	90.4	79.7	89.8	78.7	88.4	5.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.1	146.5	85.2	76.9	141.0	84.5	75.9	136.2	83.8	44.1	90.8	43.1	89.6	42.2	88.7	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.7	17.4	15.3	DB	14.7	99.5	4.0	3.5	11.8	102.0	9.4	104.1	7.1	106.0	4.2	108.6
			WB	13.2	82.8	4.0	1.6	10.3	83.9	8.0	84.8	5.8	85.7	2.9	86.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.3	44.6	48.6	56.3	64.4	72.6	79.0	81.3	81.3	75.8	65.2	54.3	47.3	(6)
	DBStd	15.45	11.12	10.66	9.78	7.76	6.21	3.84	3.25	3.81	6.12	8.58	9.34	10.54	(7)
	HDD50	694	244	143	52	4	0	0	0	0	0	5	62	184	(8)
	HDD65	2526	637	466	297	104	16	0	0	0	6	107	337	556	(9)
	CDD50	5912	75	104	247	435	700	871	970	970	775	474	192	99	(10)
	CDD65	2273	4	8	26	86	251	421	505	505	331	112	17	7	(11)
	CDH74	22368	5	34	204	698	2176	4236	5297	5332	3223	1028	112	23	(12)
	CDH80	9796	0	1	22	135	761	1910	2526	2667	1439	321	13	1	(13)
(14) Wind	WSAvg	6.3	7.4	7.8	8.0	7.6	6.5	5.4	4.5	4.3	5.0	5.5	6.2	7.0	(14)
(15) Precipitation	PrecAvg	53.2	4.7	4.5	5.5	5.2	5.2	4.2	3.9	2.9	3.4	3.6	4.8	5.6	(15)
	PrecMax	80.0	11.3	8.0	16.9	14.7	14.2	18.7	11.1	7.7	7.6	12.7	10.3	16.4	(16)
	PrecMin	32.3	0.9	1.2	1.1	0.8	0.6	0.1	0.5	0.1	0.4	0.0	1.0	0.5	(17)
	PrecStd	11.7	2.8	2.0	3.0	3.0	3.1	3.5	2.6	2.0	2.0	2.7	2.6	3.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.0	78.5	82.5	86.5	91.5	96.0	97.2	99.9	97.2	90.5	81.7	77.3	(19)
		MCWB	64.6	66.3	66.3	70.5	74.0	76.4	78.8	77.3	74.3	72.2	68.6	67.6	(20)
	2%	DB	70.3	73.6	79.3	83.6	89.3	93.2	94.9	96.9	93.5	87.0	77.3	72.5	(21)
		MCWB	63.2	63.3	64.6	68.8	73.0	76.4	78.4	77.8	74.4	71.1	65.2	64.8	(22)
	5%	DB	66.6	70.2	75.8	81.2	87.1	91.3	93.0	94.3	91.1	83.7	73.4	68.6	(23)
		MCWB	60.5	61.5	62.7	66.9	72.5	76.1	78.2	77.3	74.3	68.6	63.7	62.7	(24)
	10%	DB	62.9	66.1	72.4	78.4	84.6	89.8	91.1	92.0	88.3	80.3	70.2	64.3	(25)
		MCWB	57.8	58.8	61.6	65.7	71.4	75.7	77.8	76.8	73.2	67.3	61.9	59.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.0	68.5	70.0	74.1	77.5	80.2	82.1	82.1	79.0	76.3	71.3	69.2	(27)
		MCDB	71.5	74.8	77.6	82.7	87.0	89.9	91.2	92.3	89.9	85.1	76.5	74.6	(28)
	2%	WB	64.3	66.1	67.5	71.7	75.8	79.0	80.8	80.5	77.4	74.4	68.7	66.5	(29)
		MCDB	69.0	71.7	75.0	79.5	85.0	89.2	90.3	90.9	87.4	82.3	74.2	71.4	(30)
	5%	WB	62.0	63.5	65.6	69.9	74.5	78.1	79.9	79.6	76.4	72.5	66.1	63.7	(31)
		MCDB	66.1	68.6	73.1	77.7	83.3	88.0	89.7	89.7	85.9	79.2	71.8	67.6	(32)
	10%	WB	58.5	60.3	63.5	68.2	73.2	77.3	79.0	78.4	75.3	70.3	63.4	60.3	(33)
		MCDB	62.4	65.5	70.3	75.7	81.6	86.7	88.6	88.2	84.3	76.8	68.7	64.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.9	19.7	21.2	21.6	20.2	19.4	19.0	20.6	22.6	23.7	22.5	19.1	(35)
		MCDBR	20.9	22.4	24.1	23.0	21.7	21.6	21.3	23.6	24.3	25.3	24.6	21.2	(36)
	5% WB	MCWBR	15.0	14.2	12.8	10.8	8.9	8.3	8.2	8.2	9.0	11.4	14.4	14.7	(37)
		MCWBR	17.7	19.0	20.5	18.7	18.5	18.8	19.3	20.1	19.9	19.1	20.6	18.1	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.322	0.331	0.370	0.403	0.442	0.476	0.504	0.502	0.436	0.374	0.342	0.322	(40)
		taud	2.512	2.484	2.390	2.291	2.235	2.158	2.114	2.115	2.290	2.435	2.474	2.524	(41)
	Ebn at Noon	Ebn at Noon	284	292	287	281	270	259	251	250	263	273	273	277	(42)
		Edh at Noon	27	30	36	42	45	48	50	49	40	32	28	25	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	822	973	1367	1714	1915	2061	1966	1821	1589	1295	941	718	(44)
	RadStd	RadStd	70	155	117	119	113	134	109	138	123	171	98	70	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page