

GREENWOOD-LEFLORE, MS, USA

WMO: 747580

Lat: 33.496N

Lon: 90.087W

Elev: 41

StdP: 100.84

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13978

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	-3.8	-12.7	1.3	-2.2	-10.0	1.6	-0.6	10.4	15.0	9.2	14.7	2.3	0	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	35.6	25.2	34.4	25.0	33.5	24.8	26.9	32.5	26.5	32.1	25.9	31.3	2.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	20.9	29.6	25.0	20.1	29.2	24.4	19.5	28.8	84.8	32.7	82.4	32.0	80.2	31.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.8	6.9	-9.6	37.5	2.2	2.0	-11.2	38.9	-12.6	40.0	-13.8	41.1	-15.4	42.6		
			-10.5	28.2	2.2	0.9	-12.0	28.8	-13.3	29.3	-14.6	29.8	-16.2	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	7.0	9.2	13.5	18.0	22.5	26.1	27.4	27.4	24.4	18.4	12.4	8.5
	DBStd	8.58	6.18	5.92	5.43	4.31	3.45	2.13	1.81	2.11	3.40	4.77	5.19	5.85
	HDD10.0	386	136	79	29	2	0	0	0	0	0	3	34	102
	HDD18.3	1403	354	259	165	58	9	0	0	0	3	59	187	309
	CDD10.0	3284	42	58	137	242	389	484	539	539	431	263	107	55
	CDD18.3	1263	2	4	14	48	139	234	281	281	184	62	9	4
	CDH23.3	12427	3	19	113	388	1209	2353	2943	2962	1791	571	62	13
	CDH26.7	5442	0	1	12	75	423	1061	1403	1482	799	178	7	1
(14) Wind	WSAvg	2.8	3.3	3.5	3.6	3.4	2.9	2.4	2.0	1.9	2.2	2.5	2.8	3.1
(15) Precipitation	PrecAvg	1352	119	115	139	132	133	106	100	73	86	91	121	141
	PrecMax	2031	288	203	428	373	360	476	282	195	192	322	262	417
	PrecMin	821	22	31	27	21	14	2	12	2	11	0	26	12
	PrecStd	296	72	52	77	77	80	88	65	52	50	69	65	93
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.3	25.8	28.0	30.3	33.0	35.5	36.2	37.7	36.2	32.5	27.6	25.2
		MCWB	18.1	19.1	19.1	21.4	23.3	24.7	26.0	25.2	23.5	22.3	20.3	19.8
	2%	DB	21.3	23.1	26.3	28.7	31.9	34.0	34.9	36.1	34.2	30.6	25.2	22.5
		MCWB	17.3	17.4	18.1	20.5	22.8	24.7	25.8	25.4	23.6	21.7	18.5	18.2
	5%	DB	19.2	21.2	24.4	27.4	30.6	32.9	33.9	34.6	32.8	28.7	23.0	20.3
		MCWB	15.8	16.4	17.1	19.4	22.5	24.5	25.6	25.2	23.5	20.3	17.6	17.1
	10%	DB	17.2	18.9	22.4	25.8	29.2	32.1	32.9	33.3	31.3	26.8	21.2	18.0
		MCWB	14.3	14.9	16.4	18.7	21.9	24.3	25.5	24.9	22.9	19.6	16.6	15.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	20.3	21.1	23.4	25.3	26.8	27.8	27.8	26.1	24.6	21.8	20.7
		MCDB	22.0	23.8	25.4	28.1	30.5	32.2	32.9	33.5	32.2	29.5	24.7	23.6
	2%	WB	18.0	18.9	19.7	22.0	24.3	26.1	27.1	26.9	25.2	23.5	20.4	19.1
		MCDB	20.5	22.1	23.9	26.4	29.5	31.8	32.4	32.7	30.8	28.0	23.4	21.9
	5%	WB	16.7	17.5	18.7	21.1	23.6	25.6	26.6	26.4	24.6	22.5	19.0	17.6
		MCDB	18.9	20.3	22.8	25.4	28.5	31.1	32.1	32.1	30.0	26.2	22.1	19.8
	10%	WB	14.7	15.7	17.5	20.1	22.9	25.1	26.1	25.8	24.0	21.3	17.5	15.7
		MCDB	16.9	18.6	21.3	24.3	27.6	30.4	31.4	31.2	29.1	24.9	20.4	17.8
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	11.0	11.8	12.0	11.2	10.8	10.6	11.4	12.6	13.2	12.5	10.6
		MCDBR	11.6	12.4	13.4	12.8	12.1	12.0	11.8	13.1	13.5	14.0	13.7	11.8
		MCWBR	8.3	7.9	7.1	6.0	5.0	4.6	4.6	4.5	5.0	6.3	8.0	8.2
	5% WB	MCDBR	9.8	10.6	11.4	10.4	10.3	10.4	10.7	11.1	11.1	10.6	11.5	10.0
		MCWBR	7.7	7.6	7.2	5.7	4.8	4.6	4.6	4.6	4.5	5.6	8.0	7.8
(40) Clear-Sky Solar Irradiance	taub		0.322	0.331	0.370	0.403	0.442	0.476	0.504	0.502	0.436	0.374	0.342	0.322
	taud		2.512	2.484	2.390	2.291	2.235	2.158	2.114	2.115	2.290	2.435	2.474	2.524
	Ebn at Noon		894	921	906	886	851	818	792	787	828	860	860	872
	Edh at Noon		85	96	114	132	141	152	158	155	125	100	87	79
(44) All-Sky Solar Radiation	RadAvg		2.59	3.07	4.31	5.40	6.04	6.50	6.20	5.74	5.01	4.08	2.97	2.26
	RadStd		0.22	0.49	0.37	0.37	0.36	0.42	0.34	0.43	0.39	0.54	0.31	0.22

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page