

SEBRING 23 SSE, FL, USA

WMO: 747650

Lat: 27.1526N

Lon: 81.3689W

Elev: 150

StdP: 14.62

Time Zone: -5.00 (NAE)

Period: 08-19

WBAN: 92827

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.3	39.9	25.5	19.6	47.7	29.9	24.1	49.8	13.8	64.7	12.6	63.0	1.5	N/A	0.284

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.1	93.3	76.0	92.0	76.0	90.8	75.9	79.2	87.1	78.5	86.5	78.1	86.2	4.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.3	143.0	81.9	76.7	139.7	81.5	76.0	136.4	81.2	42.7	87.1	42.1	86.9	41.5	86.4	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
11.7	10.1	8.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
			DB	28.3	95.4	4.4	1.3	25.1	96.4	22.5	97.1	20.0	97.9	16.8	98.8
			WB	27.5	80.4	4.2	0.6	24.5	80.9	22.0	81.2	19.6	81.6	16.6	82.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.9	61.0	65.0	66.6	72.3	76.4	80.2	81.1	81.7	80.3	75.4	68.6	65.5
	DBStd	8.90	8.29	7.93	6.78	4.60	3.38	2.15	1.86	1.60	1.97	5.22	6.79	8.12
	HDD50	30	18	5	1	0	0	0	0	0	0	0	0	6
	HDD65	480	170	89	66	7	0	0	0	0	0	8	43	97
	CDD50	8391	360	426	516	669	820	906	965	983	910	788	560	488
	CDD65	3367	47	90	117	226	355	456	500	518	460	332	153	113
	CDH74	28621	340	736	1066	2180	3393	4010	4444	4549	3729	2516	997	661
	CDH80	11059	30	138	245	736	1460	1819	1987	1955	1513	858	213	105
Wind	WSAvg	3.8	4.2	4.2	4.6	4.4	4.2	3.4	2.9	3.0	3.1	3.6	3.8	3.7
Precipitation	PrecAvg	53.3	2.0	2.6	2.7	2.8	3.2	9.3	7.6	8.5	7.4	3.6	1.9	1.9
	PrecMax	67.4	5.4	7.9	5.7	7.0	7.1	18.1	14.3	16.2	12.2	9.2	5.2	7.1
	PrecMin	32.2	0.2	0.1	0.2	0.4	1.0	2.0	4.3	3.4	2.2	0.5	0.3	0.2
	PrecStd	8.7	1.6	1.8	1.8	1.4	1.7	4.1	2.5	3.4	2.8	2.2	1.7	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.3	85.9	87.2	91.2	93.9	95.1	94.3	94.2	92.3	90.7	87.7	85.4
		MCWB	70.1	70.2	69.9	72.0	72.7	75.4	76.7	77.1	76.6	75.8	74.3	72.3
	2%	DB	80.3	83.7	85.0	88.6	91.3	93.2	92.5	92.7	90.7	89.0	85.2	83.0
		MCWB	68.2	69.2	68.7	71.3	72.5	75.6	76.6	77.2	76.5	75.2	73.5	71.6
	5%	DB	78.2	81.8	83.1	86.6	89.6	91.2	91.2	91.2	89.4	87.1	82.4	80.7
		MCWB	66.8	68.6	67.6	70.2	72.2	75.6	76.7	77.2	76.1	74.3	71.8	70.1
	10%	DB	75.2	79.3	80.4	84.6	87.8	89.2	89.6	89.6	88.1	85.2	80.0	78.0
		MCWB	65.0	67.3	67.0	69.2	71.7	75.6	76.7	77.2	76.0	72.6	69.6	68.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.4	73.1	73.4	75.7	76.5	79.2	79.7	80.2	79.4	78.5	76.4	74.8
		MCDB	78.8	80.7	81.8	84.7	85.1	88.1	87.7	87.5	86.4	84.4	83.4	80.7
	2%	WB	70.4	71.5	71.6	74.2	75.5	78.2	78.8	79.3	78.4	77.2	75.0	73.2
		MCDB	76.8	80.1	79.2	83.5	84.4	86.9	87.0	87.3	85.8	83.3	82.4	79.6
	5%	WB	68.8	70.2	70.2	73.0	74.7	77.4	78.2	78.7	77.9	76.2	73.5	71.7
		MCDB	74.4	78.3	78.4	82.3	83.9	86.1	86.5	86.9	85.5	82.7	80.2	77.6
	10%	WB	67.3	68.9	68.8	71.6	73.7	76.8	77.7	78.1	77.3	75.0	72.0	70.2
		MCDB	72.4	76.4	77.0	80.7	83.3	85.3	86.1	86.5	84.8	81.5	77.9	76.0
Mean Daily Temperature Range	5% DB	MDBR	23.1	24.1	25.0	24.7	23.3	19.4	18.1	17.1	16.7	18.8	21.1	21.4
		MCDBR	23.6	23.9	25.4	25.4	25.5	22.3	19.9	19.1	18.1	19.0	19.7	20.4
		MCWBR	11.9	10.8	10.6	10.1	8.9	7.6	6.8	6.7	6.7	6.9	8.6	9.8
	5% WB	MCDBR	19.4	21.3	21.6	21.9	21.0	18.5	17.7	17.3	16.5	15.6	17.9	18.3
		MCWBR	11.8	10.5	11.2	9.5	8.2	7.0	6.8	6.7	6.8	6.6	8.8	9.9
Clear-Sky Solar Irradiance	taub	0.344	0.358	0.374	0.386	0.415	0.447	0.463	0.451	0.422	0.399	0.360	0.349	
	taud	2.507	2.478	2.423	2.372	2.338	2.324	2.273	2.336	2.406	2.428	2.487	2.515	
	Ebn at Noon	287	291	292	289	279	268	264	267	273	273	279	279	
	Edh at Noon	30	33	36	39	41	41	43	40	36	34	30	28	
All-Sky Solar Radiation	RadAvg	1146	1385	1688	1957	2000	1791	1774	1722	1567	1456	1216	1049	
	RadStd	79	72	103	82	144	154	125	101	82	88	58	73	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+0.76	+1.46	N/A	N/A	N/A	N/A	-2	-54	+277	+209	

Nomenclature: See separate page