

MOSS POINT TRENT LOTT, MS, USA

WMO: 747688

Lat: 30.464N

Lon: 88.532W

Elev: 18

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53858

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.4	30.1	13.8	11.1	37.0	18.7	14.1	40.0	19.6	45.8	18.3	47.8	3.2	0	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	93.9	77.9	92.0	77.8	90.5	77.6	81.1	88.8	80.2	87.9	79.4	87.1	5.4	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.6	84.4	78.3	147.3	84.0	77.3	142.1	83.4	44.6	88.7	43.6	87.8	42.8	86.8	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.7	15.7	13.0	21.7	97.5	3.2	2.2	19.4	99.0	17.6	100.3	15.8	101.5	13.5	103.1		
			20.1	82.8	3.3	1.2	17.8	83.6	15.8	84.4	14.0	85.0	11.6	85.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	51.1	54.9	60.7	66.6	73.4	79.9	81.4	81.6	78.0	68.7	58.7	53.7	(6)
(7)		DBStd	12.88	9.83	9.07	7.83	6.22	4.97	2.82	2.41	2.46	4.40	7.52	8.31	9.42	(7)
(8)		HDD50	253	108	47	10	1	0	0	0	0	0	18	69		(8)
(9)		HDD65	1619	440	301	177	54	6	0	0	0	1	51	221	368	(9)
(10)		CDD50	6625	142	184	342	499	724	896	974	980	839	580	281	184	(10)
(11)		CDD65	2513	9	17	43	103	265	446	509	515	390	166	33	17	(11)
(12)		CDH74	22978	16	45	190	740	2520	4442	5022	4928	3411	1418	207	39	(12)
(13)		CDH80	8870	3	1	11	77	744	1922	2224	2141	1361	372	14	0	(13)
(14)	Wind	WSAvg	4.8	5.9	6.2	6.1	5.8	4.7	3.7	3.0	3.2	4.0	4.6	5.0	5.7	(14)
(15)	Precipitation	PrecAvg	66.6	5.9	5.4	5.6	4.9	5.3	5.6	7.2	7.1	6.1	3.9	4.5	5.1	(15)
(16)		PrecMax	90.0	17.1	12.7	14.0	18.9	14.3	14.4	19.4	16.5	26.2	13.1	11.3	11.1	(16)
(17)		PrecMin	35.9	1.1	0.2	0.3	0.2	0.2	0.6	0.4	1.5	0.4	0.0	0.0	1.7	(17)
(18)		PrecStd	12.6	3.7	3.0	3.0	4.4	3.4	3.5	4.1	4.0	4.8	3.4	2.8	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.4	78.6	81.4	84.4	91.5	95.7	95.9	96.1	95.0	89.5	81.9	77.5	(19)
(20)		MCWB	67.9	69.6	67.0	70.2	74.5	75.9	79.0	79.1	77.2	75.3	71.3	69.6		(20)
(21)		2%	DB	72.8	75.0	78.6	82.0	88.2	92.6	93.1	93.3	91.3	86.6	79.1	74.8	(21)
(22)		MCWB	66.5	67.1	67.5	70.0	73.4	76.8	78.6	78.7	76.3	74.0	69.9	68.9		(22)
(23)		5%	DB	70.2	72.2	75.9	80.6	86.0	90.5	91.2	91.4	89.4	84.0	76.4	72.7	(23)
(24)		MCWB	65.1	65.6	66.3	69.5	73.2	76.8	78.3	78.7	75.9	72.5	67.9	68.1		(24)
(25)		10%	DB	67.7	69.8	73.3	78.7	84.0	88.8	89.7	89.9	87.5	81.6	73.7	69.9	(25)
(26)		MCWB	63.9	64.4	65.0	68.4	72.7	76.4	78.1	78.5	75.7	71.5	66.4	65.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.2	71.4	72.3	75.6	78.3	80.9	82.0	83.1	80.5	78.9	75.3	73.4	(27)
(28)		MADB	73.5	75.1	77.3	80.4	85.2	89.6	90.5	90.9	87.4	84.1	79.3	75.3		(28)
(29)		2%	WB	68.4	69.6	70.5	74.2	77.0	79.8	80.7	81.4	79.4	77.3	72.8	70.9	(29)
(30)		MADB	71.1	73.0	74.6	79.1	83.8	88.4	88.8	88.8	86.4	83.3	76.4	73.3		(30)
(31)		5%	WB	66.5	67.7	69.2	72.9	75.9	78.7	80.0	80.4	78.3	75.9	70.4	68.9	(31)
(32)		MADB	69.2	70.8	73.2	77.6	82.7	86.9	88.1	87.7	85.3	81.7	74.6	71.5		(32)
(33)		10%	WB	64.1	65.5	67.7	71.4	75.0	78.0	79.1	79.6	77.6	74.1	68.3	66.3	(33)
(34)		MADB	67.3	68.3	71.9	75.6	81.6	85.8	87.1	86.8	84.5	79.1	72.7	69.2		(34)
(35)	Mean Daily Temperature Range	MDBR	21.8	21.1	21.9	21.7	21.0	18.4	17.2	17.1	19.0	22.9	24.6	21.4	(35)	
(36)		5% DB	MADB	20.0	20.0	21.2	21.5	22.4	21.0	19.6	19.4	20.4	22.2	23.5	19.6	(36)
(37)		MCWBR	14.3	12.9	12.1	11.4	10.4	8.5	7.7	7.8	8.4	10.9	14.6	14.3	(37)	
(38)		5% WB	MADB	16.3	15.5	16.9	15.9	17.2	17.5	17.4	17.2	16.7	16.5	18.9	16.8	(38)
(39)		MCWBR	13.2	11.9	11.3	10.3	8.8	8.0	7.7	7.8	7.8	9.5	13.9	13.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.350	0.374	0.404	0.438	0.464	0.512	0.503	0.449	0.385	0.355	0.341	(40)	
(41)		taud	2.546	2.503	2.429	2.345	2.287	2.260	2.151	2.171	2.288	2.457	2.484	2.535	(41)	
(42)		Ebn at Noon	285	290	289	282	272	263	250	252	262	274	275	276	(42)	
(43)		Edh at Noon	27	31	36	40	43	44	49	47	41	32	29	26	(43)	
(44)	All-Sky Solar Radiation	RadAvg	969	1145	1547	1891	2087	2003	1884	1780	1669	1452	1110	853	(44)	
(45)		RadStd	78	160	122	152	112	149	129	128	104	148	96	74	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+277	+180

Nomenclature: See separate page