

HOLLY SPRINGS 4 N, MS, USA

WMO: 747700

Lat: 34.8223N

Lon: 89.4348W

Elev: 148

StdP: 99.57

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 23803

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.8	(c) -7.1	(d) -15.7	(e) 1.0	(f) -6.4	(g) -12.7	(h) 1.3	(i) -4.6	(j) 4.9	(k) 11.9	(l) 4.5	(m) 11.0	(n) 0.7	(o) N/A	(p) 0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	34.0	24.3	32.9	24.4	31.9	24.2	26.3	31.7	25.7	30.9	25.2	30.2	1.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.9	20.3	29.3	24.1	19.4	28.6	23.7	18.9	28.1	82.5	31.7	80.0	31.1	77.7	30.4	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.4	(b) 3.8	(c) 3.3	(e) -13.9	(f) 35.6	(g) 3.1	(h) 1.6	(i) -16.2	(j) 36.8	(k) -18.0	(l) 37.7	(m) -19.8	(n) 38.6	(o) -22.0	(p) 39.8		
(a) 4.4	(b) 3.8	(c) 3.3	(e) -14.6	(f) 27.2	(g) 3.3	(h) 0.7	(i) -16.9	(j) 27.7	(k) -18.9	(l) 28.1	(m) -20.7	(n) 28.5	(o) -23.1	(p) 29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	3.8	6.5	10.6	15.6	20.2	24.3	25.6	25.2	22.2	15.6	9.3	6.1		
	DBStd	8.99	6.49	6.30	5.65	4.67	3.99	2.42	2.32	2.40	3.48	4.79	5.24	5.53		
	HDD10.0	649	212	135	62	8	0	0	0	0	0	8	74	148		
	HDD18.3	1943	452	333	244	106	32	1	0	0	9	112	273	380		
	CDD10.0	2639	19	36	81	177	316	429	483	470	366	182	53	28		
	CDD18.3	891	1	1	4	24	88	181	225	212	125	27	2	1		
	CDH23.3	8541	0	2	47	240	756	1774	2216	2011	1180	301	14	1		
	CDH26.7	3365	0	0	4	36	215	708	973	873	481	74	1	0		
(14) Wind	WSAvg	1.3	1.6	1.7	1.7	1.6	1.3	1.1	0.9	0.9	0.9	1.1	1.3	1.5		
(15) Precipitation	PrecAvg	1433	116	119	146	135	139	109	111	93	95	97	133	144		
	PrecMax	2108	271	284	346	460	330	294	282	206	236	257	316	404		
	PrecMin	952	17	18	51	32	20	8	17	8	11	0	36	22		
	PrecStd	226	65	60	71	75	76	69	67	49	57	60	68	78		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.4	23.5	27.2	29.4	31.5	34.3	35.3	35.8	34.4	30.8	25.3	23.0		
		MCWB	16.0	17.6	17.8	19.9	22.3	23.6	24.8	25.6	22.2	20.4	17.6	18.1		
	2%	DB	18.6	21.6	24.6	27.8	30.2	32.9	33.6	34.0	32.9	28.7	22.6	20.1		
		MCWB	15.4	17.2	16.8	18.6	22.0	24.6	25.3	24.8	22.8	20.4	16.9	16.9		
	5%	DB	16.2	19.6	22.3	26.2	29.1	31.7	32.6	32.7	31.5	26.8	20.6	18.0		
		MCWB	13.0	15.4	15.3	18.0	21.3	24.3	25.1	24.4	23.0	19.2	15.4	15.6		
	10%	DB	14.1	17.3	20.2	24.5	27.8	30.6	31.6	31.3	29.8	24.6	18.5	15.6		
		MCWB	11.0	13.4	14.3	17.1	20.7	23.7	24.8	24.0	22.3	18.5	14.5	13.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	19.0	19.1	21.7	24.2	26.6	26.9	27.4	25.1	23.7	20.3	19.7		
		MCDB	20.3	21.8	24.6	27.2	29.1	31.5	31.4	33.5	30.9	28.6	22.7	22.0		
	2%	WB	15.9	18.1	18.0	20.6	23.3	25.7	26.3	26.4	24.3	22.6	18.5	17.6		
		MCDB	17.8	20.9	22.9	25.4	28.2	30.9	31.5	32.2	29.9	26.8	21.4	19.7		
	5%	WB	13.9	16.4	16.8	19.6	22.6	25.1	25.7	25.6	23.8	21.1	16.9	16.0		
		MCDB	15.9	19.8	21.1	23.9	27.5	30.4	30.9	30.8	29.2	24.7	19.5	17.7		
	10%	WB	11.7	14.3	15.7	18.7	21.8	24.5	25.3	25.0	23.1	19.5	15.2	13.6		
		MCDB	13.4	16.7	19.2	22.9	26.5	29.3	30.4	29.6	28.3	23.4	17.9	15.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	11.8	13.1	13.6	11.8	11.4	10.9	11.4	12.8	13.9	13.4	10.8		
		MCDBR	13.1	12.9	15.1	14.8	13.0	12.6	12.1	13.0	14.4	15.7	15.3	11.9		
	5% WB	MCWBR	9.5	9.1	8.8	7.2	6.1	5.9	5.0	5.2	6.0	7.9	9.3	8.8		
		MCWBR	10.1	11.2	12.6	11.0	10.8	11.1	10.8	10.8	11.6	12.4	10.8	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.314	0.321	0.357	0.391	0.427	0.450	0.493	0.493	0.424	0.365	0.332	0.313		
	taud		2.512	2.488	2.413	2.310	2.262	2.208	2.128	2.111	2.300	2.442	2.481	2.527		
	Ebn at Noon		895	927	915	895	862	839	800	792	835	864	863	874		
	Edh at Noon		83	94	110	128	137	144	155	155	122	98	85	77		
(44) All-Sky Solar Radiation	RadAvg		2.45	2.95	4.11	5.24	5.89	6.44	6.17	5.68	4.89	3.86	2.77	2.10		
	RadStd		0.21	0.39	0.37	0.34	0.34	0.38	0.33	0.35	0.37	0.47	0.28	0.21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page