

HURLBURT FIELD, FL, USAWMO: **747770**Lat: **30.417N**Lon: **86.683W**Elev: **38**StdP: **14.68**Time Zone: **-6.00 (NAC)**Period: **94-19**WBAN: **03852****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.2	32.2	12.1	10.2	38.5	17.5	13.3	40.5	24.0	51.4	21.3	53.7	8.6	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	92.3	78.1	90.7	78.0	89.7	77.9	81.9	88.3	80.9	87.3	80.0	86.4	10.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	157.9	85.6	79.1	151.4	84.7	78.2	146.5	84.1	45.5	88.6	44.3	87.1	43.4	86.3	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	17.8	16.1	DB	21.0	96.2	5.8	2.4	16.8	97.9	13.3	99.3	10.1	100.7	5.8	102.5	(4)
(5)			WB	19.4	83.5	5.6	1.9	15.4	84.9	12.1	86.0	8.9	87.1	4.8	88.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.0	51.7	55.3	60.1	66.4	74.0	80.1	81.9	81.6	78.4	70.0	60.0	55.4	(6)
(7)		DBStd	12.57	9.52	8.55	7.60	5.83	4.89	3.16	2.51	2.59	3.95	7.00	8.00	9.11	(7)
(8)		HDD50	212	96	42	12	0	0	0	0	0	0	0	12	50	(8)
(9)		HDD65	1483	419	282	185	53	4	0	0	0	0	36	189	315	(9)
(10)		CDD50	6775	149	191	326	493	744	902	989	979	852	619	313	218	(10)
(11)		CDD65	2571	7	11	34	96	283	452	524	514	402	190	40	18	(11)
(12)		CDH74	25437	1	6	61	381	2500	4965	6070	5784	3978	1502	174	15	(12)
(13)		CDH80	9194	0	0	4	19	590	1854	2553	2417	1451	300	6	0	(13)
(14)	Wind	WSAvg	7.8	8.9	8.7	8.8	8.4	7.5	7.1	6.5	6.6	7.3	7.8	8.1	8.3	(14)
(15)	Precipitation	PrecAvg	60.1	4.4	4.7	5.5	5.0	3.4	5.4	7.2	6.3	5.7	3.5	4.1	4.8	(15)
(16)		PrecMax	77.6	17.2	8.5	11.2	15.1	10.9	12.1	16.7	10.4	27.1	10.4	12.4	10.0	(16)
(17)		PrecMin	39.6	0.6	1.5	0.5	1.0	0.5	1.3	2.8	2.5	1.5	0.2	0.4	1.8	(17)
(18)		PrecStd	10.7	3.0	2.1	3.0	3.1	2.6	2.8	3.5	2.1	4.9	3.0	3.0	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.2	75.0	79.2	82.1	90.6	93.8	95.1	94.6	92.9	88.1	80.9	75.5	(19)
(20)			MCWB	67.4	65.7	64.7	69.0	74.2	78.5	79.2	79.2	76.0	74.1	70.7	68.6	(20)
(21)		2%	DB	71.1	72.1	75.3	79.7	87.3	90.8	91.6	91.6	90.3	85.6	78.1	73.2	(21)
(22)			MCWB	66.4	64.9	66.3	69.0	74.8	78.4	78.8	78.6	75.8	74.3	70.2	68.5	(22)
(23)		5%	DB	68.8	69.8	73.1	77.9	85.3	89.4	90.4	90.3	88.5	83.5	75.8	71.8	(23)
(24)			MCWB	65.3	64.7	65.7	68.3	74.6	78.2	78.6	78.4	75.7	72.6	68.7	67.5	(24)
(25)		10%	DB	66.5	67.9	71.6	76.2	83.4	87.8	89.1	89.0	87.0	81.3	73.4	69.7	(25)
(26)			MCWB	63.5	63.7	65.4	67.9	73.9	77.4	78.3	78.1	75.6	72.1	66.7	66.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.3	70.4	72.1	75.2	80.1	82.5	83.1	83.7	81.5	79.9	75.9	72.1	(27)
(28)			MCDWB	71.0	72.4	75.0	78.1	83.8	88.6	89.9	90.0	87.3	83.6	78.0	74.2	(28)
(29)		2%	WB	68.1	68.4	70.0	73.6	78.3	81.0	81.5	82.0	79.9	77.9	73.1	70.3	(29)
(30)			MCDWB	69.4	70.0	72.3	77.0	82.9	87.5	88.0	88.4	85.8	81.8	76.4	72.1	(30)
(31)		5%	WB	66.2	66.7	68.5	72.4	77.2	80.0	80.4	80.9	78.6	76.2	70.8	68.8	(31)
(32)			MCDWB	67.9	68.3	71.0	75.8	82.4	86.4	87.2	87.3	84.6	80.8	74.2	70.5	(32)
(33)		10%	WB	64.2	64.9	67.0	70.9	75.9	78.9	79.6	79.8	77.7	74.4	68.9	66.8	(33)
(34)			MCDWB	66.0	66.7	70.0	74.2	81.2	85.2	86.6	86.2	83.9	79.4	72.5	68.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.6	18.1	17.8	17.0	16.9	14.7	14.3	14.4	16.2	18.9	20.6	17.9	(35)
(36)			MCDBR	15.8	15.9	16.6	16.9	17.9	16.4	16.2	16.1	17.8	17.6	19.1	15.9	(36)
(37)			MCWBR	13.4	11.4	10.7	9.9	8.9	7.4	7.2	7.2	7.9	9.3	12.9	13.2	(37)
(38)		5% WB	MCDWB	14.0	13.0	13.4	12.1	14.5	14.3	14.5	14.2	14.3	14.0	15.8	14.1	(38)
(39)			MCWBR	13.4	11.4	10.3	8.8	8.4	7.6	7.1	7.2	7.8	9.4	13.1	13.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.349	0.371	0.398	0.436	0.465	0.503	0.495	0.438	0.386	0.357	0.342	(40)	
(41)		taud	2.543	2.505	2.439	2.370	2.298	2.268	2.181	2.198	2.332	2.457	2.477	2.529	(41)	
(42)		Ebn at Noon	285	290	290	284	272	263	252	253	265	274	274	276	(42)	
(43)		Edh at Noon	27	31	35	39	42	43	47	46	39	32	29	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	988	1181	1599	1924	2136	2008	1890	1754	1641	1453	1120	870	(44)	
(45)		RadStd	73	154	125	153	121	162	120	132	99	137	98	86	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (36 neighbors)		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+270	+164	

Nomenclature: See separate page