

HURLBURT FIELD, FL, USAWMO: **747770**Lat: **30.417N**Lon: **86.683W**Elev: **12**StdP: **101.19**Time Zone: **-6.00 (NAC)**Period: **94-19**WBAN: **03852****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	0.1	-11.1	1.5	3.6	-8.1	1.9	4.7	10.7	10.8	9.5	12.1	3.8	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	33.5	25.6	32.6	25.6	32.1	25.5	27.7	31.3	27.1	30.7	26.7	30.2	4.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	29.8	26.2	21.6	29.3	25.6	20.9	28.9	87.9	31.5	85.2	30.6	83.0	30.2	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.9	8.0	7.2	-6.1	35.6	3.2	1.4	-8.5	36.6	-10.4	37.4	-12.2	38.2	-14.5	39.2
			-7.0	28.6	3.1	1.1	-9.2	29.4	-11.1	30.0	-12.8	30.6	-15.1	31.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	11.0	12.9	15.6	19.1	23.3	26.7	27.7	27.5	25.8	21.1	15.6	13.0
	DBStd	6.98	5.29	4.75	4.22	3.24	2.72	1.76	1.40	1.44	2.20	3.89	4.44	5.06
	HDD10.0	118	53	23	7	0	0	0	0	0	0	0	7	28
	HDD18.3	824	233	157	103	29	2	0	0	0	0	20	105	175
	CDD10.0	3764	83	106	181	274	413	501	549	544	473	344	174	121
	CDD18.3	1428	4	6	19	53	157	251	291	286	223	106	22	10
	CDH23.3	14132	1	3	34	212	1389	2758	3372	3213	2210	834	97	8
	CDH26.7	5108	0	0	2	11	328	1030	1418	1343	806	167	3	0
Wind	WSAvg	3.5	4.0	3.9	4.0	3.8	3.4	3.2	2.9	2.9	3.3	3.5	3.6	3.7
Precipitation	PrecAvg	1526	111	119	139	127	86	138	183	160	146	89	105	122
	PrecMax	1970	438	217	285	384	278	308	425	265	689	265	314	253
	PrecMin	1005	14	38	12	26	12	34	71	64	39	5	10	46
	PrecStd	273	77	53	76	80	67	70	88	53	124	75	77	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	23.9	26.2	27.8	32.6	34.4	35.0	34.8	33.8	31.2	27.2	24.2
		MCWB	19.7	18.7	18.2	20.5	23.4	25.8	26.2	26.2	24.4	23.4	21.5	20.3
	2%	DB	21.7	22.3	24.1	26.5	30.7	32.7	33.1	33.1	32.4	29.8	25.6	22.9
		MCWB	19.1	18.3	19.1	20.5	23.8	25.8	26.0	25.9	24.3	23.5	21.2	20.3
	5%	DB	20.5	21.0	22.9	25.5	29.6	31.9	32.4	32.4	31.4	28.6	24.3	22.1
		MCWB	18.5	18.2	18.7	20.2	23.7	25.7	25.9	25.8	24.3	22.6	20.4	19.7
	10%	DB	19.1	20.0	22.0	24.5	28.5	31.0	31.7	31.7	30.6	27.4	23.0	21.0
		MCWB	17.5	17.6	18.5	19.9	23.3	25.2	25.7	25.6	24.2	22.3	19.3	19.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.3	22.3	24.0	26.7	28.1	28.4	28.7	27.5	26.6	24.4	22.3
		MCDB	21.7	22.4	23.9	25.6	28.8	31.5	32.2	32.2	30.7	28.7	25.6	23.5
	2%	WB	20.1	20.2	21.1	23.1	25.7	27.2	27.5	27.8	26.6	25.5	22.8	21.3
		MCDB	20.8	21.1	22.4	25.0	28.3	30.9	31.1	31.3	29.9	27.7	24.7	22.3
	5%	WB	19.0	19.3	20.3	22.4	25.1	26.7	26.9	27.1	25.9	24.6	21.6	20.4
		MCDB	19.9	20.2	21.7	24.3	28.0	30.2	30.7	30.7	29.2	27.1	23.4	21.4
	10%	WB	17.9	18.3	19.4	21.6	24.4	26.1	26.4	26.6	25.4	23.5	20.5	19.3
		MCDB	18.9	19.3	21.1	23.5	27.4	29.6	30.3	30.1	28.8	26.3	22.5	20.5
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.1	9.9	9.5	9.4	8.1	7.9	8.0	9.0	10.5	11.4	9.9
		MCDBR	8.8	8.8	9.2	9.4	9.9	9.1	9.0	9.0	9.9	9.8	10.6	8.8
		MCWBR	7.4	6.3	5.9	5.5	5.0	4.1	4.0	4.0	4.4	5.1	7.2	7.3
	5% WB	MCDBR	7.8	7.2	7.5	6.7	8.0	7.9	8.1	7.9	8.0	7.8	8.8	7.9
		MCWBR	7.4	6.3	5.7	4.9	4.6	4.2	4.0	4.0	4.3	5.2	7.3	7.5
Clear-Sky Solar Irradiance	taub	0.334	0.349	0.371	0.398	0.436	0.465	0.503	0.495	0.438	0.386	0.357	0.342	
	taud	2.543	2.505	2.439	2.370	2.298	2.268	2.181	2.198	2.332	2.457	2.477	2.529	
	Ebn at Noon	899	915	914	896	859	829	796	799	836	863	863	870	
	Edh at Noon	86	97	111	123	133	136	148	144	122	101	91	84	
All-Sky Solar Radiation	RadAvg	3.12	3.72	5.04	6.06	6.74	6.33	5.96	5.53	5.17	4.58	3.53	2.74	
	RadStd	0.23	0.48	0.40	0.48	0.38	0.51	0.38	0.41	0.31	0.43	0.31	0.27	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+150	+91	

Nomenclature: See separate page