

HUNTER AAF, GA, USA

WMO: 747804

Lat: 32.017N

Lon: 81.133W

Elev: 41

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13824

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.8	31.6	11.6	10.0	39.2	16.2	12.5	39.7	23.4	50.6	20.7	51.5	5.7	270	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	95.4	77.6	93.3	77.3	91.1	77.1	81.6	88.5	80.5	87.7	79.5	86.9	8.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	156.7	84.3	78.8	149.9	83.7	77.4	142.9	82.8	45.2	89.0	44.0	87.9	42.9	86.7	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.3	16.9	14.9	22.0	99.7	3.2	2.4	19.7	101.4	17.8	102.8	16.0	104.2	13.6	105.9		
			19.8	83.4	3.3	1.5	17.5	84.4	15.6	85.3	13.8	86.1	11.4	87.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.8	50.6	54.8	60.3	66.9	74.5	80.2	82.7	81.7	77.8	69.1	59.7	54.2	(6)
(7)		DBStd	13.02	9.47	8.81	8.17	6.72	5.29	3.76	2.72	2.87	4.10	6.77	8.23	9.05	(7)
(8)		HDD50	244	110	46	16	0	0	0	0	0	0	14	58	(8)	
(9)		HDD65	1588	451	299	187	58	4	0	0	0	40	199	350	(9)	
(10)		CDD50	6739	130	181	336	509	761	905	1014	983	833	593	305	189	(10)
(11)		CDD65	2606	5	14	42	116	300	455	549	518	383	168	40	16	(11)
(12)		CDH74	23579	24	83	294	838	2514	4351	5824	5190	3148	1067	190	56	(12)
(13)		CDH80	9005	0	7	48	190	872	1822	2617	2144	1058	227	18	2	(13)
(14)	Wind	WSAvg	6.7	7.2	7.4	7.9	7.5	7.0	6.5	6.2	5.8	6.3	6.1	6.2	6.5	(14)
(15)	Precipitation	PrecAvg	46.3	3.1	3.1	3.5	2.9	3.3	6.0	5.6	5.5	4.6	3.7	2.1	2.8	(15)
(16)		PrecMax	68.5	8.9	10.0	7.4	6.9	8.8	12.9	11.5	13.0	8.1	18.9	5.0	10.4	(16)
(17)		PrecMin	32.0	0.2	0.3	0.1	0.3	0.9	1.1	1.5	2.3	0.6	0.0	0.0	0.3	(17)
(18)		PrecStd	8.4	2.2	2.0	2.0	2.0	2.3	2.6	2.5	2.2	1.9	4.0	1.7	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.2	80.9	84.8	89.4	95.0	97.4	98.6	97.8	93.2	88.1	82.2	78.9	(19)
(20)		0.4%	MCWB	66.7	66.5	66.9	69.6	72.6	77.6	77.4	78.7	76.0	75.8	71.5	69.8	(20)
(21)		2%	DB	72.7	76.7	80.9	84.8	91.0	94.6	95.4	94.2	90.2	84.7	79.1	75.2	(21)
(22)		2%	MCWB	64.1	66.1	65.9	69.5	72.9	77.3	78.5	78.3	75.9	73.3	68.9	67.4	(22)
(23)		5%	DB	68.8	72.7	77.2	81.9	87.9	91.5	93.2	91.3	88.1	82.3	75.7	71.7	(23)
(24)		5%	MCWB	61.7	63.0	64.1	68.2	72.6	76.7	78.2	78.0	75.4	71.4	67.0	66.3	(24)
(25)		10%	DB	65.6	68.7	73.5	79.1	84.7	89.1	90.9	89.7	86.1	80.4	72.7	68.2	(25)
(26)		10%	MCWB	60.6	60.6	62.6	66.5	71.9	76.4	78.1	77.6	75.2	70.4	66.1	64.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.0	72.2	71.5	75.4	77.9	82.2	83.1	83.3	81.0	78.3	75.7	73.4	(27)
(28)		0.4%	MCDWB	73.1	75.4	78.1	80.9	86.1	89.6	91.0	89.3	85.7	83.2	78.4	74.5	(28)
(29)		2%	WB	66.5	68.2	69.3	73.0	76.3	80.2	81.6	81.5	79.3	76.3	72.2	69.8	(29)
(30)		2%	MCDWB	70.3	74.0	76.1	80.1	84.1	88.1	88.8	88.1	84.6	81.1	75.4	72.6	(30)
(31)		5%	WB	64.2	65.4	67.4	71.1	75.1	79.0	80.4	80.4	78.2	74.9	70.1	67.4	(31)
(32)		5%	MCDWB	67.3	69.8	73.0	78.2	82.6	86.7	88.3	87.3	83.9	79.4	73.7	70.5	(32)
(33)		10%	WB	61.4	62.9	65.5	69.4	73.9	77.9	79.3	79.4	77.3	73.3	67.7	64.7	(33)
(34)		10%	MCDWB	64.3	67.0	71.1	75.6	81.1	85.6	87.7	86.4	83.1	77.7	71.6	67.9	(34)
(35)	Mean Daily Temperature Range		MDBR	20.6	20.7	20.9	20.7	19.3	17.3	17.2	16.0	15.7	18.7	20.4	19.7	(35)
(36)		5% DB	MCDBR	22.8	23.3	23.9	22.2	22.7	20.8	20.0	18.8	18.2	19.5	21.0	20.3	(36)
(37)			MCWBR	14.9	14.1	11.7	9.9	8.6	8.0	7.5	7.4	7.5	9.6	12.2	13.8	(37)
(38)			MCDBR	19.6	20.2	19.4	19.1	18.1	17.9	18.0	17.0	14.9	15.5	16.6	18.5	(38)
(39)		5% WB	MCWBR	15.0	14.6	11.3	10.1	7.8	8.1	7.8	7.4	7.4	9.3	11.6	14.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.331	0.337	0.370	0.402	0.451	0.494	0.525	0.509	0.429	0.396	0.357	0.346	(40)	
(41)		taud	2.528	2.512	2.439	2.340	2.238	2.171	2.095	2.142	2.364	2.423	2.487	2.511	(41)	
(42)		Ebn at Noon	283	293	289	282	268	255	246	249	266	268	271	271	(42)	
(43)		Edh at Noon	27	30	35	40	45	48	51	48	37	33	28	26	(43)	
(44)	All-Sky Solar Radiation	RadAvg	942	1144	1504	1892	2037	2017	1985	1796	1518	1325	1042	831	(44)	
(45)		RadStd	53	118	136	124	122	153	121	113	129	139	69	67	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.63	N/A	N/A	N/A	N/A	+0.29	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+1.03	+1.40	N/A	N/A	N/A	N/A	N/A	-153	+346	+238

Nomenclature: See separate page