

STATESBORO, GA, USA

WMO: 747805

Lat: 32.483N

Lon: 81.737W

Elev: 57

StdP: 100.64

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 63818

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	-1.1	-14.2	1.1	4.8	-10.3	1.6	5.7	9.3	11.9	8.4	11.5	1.0	320	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	36.3	25.8	35.2	25.4	34.0	25.3	29.6	33.2	28.7	32.0	27.6	29.8	2.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.7	25.4	32.3	27.7	23.9	30.4	27.2	23.2	29.5	97.5	32.7	93.2	32.1	88.2	30.8	33.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.4	5.3	-5.8	37.6	2.0	1.7	-7.2	38.8	-8.4	39.8	-9.5	40.7	-10.9	41.9		
(5)			-6.8	28.6	2.0	2.1	-8.2	30.1	-9.4	31.3	-10.6	32.4	-12.0	33.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	9.7	11.8	15.4	19.3	23.8	27.3	28.4	28.1	25.5	20.1	14.0	11.5	(6)
(7)		DBStd	7.71	5.34	4.85	4.72	3.80	3.17	2.15	1.81	1.91	2.42	3.99	4.46	4.99	(7)
(8)		HDD10.0	171	74	32	11	1	0	0	0	0	0	0	13	41	(8)
(9)		HDD18.3	1002	272	188	113	33	3	0	0	0	0	28	144	221	(9)
(10)		CDD10.0	3681	63	83	179	281	427	519	571	560	466	312	132	87	(10)
(11)		CDD18.3	1469	3	6	23	64	172	269	312	302	216	82	13	8	(11)
(12)		CDH23.3	14671	17	55	243	671	1693	2819	3383	3107	1891	658	96	38	(12)
(13)		CDH26.7	6482	0	4	47	198	729	1373	1669	1468	796	182	12	3	(13)
(14)	Wind	WSAvg	1.8	2.2	2.2	2.3	2.3	2.0	1.7	1.5	1.3	1.5	1.5	1.7	1.9	(14)
(15)	Precipitation	PrecAvg	1207	112	84	101	65	69	147	134	149	97	91	68	76	(15)
(16)		PrecMax	1629	239	240	219	154	201	305	273	325	180	313	190	152	(16)
(17)		PrecMin	758	20	10	7	13	5	47	64	58	8	3	16	12	(17)
(18)		PrecStd	254	56	50	66	39	45	72	55	77	49	81	48	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.5	27.4	30.1	32.4	36.1	37.5	37.6	37.6	35.1	32.3	28.0	27.0	(19)
(20)			MCWB	19.2	18.5	20.5	21.9	23.8	24.4	27.0	27.3	23.7	23.9	21.1	20.9	(20)
(21)		2%	DB	22.8	25.2	27.8	30.8	33.9	36.2	36.2	36.0	33.7	30.4	26.2	24.1	(21)
(22)			MCWB	18.0	17.4	18.8	20.9	23.0	24.7	26.6	26.3	24.1	22.7	20.2	20.3	(22)
(23)		5%	DB	20.9	22.8	26.2	29.0	32.4	34.7	35.0	34.2	32.5	28.7	24.0	22.3	(23)
(24)			MCWB	16.9	16.2	18.0	19.6	22.3	24.8	26.2	25.9	23.9	21.6	18.9	19.0	(24)
(25)		10%	DB	18.6	20.9	24.0	27.4	31.0	32.9	33.8	32.9	31.3	27.3	22.3	20.1	(25)
(26)			MCWB	15.9	15.4	16.7	18.7	21.9	24.6	26.3	25.4	23.8	21.1	17.8	17.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	20.8	23.0	24.7	27.6	29.4	30.6	31.6	28.9	27.5	24.2	23.6	(27)
(28)			MCDWB	23.0	23.5	26.6	29.0	31.6	33.2	34.9	35.6	31.8	29.4	26.7	24.6	(28)
(29)		2%	WB	19.5	19.4	21.1	23.0	25.9	28.4	29.6	29.6	27.4	25.4	22.3	21.4	(29)
(30)			MCDWB	21.6	22.9	24.5	26.7	30.1	32.0	33.8	32.3	29.0	26.9	24.2	22.9	(30)
(31)		5%	WB	18.1	18.0	20.0	21.9	24.6	27.3	28.9	28.2	26.3	24.0	20.8	19.7	(31)
(32)			MCDWB	20.0	21.3	23.7	25.6	28.2	30.0	32.5	30.6	28.6	26.3	22.4	21.6	(32)
(33)		10%	WB	16.5	16.8	18.8	20.7	23.6	26.2	27.8	27.2	25.5	22.9	18.9	17.9	(33)
(34)			MCDWB	18.1	19.6	22.5	24.5	27.2	29.8	30.0	29.4	28.8	25.4	21.6	19.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.9	12.7	13.3	13.5	12.4	11.1	10.6	10.2	10.6	12.2	13.1	11.7	(35)
(36)			MCDBR	13.5	14.9	15.1	15.0	14.0	12.8	12.1	11.6	12.3	12.9	14.3	12.7	(36)
(37)			MCWBR	9.0	8.4	7.2	6.0	4.9	4.2	4.4	4.0	4.5	6.1	8.8	8.4	(37)
(38)		5% WB	MCDBR	11.5	12.5	12.3	12.1	11.2	10.4	10.8	10.1	9.6	9.5	10.9	10.5	(38)
(39)			MCWBR	9.0	8.9	7.3	6.5	5.4	5.0	5.6	5.1	4.9	5.8	8.5	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.335	0.365	0.400	0.449	0.496	0.527	0.518	0.427	0.392	0.354	0.330	(40)	
(41)		taud	2.496	2.468	2.415	2.310	2.208	2.130	2.060	2.083	2.328	2.390	2.451	2.519	(41)	
(42)		Ebn at Noon	894	921	914	891	846	802	775	777	840	845	852	870	(42)	
(43)		Edh at Noon	87	99	112	130	145	156	167	161	121	106	91	81	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.94	3.56	4.63	5.83	6.27	6.28	6.12	5.57	4.79	4.13	3.23	2.56	(44)	
(45)		RadStd	0.15	0.34	0.38	0.39	0.40	0.47	0.41	0.31	0.40	0.45	0.23	0.23	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.58	+0.74	N/A	N/A	N/A	N/A	-93	+198	+138

Nomenclature: See separate page