

THOMASTON, GA, USA

WMO: 747806

Lat: 32.955N

Lon: 84.264W

Elev: 243

StdP: 98.44

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 63809

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.7	-2.0	-17.6	0.8	3.8	-13.8	1.2	5.6	10.0	10.6	8.9	10.0	2.7	320	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	35.2	25.1	33.9	24.7	32.8	24.1	27.8	32.4	26.8	31.1	26.1	30.3	2.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	23.3	30.3	26.0	22.0	29.2	25.0	20.6	28.3	90.1	33.3	85.7	31.8	82.4	30.0	36.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.1	6.9	5.7	-7.6	36.3	2.4	2.2	-9.3	37.9	-10.6	39.2	-12.0	40.4	-13.7	42.0		
			-8.8	27.2	2.3	1.8	-10.5	28.4	-11.9	29.5	-13.2	30.4	-14.8	31.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	8.2	10.1	14.0	17.7	22.2	26.1	27.2	26.9	24.4	18.8	13.0	9.9
	DBStd	7.79	5.36	4.78	4.64	3.76	3.29	2.28	1.71	2.00	2.72	4.02	4.38	4.82
	HDD10.0	256	99	54	17	2	0	0	0	0	0	1	19	63
	HDD18.3	1233	314	233	146	54	9	0	0	0	1	44	167	264
	CDD10.0	3269	44	56	142	234	377	484	534	524	431	273	110	60
	CDD18.3	1205	1	2	12	36	128	234	276	266	182	58	8	3
	CDH23.3	11131	1	9	109	360	1133	2253	2767	2545	1483	420	46	6
	CDH26.7	4631	0	0	16	73	401	1026	1281	1142	591	98	3	0
(14) Wind	WSAvg	2.3	2.8	2.8	2.8	2.6	2.3	1.9	1.7	1.7	2.1	2.1	2.3	2.6
(15) Precipitation	PrecAvg	1250	112	110	146	83	68	110	156	98	97	67	91	97
	PrecMax	1614	237	205	318	168	178	219	475	169	310	167	267	215
	PrecMin	993	54	21	13	25	13	34	58	48	26	2	21	48
	PrecStd	201	42	45	74	41	38	51	102	36	63	44	63	39
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.5	25.0	28.7	31.1	33.6	37.1	36.3	37.3	34.9	31.3	27.2	23.9
		MCWB	16.5	17.0	18.4	22.0	22.2	26.5	26.7	23.7	21.7	21.6	19.3	18.6
	2%	DB	21.0	22.4	26.3	28.0	32.2	35.0	34.9	34.9	32.8	29.0	24.8	22.1
		MCWB	15.9	16.0	17.4	19.2	22.2	25.5	25.9	25.1	22.6	20.3	18.4	17.6
	5%	DB	18.0	20.1	23.9	27.3	30.9	33.0	33.6	33.0	32.1	27.5	22.6	20.0
		MCWB	15.0	14.5	16.7	18.1	21.9	24.1	25.4	24.8	22.6	19.3	17.4	17.2
	10%	DB	17.1	17.8	22.3	25.9	28.9	32.2	32.5	32.3	30.2	26.1	21.1	17.8
		MCWB	14.1	13.8	15.8	17.2	21.0	23.6	24.6	24.4	22.2	18.8	16.7	14.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	19.7	21.1	23.9	25.9	32.4	30.8	28.8	26.1	24.2	22.9	21.8
		MCDB	20.9	21.9	24.2	28.4	30.4	33.7	32.1	32.9	29.7	27.4	24.3	22.2
	2%	WB	17.7	17.7	19.9	21.7	24.4	27.3	27.6	27.6	25.3	23.0	21.1	19.1
		MCDB	18.5	19.4	24.1	26.2	28.9	31.3	32.6	32.0	29.6	25.5	22.3	20.5
	5%	WB	16.2	16.3	18.7	20.5	23.4	26.0	26.7	26.7	24.6	22.1	18.9	17.5
		MCDB	17.7	19.0	22.1	24.7	28.1	30.7	31.5	30.4	28.7	24.9	21.6	18.9
	10%	WB	14.2	15.0	17.3	19.3	22.4	25.1	25.9	25.9	23.8	20.8	17.4	15.5
		MCDB	16.2	17.9	20.3	23.4	26.9	29.9	30.6	29.6	27.4	23.7	19.4	17.7
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	11.0	12.0	12.6	11.7	10.7	10.4	9.9	10.4	11.4	11.9	10.5
		MCDBR	12.3	12.8	14.0	14.4	13.3	12.3	11.7	11.3	12.5	12.7	13.3	11.6
		MCWBR	8.6	7.8	7.0	7.0	5.4	5.1	4.4	4.7	4.5	6.2	7.9	8.0
	5% WB	MCDBR	10.1	10.5	12.0	11.9	11.0	10.5	10.7	9.8	9.5	9.4	10.9	10.0
		MCWBR	8.6	8.0	7.5	7.7	6.1	5.8	5.0	5.1	5.0	6.3	8.3	8.6
(40) Clear-Sky Solar Irradiance	taub		0.316	0.320	0.348	0.384	0.430	0.470	0.509	0.513	0.418	0.368	0.341	0.318
	taud		2.528	2.510	2.455	2.339	2.252	2.197	2.098	2.074	2.327	2.452	2.472	2.538
	Ebn at Noon		905	937	931	905	862	823	789	779	847	870	865	882
	Edh at Noon		84	94	107	126	139	146	160	162	121	99	88	79
(44) All-Sky Solar Radiation	RadAvg		2.80	3.38	4.47	5.59	6.19	6.15	5.99	5.44	4.77	4.08	3.11	2.39
	RadStd		0.15	0.40	0.37	0.38	0.49	0.49	0.37	0.31	0.46	0.50	0.28	0.25

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+156	+107

Nomenclature: See separate page