

MOODY AFB, GA, USA

WMO: 747810

Lat: 30.967N

Lon: 83.200W

Elev: 233

StdP: 14.57

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13857

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.5	32.2	12.1	10.3	37.0	17.2	13.2	39.9	21.4	58.1	19.2	54.8	5.4	310	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	95.8	76.4	94.0	76.2	92.4	75.9	80.3	89.6	79.2	88.8	78.2	87.5	7.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.1	147.3	84.0	76.9	141.3	82.8	75.7	135.8	81.7	44.0	89.8	42.7	88.9	41.7	87.8	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	15.8	12.9	22.0	98.5	5.5	2.2	18.0	100.1	14.8	101.3	11.7	102.6	7.7	104.2
			19.5	82.3	5.1	2.2	15.8	83.9	12.8	85.2	10.0	86.4	6.3	88.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.3	51.7	56.3	61.1	67.7	75.3	80.5	82.2	81.8	77.9	69.5	59.5	55.6
	DBStd	12.62	9.41	9.19	7.99	6.11	5.01	3.56	2.75	2.81	4.00	6.76	7.85	9.14
	HDD50	209	93	41	14	0	0	0	0	0	0	0	13	48
	HDD65	1443	419	263	166	43	3	0	0	0	37	199	313	
	CDD50	6902	147	218	359	530	784	916	1000	985	837	606	299	221
	CDD65	2659	8	20	46	122	322	466	535	520	387	177	35	21
	CDH74	24888	42	133	411	1189	3151	4591	5454	5047	3225	1318	231	96
	CDH80	10580	0	10	61	329	1335	2200	2611	2321	1326	355	28	4
Wind	WSAvg	5.8	6.5	6.5	6.7	6.5	5.8	5.3	5.1	4.9	5.0	5.6	5.6	5.9
Precipitation	PrecAvg	47.2	3.9	4.0	4.2	3.7	3.0	5.5	5.6	5.4	3.9	2.8	2.4	3.2
	PrecMax	68.3	18.3	8.3	10.9	9.6	5.8	11.3	8.6	9.2	14.8	10.7	5.7	6.1
	PrecMin	36.1	0.4	0.8	0.0	0.7	0.6	1.2	3.0	1.6	0.8	0.0	0.2	1.2
	PrecStd	8.5	3.5	1.9	2.6	2.2	1.3	2.8	1.4	1.8	3.2	2.5	1.6	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.5	81.6	84.5	89.1	95.3	98.5	97.4	97.4	94.7	89.4	83.5	80.1
		MCWB	66.5	66.9	66.3	69.5	71.9	74.5	76.8	77.9	75.1	75.3	69.6	68.1
	2%	DB	74.6	78.1	81.8	86.4	92.2	95.4	95.3	94.7	91.8	86.4	79.7	76.9
		MCWB	63.9	65.6	65.8	68.1	71.8	75.8	77.1	77.7	74.9	72.7	67.7	66.4
	5%	DB	70.8	75.0	78.8	84.0	89.9	93.2	93.4	92.8	89.9	84.0	76.7	73.2
		MCWB	62.6	63.4	64.1	67.4	71.2	76.0	76.8	77.1	74.7	71.0	65.5	65.6
	10%	DB	66.8	71.4	75.6	81.3	87.4	90.8	91.4	90.7	87.8	81.5	73.1	70.0
		MCWB	60.1	62.2	62.5	65.9	70.6	75.5	76.8	76.8	74.2	69.5	64.8	64.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.5	70.4	71.2	73.3	77.0	81.1	82.4	82.6	79.4	78.0	74.0	71.8
		MCDB	72.7	75.9	78.4	81.5	86.8	90.3	89.9	91.9	87.3	84.2	79.0	75.4
	2%	WB	66.7	68.3	69.0	71.5	75.4	79.3	80.1	80.5	78.0	76.2	71.4	69.7
		MCDB	71.6	74.0	75.8	80.0	84.9	90.1	89.6	89.7	86.3	82.0	75.2	72.7
	5%	WB	64.4	66.4	67.3	70.2	74.2	78.0	79.0	79.1	77.1	74.5	69.0	67.7
		MCDB	68.5	72.2	74.1	78.5	83.5	88.2	88.9	88.3	85.3	79.8	73.5	71.3
	10%	WB	62.1	64.4	65.4	68.8	73.0	76.9	78.0	78.1	76.1	72.9	66.3	65.5
		MCDB	66.4	69.4	72.9	76.9	82.2	86.6	87.5	86.8	83.7	78.1	71.6	70.0
Mean Daily Temperature Range	5% DB	MDBR	21.3	21.6	22.7	22.8	22.0	19.7	18.7	18.0	18.2	20.6	22.1	20.0
		MCDBR	23.9	23.4	25.2	25.7	24.2	22.5	20.7	20.2	20.9	21.1	23.8	21.4
		MCWBR	14.8	12.7	11.8	10.3	7.8	7.2	6.7	6.8	7.1	9.2	12.7	12.7
	5% WB	MCDBR	20.2	19.5	20.4	21.0	20.2	19.7	18.7	18.3	17.4	17.1	18.2	17.7
		MCWBR	14.8	12.5	11.6	11.0	7.9	7.7	7.1	7.2	6.7	8.8	12.1	12.6
Clear-Sky Solar Irradiance	taub	0.327	0.334	0.360	0.387	0.426	0.472	0.509	0.495	0.430	0.377	0.347	0.331	
	taud	2.518	2.497	2.445	2.355	2.287	2.219	2.119	2.159	2.333	2.453	2.485	2.530	
	Ebn at Noon	287	295	293	287	275	261	251	253	267	276	277	279	
	Edh at Noon	28	31	35	40	43	45	50	48	38	32	29	26	
All-Sky Solar Radiation	RadAvg	979	1167	1536	1870	2046	1910	1910	1731	1553	1364	1089	858	
	RadStd	64	136	131	142	126	128	114	114	128	123	77	77	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	+0.38	N/A	N/A	N/A	N/A
Regional (32 neighbors)	+0.90	N/A	N/A	N/A	N/A	N/A	-40	-142	+302	+207

Nomenclature: See separate page