

FT LAUDERDALE HOLLYWOOD, FL, USA

WMO: 747830

Lat: 26.079N

Lon: 80.162W

Elev: 11

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12849

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.8	51.9	30.4	24.6	54.7	36.4	31.6	56.7	24.9	70.7	22.6	70.2	9.0	320	0.422

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	91.5	78.4	90.5	78.3	89.8	78.3	81.2	87.6	80.5	86.9	80.0	86.5	11.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.6	84.5	78.8	149.7	84.3	78.1	146.2	83.9	44.6	87.6	44.0	87.2	43.3	86.4	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.6	19.5	18.1	DB	41.3	94.9	3.8	3.0	38.6	97.1	36.4	98.9	34.3	100.6	31.5	102.8	
			WB	36.6	82.8	4.2	2.3	33.6	84.4	31.1	85.8	28.8	87.1	25.8	88.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.4	68.2	70.7	72.9	76.6	79.9	82.7	84.0	84.1	82.8	80.1	74.6	71.4
	DBStd	7.07	7.21	6.34	5.50	3.83	2.76	2.57	2.17	2.03	2.18	3.63	4.81	6.66
	HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1
	HDD65	127	56	26	12	1	0	0	0	0	0	0	4	28
	CDD50	9991	566	579	709	798	928	981	1055	1056	985	932	739	663
	CDD65	4640	156	185	255	349	463	531	590	591	535	467	293	225
	CDH74	43841	557	832	1408	2506	4400	5958	7193	7197	6108	4629	1915	1138
	CDH80	13980	26	83	216	470	1182	2196	3041	3005	2220	1231	231	79
Wind	WSAvg	9.2	9.5	9.6	10.6	10.5	9.8	8.0	7.6	7.5	7.9	10.0	9.9	9.5
Precipitation	PrecAvg	64.0	2.6	2.9	2.8	3.3	6.5	10.2	6.5	7.2	8.6	7.1	4.1	2.2
	PrecMax	87.2	10.0	13.8	12.3	19.4	15.7	24.4	14.0	15.5	18.0	20.7	14.6	7.1
	PrecMin	35.6	0.3	0.1	0.0	0.0	0.2	3.5	1.3	1.0	1.4	0.9	0.6	0.1
	PrecStd	11.1	2.1	2.5	2.7	3.5	3.5	4.7	3.1	3.2	3.9	4.9	3.2	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.5	85.1	87.9	90.2	92.7	93.4	93.3	92.8	91.8	89.8	86.2	84.1
		MCWB	72.5	71.3	73.0	73.9	74.8	78.6	79.2	78.4	78.0	78.0	75.8	75.0
	2%	DB	80.4	82.3	84.4	86.2	88.7	90.9	91.2	91.1	90.1	87.9	84.1	82.0
		MCWB	71.5	72.2	72.7	73.2	75.3	78.5	78.9	78.7	78.2	77.3	75.1	73.5
	5%	DB	78.9	80.7	82.2	84.2	86.9	89.6	90.2	90.2	88.8	86.4	82.4	80.7
		MCWB	70.6	71.5	71.9	72.9	75.2	78.2	78.7	78.7	78.1	76.7	73.8	72.6
	10%	DB	77.2	78.9	80.4	82.5	85.4	88.1	89.2	89.2	87.8	85.3	81.2	79.2
		MCWB	69.6	70.7	70.7	71.9	74.8	77.8	78.5	78.7	77.8	76.2	72.8	71.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	76.3	76.6	77.6	79.5	81.8	82.1	81.9	81.4	81.3	78.5	77.1
		MCDB	79.8	80.4	82.3	84.2	85.0	88.8	88.6	87.8	87.3	85.6	81.8	80.7
	2%	WB	73.9	74.5	74.9	76.1	78.2	80.6	81.0	80.9	80.4	79.7	77.3	75.8
		MCDB	77.8	79.0	81.1	82.4	84.2	87.4	87.8	87.3	86.4	84.8	81.8	79.8
	5%	WB	72.7	73.2	73.7	75.1	77.3	79.9	80.3	80.3	79.9	78.4	76.1	74.9
		MCDB	76.8	78.1	79.6	81.2	83.6	86.6	87.2	86.8	85.8	83.8	80.9	79.0
	10%	WB	71.2	72.2	72.7	74.0	76.4	79.0	79.6	79.7	79.2	77.8	75.0	73.5
		MCDB	75.9	77.2	78.7	80.3	82.8	85.7	86.6	86.4	85.1	83.3	80.0	77.8
Mean Daily Temperature Range	5% DB	MDBR	13.6	13.1	13.0	11.7	10.9	10.7	10.7	10.7	10.1	9.9	11.5	12.0
		MCDBR	11.5	12.7	13.8	13.3	12.9	12.3	11.8	11.6	11.0	10.2	10.4	10.4
		MCWBR	6.4	6.1	6.2	6.0	5.5	5.4	5.1	4.7	4.6	4.5	5.4	5.6
	5% WB	MCDBR	10.9	11.1	12.3	11.7	11.4	11.3	11.0	10.7	10.2	9.5	9.2	9.6
MCWBR		7.1	6.0	6.7	5.9	5.6	5.7	5.6	5.1	5.0	4.8	5.5	6.0	
Clear-Sky Solar Irradiance	taub	0.364	0.373	0.387	0.402	0.428	0.464	0.469	0.462	0.435	0.415	0.381	0.373	
	taud	2.520	2.512	2.458	2.401	2.368	2.327	2.307	2.352	2.427	2.449	2.494	2.513	
	Ebn at Noon	282	288	288	285	275	264	262	265	270	270	273	273	
	Edh at Noon	30	32	35	38	40	41	42	40	36	34	30	29	
All-Sky Solar Radiation	RadAvg	1156	1407	1719	1958	1977	1812	1850	1780	1566	1440	1227	1070	
	RadStd	77	85	88	93	165	163	90	96	80	103	60	77	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (27 neighbors)	+0.68	+1.55	N/A	N/A	N/A	N/A	N/A	-38	+234	+184

Nomenclature: See separate page