

FT LAUDERDALE HOLLYWOOD, FL, USA

WMO: 747830

Lat: 26.079N

Lon: 80.162W

Elev: 3

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12849

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	11.0	-0.9	3.5	12.6	2.4	4.5	13.7	11.1	21.5	10.1	21.2	4.0	320	0.422

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.0	33.0	25.8	32.5	25.7	32.1	25.7	27.3	30.9	26.9	30.5	26.7	30.3	5.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	29.2	26.0	21.4	29.0	25.6	20.9	28.9	85.9	30.9	84.4	30.6	82.9	30.2	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.7	8.1	DB	5.2	35.0	2.1	1.7	3.7	36.2	2.4	37.2	1.3	38.1	-0.3	39.3	(4)
			WB	2.5	28.2	2.3	1.3	0.9	29.1	-0.5	29.9	-1.8	30.6	-3.4	31.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	20.1	21.5	22.7	24.8	26.6	28.2	28.9	28.9	28.2	26.7	23.7	21.9	(6)
	DBStd	3.93	4.01	3.52	3.06	2.13	1.53	1.43	1.20	1.13	1.21	2.02	2.67	3.70	(7)
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	1	(8)
	HDD18.3	71	31	14	7	1	0	0	0	0	0	0	2	16	(9)
	CDD10.0	5551	314	322	394	443	516	545	586	587	547	518	411	368	(10)
	CDD18.3	2578	87	103	142	194	257	295	328	328	297	259	163	125	(11)
	CDH23.3	24356	309	462	782	1392	2444	3310	3996	3998	3393	2572	1064	632	(12)
	CDH26.7	7767	14	46	120	261	657	1220	1689	1669	1233	684	128	44	(13)
Wind	WSAvg	4.1	4.3	4.3	4.7	4.7	4.4	3.6	3.4	3.4	3.5	4.5	4.4	4.3	(14)
Precipitation	PrecAvg	1626	65	73	71	84	164	259	164	183	219	180	104	57	(15)
	PrecMax	2216	255	351	313	494	400	619	356	393	456	525	371	180	(16)
	PrecMin	903	8	2	0	1	5	89	32	25	35	24	16	3	(17)
	PrecStd	281	54	64	68	89	90	119	80	82	100	125	82	45	(18)
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	29.5	31.0	32.4	33.7	34.1	34.1	33.8	33.2	32.1	30.1	28.9	(19)
		MCWB	22.5	21.9	22.8	23.3	23.8	25.9	26.2	25.8	25.5	25.6	24.3	23.9	(20)
	2%	DB	26.9	27.9	29.1	30.1	31.5	32.7	32.9	32.8	32.3	31.0	28.9	27.8	(21)
		MCWB	21.9	22.4	22.6	22.9	24.1	25.8	26.1	25.9	25.7	25.2	23.9	23.0	(22)
	5%	DB	26.1	27.0	27.9	29.0	30.5	32.0	32.3	32.3	31.5	30.2	28.0	27.1	(23)
		MCWB	21.5	22.0	22.2	22.7	24.0	25.6	26.0	26.0	25.6	24.9	23.2	22.6	(24)
	10%	DB	25.1	26.1	26.9	28.0	29.6	31.2	31.8	31.8	31.0	29.6	27.3	26.2	(25)
		MCWB	20.9	21.5	21.5	22.2	23.8	25.5	25.8	25.9	25.5	24.6	22.7	22.1	(26)
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	24.6	24.8	25.3	26.4	27.7	27.8	27.7	27.4	27.4	25.8	25.1	(27)
		MCDB	26.5	26.9	27.9	29.0	29.5	31.6	31.5	31.0	30.7	29.8	27.6	27.1	(28)
	2%	WB	23.3	23.6	23.8	24.5	25.7	27.0	27.2	27.2	26.9	26.5	25.2	24.4	(29)
		MCDB	25.4	26.1	27.3	28.0	29.0	30.8	31.0	30.7	30.2	29.3	27.6	26.6	(30)
	5%	WB	22.6	22.9	23.2	23.9	25.2	26.6	26.8	26.8	26.6	25.8	24.5	23.8	(31)
		MCDB	24.9	25.6	26.4	27.3	28.7	30.3	30.7	30.5	29.9	28.8	27.2	26.1	(32)
	10%	WB	21.8	22.3	22.6	23.4	24.7	26.1	26.4	26.5	26.2	25.4	23.9	23.1	(33)
		MCDB	24.4	25.1	26.0	26.9	28.2	29.8	30.4	30.2	29.5	28.5	26.6	25.5	(34)
Mean Daily Temperature Range		MDBR	7.5	7.3	7.2	6.5	6.1	5.9	6.0	5.9	5.6	5.5	6.4	6.7	(35)
	5% DB	MCDBR	6.4	7.0	7.7	7.4	7.2	6.8	6.5	6.4	6.1	5.7	5.8	5.8	(36)
		MCWBR	3.6	3.4	3.5	3.3	3.0	3.0	2.8	2.6	2.5	2.5	3.0	3.1	(37)
	5% WB	MCDBR	6.0	6.2	6.8	6.5	6.4	6.3	6.1	5.9	5.7	5.3	5.1	5.3	(38)
		MCWBR	4.0	3.3	3.7	3.3	3.1	3.2	3.1	2.8	2.8	2.6	3.0	3.3	(39)
Clear-Sky Solar Irradiance	taub	0.364	0.373	0.387	0.402	0.428	0.464	0.469	0.462	0.435	0.415	0.381	0.373	(40)	
	taud	2.520	2.512	2.458	2.401	2.368	2.327	2.307	2.352	2.427	2.449	2.494	2.513	(41)	
	Ebn at Noon	888	907	909	898	868	832	827	834	851	851	862	862	(42)	
	Edh at Noon	93	100	111	121	125	129	132	125	114	106	95	91	(43)	
All-Sky Solar Radiation	RadAvg	3.64	4.44	5.42	6.17	6.23	5.71	5.83	5.61	4.94	4.54	3.87	3.37	(44)	
	RadStd	0.24	0.27	0.28	0.29	0.52	0.51	0.28	0.30	0.25	0.32	0.19	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
Regional (27 neighbors)		+0.38	+0.86	N/A	N/A	N/A	N/A	N/A	-21	+130	+102	(47)

Nomenclature: See separate page