

MYRTLE BEACH, SC, USA

WMO: 747910

Lat: 33.683N

Lon: 78.933W

Elev: 25

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13717

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.1	27.8	7.0	7.9	29.5	11.9	10.1	35.1	24.4	49.4	21.4	45.9	6.1	350	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	91.0	77.7	89.6	77.9	87.7	77.5	81.1	87.0	79.9	85.9	78.7	84.7	11.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.3	152.2	84.8	78.3	147.1	84.1	76.9	140.2	83.0	44.6	86.9	43.2	85.5	42.2	85.2	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.2	18.9	17.6	DB	18.7	95.6	3.7	3.0	16.1	97.8	13.9	99.6	11.8	101.3	9.1	103.5
			WB	14.9	82.1	3.3	1.8	12.5	83.4	10.5	84.5	8.6	85.5	6.2	86.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.0	46.0	50.0	55.1	62.4	70.8	77.1	80.0	79.1	75.3	66.2	56.0	49.1	(6)
(7)		DBStd	13.94	10.00	8.80	8.17	7.20	6.34	4.46	3.18	3.40	4.76	7.37	8.31	9.14	(7)
(8)		HDD50	514	200	100	46	2	0	0	0	0	0	1	34	131	(8)
(9)		HDD65	2353	590	424	317	132	22	2	0	0	4	77	288	497	(9)
(10)		CDD50	5625	76	100	204	374	643	814	932	903	760	503	214	102	(10)
(11)		CDD65	1989	1	4	10	54	200	366	467	438	314	114	18	3	(11)
(12)		CDH74	16977	1	11	40	227	1344	3183	4769	4224	2466	649	56	7	(12)
(13)		CDH80	4910	0	1	5	44	298	895	1640	1353	590	82	2	0	(13)
(14)	Wind	WSAvg	8.6	8.5	8.4	9.5	9.9	9.3	8.8	8.3	8.0	8.9	7.8	7.6	7.9	(14)
(15)	Precipitation	PrecAvg	51.0	3.5	3.5	3.8	2.8	3.7	4.8	5.8	6.7	6.3	4.1	2.8	3.3	(15)
(16)		PrecMax	70.1	8.8	12.0	8.1	6.5	7.2	12.7	10.4	14.2	21.4	13.5	5.9	10.1	(16)
(17)		PrecMin	34.3	0.8	0.9	1.1	0.1	1.3	0.4	3.0	3.3	1.6	0.1	0.2	1.0	(17)
(18)		PrecStd	8.3	2.0	2.1	1.8	1.7	1.5	2.6	1.9	2.5	4.4	3.3	1.5	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.4	75.4	79.2	85.5	91.4	92.8	95.5	93.9	89.6	85.2	79.3	74.8	(19)
(20)			MCWB	62.9	63.9	63.6	66.5	74.4	76.6	80.1	79.2	76.3	75.6	68.3	64.8	(20)
(21)		2%	DB	68.0	70.8	73.5	79.4	86.6	89.9	90.9	90.3	87.0	82.0	75.1	70.3	(21)
(22)			MCWB	61.4	62.1	62.5	66.7	74.0	76.7	79.0	79.1	76.4	73.1	66.9	63.2	(22)
(23)		5%	DB	64.3	66.7	71.2	75.5	82.4	87.2	89.4	88.2	84.6	80.1	72.7	66.5	(23)
(24)			MCWB	59.3	60.6	61.8	65.7	72.1	76.3	78.8	78.4	75.8	71.9	65.7	62.1	(24)
(25)		10%	DB	62.6	63.9	67.9	73.2	80.9	84.3	87.5	86.1	83.5	78.0	70.2	63.9	(25)
(26)			MCWB	57.7	58.2	60.3	64.5	71.2	75.6	78.3	77.6	75.3	71.1	64.2	59.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.4	67.2	68.3	71.1	77.6	80.8	83.1	82.9	80.0	77.8	71.9	67.2	(27)
(28)			MCD B	69.8	72.4	74.5	80.3	84.6	87.5	91.3	89.6	83.5	81.4	76.4	72.1	(28)
(29)		2%	WB	62.7	64.6	65.6	69.4	75.9	78.9	81.3	81.1	78.4	76.1	69.5	65.0	(29)
(30)			MCD B	65.8	68.5	70.8	76.2	82.6	85.7	87.4	86.8	83.3	79.9	73.2	68.3	(30)
(31)		5%	WB	60.8	62.2	63.8	67.9	74.5	77.8	80.2	79.7	77.5	74.2	67.3	62.9	(31)
(32)			MCD B	64.3	65.7	68.2	74.0	81.1	84.2	86.4	85.7	83.3	78.6	71.7	66.2	(32)
(33)		10%	WB	58.2	59.5	61.9	66.4	73.0	76.7	79.0	78.4	76.4	72.3	65.0	60.3	(33)
(34)			MCD B	61.9	63.6	66.8	71.9	79.4	82.9	85.2	84.3	82.0	77.0	69.2	63.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.3	18.3	18.7	17.9	16.2	13.9	13.4	13.7	14.3	17.3	19.5	18.2	(35)
(36)			MCDBR	19.9	19.6	20.1	18.5	16.9	16.5	15.8	15.2	14.9	16.3	19.5	19.1	(36)
(37)			MCWBR	15.7	13.9	13.1	10.7	8.7	7.7	7.6	7.5	7.5	9.3	13.0	14.6	(37)
(38)		5% WB	MCD BR	17.8	18.1	17.4	15.9	14.0	13.9	13.7	13.4	12.5	11.8	16.7	17.6	(38)
(39)			MCWBR	15.7	14.4	13.7	10.0	7.8	7.4	7.8	7.3	6.9	7.4	13.0	14.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.335	0.366	0.399	0.460	0.483	0.527	0.503	0.429	0.394	0.351	0.330	(40)	
(41)		taud	2.522	2.498	2.431	2.326	2.208	2.189	2.084	2.147	2.346	2.414	2.490	2.542	(41)	
(42)		Ebn at Noon	282	291	288	282	265	258	246	250	265	266	269	273	(42)	
(43)		Edh at Noon	27	30	35	40	46	47	51	48	37	32	27	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	870	1081	1449	1846	2004	2063	1961	1764	1503	1264	969	775	(44)	
(45)		RadStd	53	107	130	123	137	132	121	97	114	135	73	60	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+0.90	N/A	N/A	N/A	N/A	N/A	N/A	+301	+212

Nomenclature: See separate page