

GEORGETOWN, SC, USA

WMO: 747918

Lat: 33.317N

Lon: 79.317W

Elev: 40

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00391

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 25.2	(c) 28.1	(d) 9.5	(e) 8.9	(f) 31.9	(g) 14.2	(h) 11.3	(i) 36.4	(j) 22.0	(k) 58.0	(l) 19.1	(m) 54.9	(n) 3.6	(o) 320	(p) 0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.7	(c) 91.5	(d) 77.6	(e) 90.4	(f) 77.5	(g) 88.4	(h) 77.0	(i) 81.3	(j) 86.1	(k) 80.6	(l) 85.2	(m) 79.4	(n) 83.8	(o) 8.2	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.6	159.2	83.6	79.2	151.7	82.5	78.7	148.9	82.1	44.8	86.5	43.9	86.4	43.0	84.9	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.6	(b) 16.4	(c) 14.3	(e) 19.9	(f) 96.1	(g) 4.3	(h) 2.1	(i) 16.8	(j) 97.7	(k) 14.3	(l) 98.9	(m) 11.9	(n) 100.1	(o) 8.8	(p) 101.7		
(4) 18.6	(5) 16.4	(6) 14.3	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	45.4	50.1	54.9	63.5	71.1	77.6	80.0	79.1	75.3	65.8	54.6	50.8
	DBStd	13.95	10.12	9.10	8.92	7.02	5.38	4.14	2.96	3.04	3.97	7.32	7.52	9.68
	HDD50	524	217	104	54	2	0	0	0	0	0	1	34	112
	HDD65	2344	611	421	330	111	15	0	0	0	0	81	324	451
	CDD50	5660	73	107	206	406	653	827	930	901	759	491	171	136
	CDD65	2006	2	4	17	64	203	378	465	436	310	106	11	10
	CDH74	16474	12	33	133	456	1522	3279	4353	3695	2229	693	49	20
	CDH80	5469	0	0	15	57	412	1203	1705	1295	674	106	2	0
	WSAvg	5.9	5.9	6.7	7.1	7.3	6.3	5.6	5.5	4.6	5.1	5.3	5.3	5.6
	PrecAvg	55.5	4.2	3.5	4.3	2.7	4.0	5.9	7.0	7.0	5.9	4.3	2.8	3.6
(15) Precipitation	PrecMax	74.3	10.7	12.5	12.8	8.0	9.5	12.0	15.7	19.5	17.3	13.1	11.7	10.4
	PrecMin	36.6	0.4	0.6	0.8	0.0	0.6	1.4	0.1	1.0	0.6	0.0	0.0	0.7
	PrecStd	10.5	2.3	2.4	2.4	2.0	2.5	2.5	3.4	4.5	4.4	3.7	2.3	2.1
	PrecStd	10.5	2.3	2.4	2.4	2.0	2.5	2.5	3.4	4.5	4.4	3.7	2.3	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.4	78.6	81.9	84.3	91.4	95.2	95.3	93.4	90.3	86.3	79.3	77.0
		MCWB	66.2	65.3	64.8	67.8	72.3	79.2	77.1	79.6	76.1	75.8	69.5	69.6
	2%	DB	70.3	73.2	77.5	81.5	87.9	91.2	91.4	90.5	88.2	82.1	74.7	72.5
		MCWB	64.4	63.6	63.8	68.7	72.4	77.4	78.0	78.4	75.8	73.2	66.9	66.8
	5%	DB	65.6	70.2	73.1	79.2	84.1	89.9	90.4	88.5	86.3	80.9	72.0	70.1
		MCWB	61.3	62.6	62.2	67.8	72.9	76.9	78.1	78.0	75.7	72.0	65.8	66.2
	10%	DB	62.7	65.7	70.1	76.9	81.5	87.6	88.4	87.5	84.1	78.6	68.9	66.4
		MCWB	59.0	61.0	61.3	66.5	72.1	76.2	77.8	77.9	75.4	70.5	63.5	63.4
	0.4%	WB	68.1	69.8	69.5	75.1	79.6	83.4	82.8	82.2	81.0	79.2	73.0	71.3
		MCDB	71.7	72.0	74.6	79.7	82.3	90.7	89.5	87.7	83.9	81.1	76.9	75.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	66.0	66.9	66.9	72.9	77.8	80.8	81.3	81.2	79.4	77.1	70.1	69.6
		MCDB	70.2	72.1	73.2	77.7	81.1	86.1	86.8	85.4	82.8	79.6	72.2	71.3
	5%	WB	63.3	64.1	64.7	71.0	75.4	79.0	80.4	80.4	78.3	75.0	67.5	66.1
		MCDB	64.4	67.4	70.4	76.0	81.7	84.1	85.8	84.6	82.1	79.2	70.1	68.6
	10%	WB	59.5	61.4	63.1	69.0	73.4	77.6	79.2	79.2	77.0	72.7	64.6	63.3
		MCDB	61.6	65.5	67.4	73.3	78.7	83.4	84.4	83.4	81.5	76.6	67.6	65.0
(35) Mean Daily Temperature Range	5% DB	MDBR	19.8	21.0	21.5	21.3	19.3	17.5	16.7	15.4	17.0	20.1	21.5	18.9
		MCDBR	24.4	24.7	25.1	23.3	22.7	19.9	18.7	17.1	18.8	19.4	23.2	19.2
		MCWBR	17.6	15.6	13.5	12.3	10.5	8.4	8.2	7.9	9.0	11.0	15.2	13.6
		MCDBR	19.9	21.7	20.9	18.2	18.6	17.5	16.8	15.3	15.6	15.1	17.6	17.5
	5% WB	MCWBR	16.9	16.6	12.8	11.3	11.5	9.2	9.1	8.5	8.9	9.5	13.5	14.0
		MCWBR	16.9	16.6	12.8	11.3	11.5	9.2	9.1	8.5	8.9	9.5	13.5	14.0
(40) Clear-Sky Solar Irradiance	taub		0.329	0.336	0.366	0.402	0.469	0.487	0.533	0.509	0.433	0.393	0.349	0.330
	taud		2.525	2.503	2.441	2.319	2.187	2.184	2.069	2.133	2.339	2.427	2.504	2.551
	Ebn at Noon		282	291	289	281	263	257	244	248	264	267	271	275
	Edh at Noon		27	30	35	41	47	47	52	49	38	32	27	25
(44) All-Sky Solar Radiation	RadAvg		882	1090	1460	1868	2019	2063	1969	1768	1511	1283	982	787
	RadStd		54	111	132	128	142	141	120	99	122	139	74	62

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+346	+245

Nomenclature: See separate page