

VERO BEACH, FL, USA

WMO: 747930

Lat: 27.651N

Lon: 80.420W

Elev: 9

StdP: 101.22

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12843

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.8	(c) 6.2	(d) -3.4	(e) 2.8	(f) 7.9	(g) -0.2	(h) 3.7	(i) 10.2	(j) 10.8	(k) 21.1	(l) 9.4	(m) 18.5	(n) 3.1	(o) 320	(p) 0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.5	(c) 33.4	(d) 25.1	(e) 32.7	(f) 25.3	(g) 32.2	(h) 25.3	(i) 26.9	(j) 31.1	(k) 26.6	(l) 30.8	(m) 26.2	(n) 30.3	(o) 4.6	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.2	28.9	25.2	20.4	28.7	25.0	20.1	28.5	83.8	31.0	82.3	30.5	80.9	30.5	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.3	7.5	0.8	35.6	1.9	1.0	-0.6	36.3	-1.7	36.9	-2.8	37.4	-4.2	38.1
			-1.1	27.7	2.2	0.6	-2.7	28.2	-3.9	28.5	-5.1	28.9	-6.7	29.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	16.8	18.3	20.0	22.4	24.9	27.0	27.7	27.7	27.1	24.8	21.1	18.8	(6)
(7)		DBStd	4.84	4.49	4.22	3.75	2.84	1.95	1.31	1.12	1.01	1.18	2.70	3.45	4.36	(7)
(8)		HDD10.0	9	6	2	0	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD18.3	231	82	49	28	6	0	0	0	0	0	2	15	49	(9)
(10)		CDD10.0	4789	218	234	311	372	463	511	548	550	514	459	334	276	(10)
(11)		CDD18.3	1969	36	48	80	127	205	261	289	292	264	203	99	65	(11)
(12)		CDH23.3	17234	160	258	478	904	1769	2513	3026	3013	2532	1713	575	293	(12)
(13)		CDH26.7	5643	13	36	91	196	518	945	1244	1207	872	418	77	26	(13)
(14)	Wind	WSAvg	3.6	3.7	3.8	4.2	4.2	3.9	3.3	3.0	3.0	3.2	3.8	3.7	3.5	(14)
(15)	Precipitation	PrecAvg	1326	70	74	92	65	74	159	153	165	177	122	88	51	(15)
(16)		PrecMax	1693	226	176	325	265	146	526	293	295	391	314	299	137	(16)
(17)		PrecMin	960	8	1	6	1	2	8	33	85	42	19	9	5	(17)
(18)		PrecStd	217	54	52	75	65	41	118	77	68	86	87	67	39	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	29.6	31.1	32.1	33.3	34.4	34.5	34.0	33.3	32.2	30.3	28.7	(19)
(20)			MCWB	21.6	21.5	22.1	22.1	23.4	24.6	25.3	25.4	25.2	24.9	23.8	23.0	(20)
(21)		2%	DB	26.5	27.7	28.9	30.2	32.0	32.9	33.0	32.9	32.3	30.9	28.7	27.3	(21)
(22)			MCWB	20.8	21.3	21.4	22.2	23.1	25.0	25.6	25.7	25.4	24.8	23.2	22.2	(22)
(23)		5%	DB	25.2	26.3	27.4	28.8	30.5	32.2	32.4	32.3	31.3	29.8	27.4	26.3	(23)
(24)			MCWB	20.3	20.9	20.9	21.9	23.3	25.1	25.6	25.8	25.3	24.3	22.2	21.5	(24)
(25)		10%	DB	23.8	24.9	26.1	27.6	29.2	31.1	31.8	31.6	30.8	28.9	26.3	25.0	(25)
(26)			MCWB	19.5	20.0	20.2	21.2	23.0	25.0	25.6	25.7	25.1	23.7	21.4	20.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	23.3	24.1	24.7	25.6	26.9	27.4	27.4	27.1	26.5	25.0	24.0	(27)
(28)			MCD B	26.0	26.7	27.3	28.6	29.8	31.5	31.6	31.6	30.9	29.6	28.2	27.2	(28)
(29)		2%	WB	21.9	22.5	22.9	23.8	24.9	26.3	26.8	26.9	26.5	25.8	24.2	23.2	(29)
(30)			MCD B	24.7	25.7	26.5	27.6	29.1	30.8	31.1	31.1	30.4	28.9	27.1	26.0	(30)
(31)		5%	WB	21.2	21.7	22.2	23.0	24.4	25.8	26.4	26.5	26.0	25.3	23.5	22.6	(31)
(32)			MCD B	23.9	25.0	25.8	26.8	28.4	30.2	30.7	30.8	29.7	28.5	26.3	25.1	(32)
(33)		10%	WB	20.4	21.0	21.3	22.4	23.9	25.4	25.9	26.1	25.6	24.8	22.7	21.8	(33)
(34)			MCD B	23.2	24.0	24.8	26.2	27.9	29.7	30.2	30.2	29.3	27.8	25.4	24.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.0	11.0	10.8	10.2	9.3	8.7	8.7	8.5	7.8	8.0	9.3	9.9	(35)
(36)			MCDBR	10.7	11.1	11.3	11.0	10.8	10.1	9.5	9.2	8.5	8.1	8.8	9.3	(36)
(37)			MCWBR	6.3	5.8	5.4	4.8	4.4	3.9	3.8	3.7	3.4	3.6	4.6	5.2	(37)
(38)		5% WB	MCDBR	9.6	9.7	10.1	9.6	9.1	8.9	8.8	8.4	7.8	7.1	7.9	8.3	(38)
(39)			MCWBR	6.3	5.3	5.5	4.8	4.2	3.9	3.9	3.8	3.5	3.5	4.5	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.347	0.355	0.370	0.396	0.426	0.453	0.469	0.458	0.425	0.393	0.362	0.358	(40)	
(41)		taud	2.534	2.528	2.474	2.377	2.338	2.338	2.287	2.338	2.423	2.483	2.515	2.525	(41)	
(42)		Ebn at Noon	899	920	923	902	870	841	826	835	856	867	874	870	(42)	
(43)		Edh at Noon	90	97	109	123	128	128	134	126	113	101	91	88	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.44	4.23	5.19	6.07	6.23	5.87	5.80	5.59	4.92	4.41	3.62	3.13	(44)	
(45)		RadStd	0.24	0.23	0.31	0.22	0.47	0.51	0.37	0.34	0.26	0.28	0.18	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-31	+151	+116

Nomenclature: See separate page