

HOLLISTER, CA, USA

WMO: 749179

Lat: 36.900N

Lon: 121.417W

Elev: 237

StdP: 14.57

Time Zone: -8.00 (NAP)

Period: 09-19

WBAN: 00392

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	31.5	32.3	18.7	14.2	44.8	22.8	17.3	45.0	21.9	57.8	19.0	57.5	0.8	60	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.9	93.4	65.9	90.1	65.2	85.8	64.2	68.4	87.6	67.0	85.5	65.8	82.6	10.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.2	87.5	68.6	61.3	81.8	67.6	60.6	79.7	67.6	32.6	86.9	31.4	84.9	30.5	82.3	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.4	19.6	17.9	DB	26.2	101.6	2.7	3.7	24.3	104.3	22.7	106.4	21.2	108.5	19.3	111.2
			WB	24.2	72.5	2.6	2.4	22.3	74.2	20.8	75.6	19.3	76.9	17.4	78.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.4	50.7	51.8	55.1	57.6	60.8	65.6	68.0	68.2	68.1	62.8	54.8	49.4	(6)
	DBStd	8.35	4.57	5.15	4.73	5.13	4.62	4.98	4.25	4.21	5.13	5.20	5.26	5.01	(7)
	HDD50	186	47	39	10	3	0	0	0	0	0	0	15	72	(8)
	HDD65	2493	443	369	308	230	148	48	16	13	22	106	306	484	(9)
	CDD50	3631	69	90	168	231	334	467	557	563	542	397	160	53	(10)
	CDD65	465	0	0	1	8	18	65	108	112	114	38	1	0	(11)
	CDH74	6375	6	14	77	257	418	984	1207	1166	1409	729	108	0	(12)
	CDH80	2539	0	0	12	88	152	386	472	460	660	291	18	0	(13)
(14) Wind	WSAvg	5.2	3.6	4.6	4.9	5.8	7.0	7.2	7.0	6.1	5.2	4.0	3.2	3.4	(14)
(15) Precipitation	PrecAvg	16.5	3.6	3.4	2.2	1.0	0.5	0.1	0.0	0.0	0.0	0.8	1.5	3.1	(15)
	PrecMax	28.4	8.7	11.8	8.1	3.7	2.4	0.4	0.0	0.3	0.4	3.5	4.4	6.5	(16)
	PrecMin	8.6	0.4	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.4	(17)
	PrecStd	5.3	2.4	2.4	2.1	0.9	0.6	0.1	0.0	0.1	0.1	1.0	1.2	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.1	75.4	81.4	89.7	90.8	97.1	95.4	96.9	99.6	95.4	82.1	70.1	(19)
		MCWB	54.4	59.1	62.7	63.7	62.9	68.9	66.2	67.9	65.7	63.3	60.9	54.9	(20)
	2%	DB	69.6	72.3	75.1	81.3	83.8	90.1	90.1	90.1	93.3	87.9	77.1	65.8	(21)
		MCWB	54.9	57.8	59.1	61.3	61.5	65.9	66.4	66.9	65.4	61.6	59.5	53.9	(22)
	5%	DB	64.3	66.4	72.0	75.0	78.7	83.6	84.5	84.4	88.0	81.8	72.2	63.1	(23)
		MCWB	54.2	55.9	57.8	58.8	61.0	64.2	65.2	65.7	64.5	60.1	57.6	54.6	(24)
	10%	DB	61.4	63.3	66.4	70.3	72.7	79.4	81.2	81.1	81.8	76.7	66.3	60.6	(25)
		MCWB	53.7	55.0	56.6	57.4	59.0	62.8	64.3	64.6	63.4	58.7	55.3	54.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.7	63.4	63.7	65.7	66.0	69.9	69.4	69.4	68.5	68.3	67.9	62.8	(27)
		MCDB	65.3	67.7	74.0	81.7	84.3	92.0	89.3	87.9	89.4	81.9	72.5	64.1	(28)
	2%	WB	57.8	60.5	61.4	62.6	63.2	67.3	67.5	67.7	66.9	65.5	62.0	60.4	(29)
		MCDB	63.4	67.6	71.0	78.1	79.7	86.8	86.1	87.5	87.4	76.9	71.3	62.3	(30)
	5%	WB	56.0	58.3	59.4	60.6	61.5	65.0	66.0	66.1	65.6	63.3	59.5	57.3	(31)
		MCDB	61.7	64.7	68.9	72.5	76.5	81.4	83.3	83.3	84.8	74.1	67.3	59.6	(32)
	10%	WB	54.2	56.1	57.4	58.6	59.5	63.3	64.5	64.8	64.2	61.4	57.4	54.9	(33)
		MCDB	59.8	61.8	64.4	68.3	71.5	77.9	79.9	79.6	80.1	73.7	64.1	57.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	23.3	23.0	24.0	25.2	24.2	27.2	26.9	26.8	30.3	29.7	26.4	21.7	(35)
		MCDBR	29.3	31.4	33.0	35.8	35.4	36.2	34.2	34.4	40.2	38.3	34.5	26.0	(36)
		MCWBR	18.0	18.7	18.4	18.3	17.1	15.7	14.1	14.5	16.9	18.1	19.3	16.5	(37)
	5% WB	MCDBR	22.3	25.8	27.4	30.5	30.6	32.4	30.6	31.0	34.3	30.4	26.7	15.1	(38)
		MCWBR	15.1	16.7	16.3	16.5	15.4	14.7	13.3	13.5	15.2	15.3	16.6	11.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.320	0.325	0.324	0.350	0.360	0.345	0.355	0.342	0.343	0.339	0.316	0.311	(40)
	taud		2.519	2.511	2.512	2.423	2.410	2.466	2.452	2.471	2.470	2.498	2.537	2.560	(41)
	Ebn at Noon		277	290	300	295	292	295	292	294	289	280	277	273	(42)
	Edh at Noon		25	29	31	36	37	35	36	34	32	29	24	23	(43)
(44) All-Sky Solar Radiation	RadAvg		813	1104	1559	1986	2350	2597	2511	2271	1890	1387	956	722	(44)
	RadStd		97	123	135	169	121	84	57	54	52	77	51	94	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (43 neighbors)		+0.74	N/A	-2.07	N/A	N/A	N/A	N/A	-220	+268	+67	

Nomenclature: See separate page