

HOLLISTER, CA, USAWMO: **749179**Lat: **36.900N**Lon: **121.417W**Elev: **72**StdP: **100.46**Time Zone: **-8.00 (NAP)**Period: **09-19**WBAN: **00392****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-0.3	0.2	-7.4	2.0	7.1	-5.1	2.5	7.2	9.8	14.4	8.5	14.2	0.3	60	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	34.1	18.8	32.3	18.4	29.9	17.9	20.2	30.9	19.4	29.7	18.8	28.1	4.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	12.5	20.3	16.3	11.7	19.8	15.9	11.4	19.8	58.0	30.5	55.2	29.4	53.0	27.9	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.8	8.0	-3.2	38.7	1.5	2.1	-4.3	40.1	-5.2	41.4	-6.0	42.5	-7.1	44.0		
(5)			-4.3	22.5	1.5	1.3	-5.4	23.4	-6.2	24.2	-7.0	24.9	-8.1	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	10.4	11.0	12.8	14.2	16.0	18.6	20.0	20.1	20.0	17.1	12.7	9.7
	DBStd	4.64	2.54	2.86	2.63	2.85	2.57	2.77	2.36	2.34	2.85	2.89	2.92	2.79
	HDD10.0	103	26	22	6	2	0	0	0	0	0	0	8	40
	HDD18.3	1385	246	205	171	128	82	27	9	7	12	59	170	269
	CDD10.0	2017	38	50	93	128	186	259	309	313	301	221	89	29
	CDD18.3	258	0	0	1	4	10	36	60	62	63	21	1	0
	CDH23.3	3542	3	8	43	143	232	547	671	648	783	405	60	0
	CDH26.7	1411	0	0	7	49	84	214	262	256	367	162	10	0
Wind	WSAvg	2.3	1.6	2.0	2.2	2.6	3.1	3.2	3.1	2.7	2.3	1.8	1.4	1.5
Precipitation	PrecAvg	419	92	86	56	26	13	2	0	1	1	21	38	79
	PrecMax	722	222	300	207	94	62	9	1	8	11	88	113	166
	PrecMin	219	11	3	0	1	0	0	0	0	0	2	5	11
	PrecStd	134	60	62	54	24	16	3	0	2	3	25	31	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	24.1	27.5	32.1	32.7	36.1	35.2	36.1	37.5	35.2	27.8	21.1
		MCWB	12.4	15.1	17.1	17.6	17.2	20.5	19.0	19.9	18.7	17.4	16.1	12.7
	2%	DB	20.9	22.4	23.9	27.4	28.8	32.3	32.3	32.3	34.0	31.1	25.0	18.8
		MCWB	12.7	14.3	15.0	16.3	16.4	18.9	19.1	19.4	18.6	16.4	15.3	12.2
	5%	DB	18.0	19.1	22.2	23.9	26.0	28.7	29.1	29.1	31.1	27.7	22.3	17.3
		MCWB	12.3	13.3	14.3	14.9	16.1	17.9	18.5	18.7	18.1	15.6	14.2	12.6
	10%	DB	16.3	17.4	19.1	21.3	22.6	26.3	27.3	27.3	27.7	24.8	19.1	15.9
		MCWB	12.1	12.8	13.7	14.1	15.0	17.1	17.9	18.1	17.5	14.9	12.9	12.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.9	17.4	17.6	18.7	18.9	21.1	20.8	20.8	20.3	20.2	19.9	17.1
		MCDB	18.5	19.8	23.3	27.6	29.0	33.3	31.8	31.1	31.9	27.7	22.5	17.9
	2%	WB	14.3	15.8	16.4	17.0	17.4	19.6	19.7	19.8	19.4	18.6	16.7	15.8
		MCDB	17.4	19.8	21.7	25.6	26.5	30.4	30.0	30.8	30.8	24.9	21.8	16.8
	5%	WB	13.4	14.6	15.2	15.9	16.4	18.4	18.9	19.0	18.7	17.4	15.3	14.1
		MCDB	16.5	18.2	20.5	22.5	24.7	27.5	28.5	28.5	29.3	23.4	19.6	15.3
	10%	WB	12.4	13.4	14.1	14.8	15.3	17.4	18.0	18.2	17.9	16.4	14.1	12.7
		MCDB	15.4	16.6	18.0	20.1	22.0	25.5	26.6	26.5	26.7	23.2	17.8	14.3
Mean Daily Temperature Range	5% DB	MDBR	12.9	12.8	13.3	14.0	13.5	15.1	14.9	14.9	16.8	16.5	14.7	12.1
		MCDBR	16.3	17.5	18.3	19.9	19.7	20.1	19.0	19.1	22.3	21.3	19.2	14.4
		MCWBR	10.0	10.4	10.2	10.2	9.5	8.7	7.8	8.0	9.4	10.0	10.7	9.2
		MCDBR	12.4	14.3	15.2	17.0	17.0	18.0	17.0	17.2	19.0	16.9	14.8	8.4
	5% WB	MCWBR	8.4	9.3	9.0	9.2	8.6	8.2	7.4	7.5	8.4	8.5	9.2	6.3
Clear-Sky Solar Irradiance	taub		0.320	0.325	0.324	0.350	0.360	0.345	0.355	0.342	0.343	0.339	0.316	0.311
	taud		2.519	2.511	2.512	2.423	2.410	2.466	2.452	2.471	2.470	2.498	2.537	2.560
	Ebn at Noon		873	913	945	931	921	931	919	927	911	884	872	862
	Edh at Noon		80	90	98	114	117	111	112	107	101	90	77	72
All-Sky Solar Radiation	RadAvg		2.56	3.48	4.92	6.26	7.41	8.19	7.92	7.16	5.96	4.37	3.01	2.28
	RadStd		0.31	0.39	0.43	0.53	0.38	0.27	0.18	0.17	0.16	0.24	0.16	0.30