

EVERGLADES CITY 5 NE, FL, USA

WMO: 752040

Lat: 25.8996N

Lon: 81.3183W

Elev: 4

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 92826

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 40.8	(c) 44.9	(d) 31.0	(e) 25.2	(f) 54.5	(g) 35.6	(h) 30.6	(i) 53.0	(j) 9.5	(k) 65.0	(l) 8.7	(m) 65.6	(n) 1.4	(o) N/A	(p) 0.274

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 15.6	(c) 94.1	(d) 78.3	(e) 92.8	(f) 77.9	(g) 91.6	(h) 77.6	(i) 80.5	(j) 89.2	(k) 80.1	(l) 88.6	(m) 79.6	(n) 87.8	(o) 3.0	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.7	149.1	82.6	78.2	146.4	82.5	77.6	143.4	82.3	44.0	89.4	43.5	88.4	43.0	88.0	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.5	(b) 7.2	(c) 6.5	(e) 34.0	(f) 96.4	(g) 4.6	(h) 1.3	(i) 30.7	(j) 97.3	(k) 28.0	(l) 98.1	(m) 25.4	(n) 98.8	(o) 22.1	(p) 99.7		
(a) 8.5	(b) 7.2	(c) 6.5	(e) 33.0	(f) 81.9	(g) 4.2	(h) 0.7	(i) 29.9	(j) 82.4	(k) 27.5	(l) 82.8	(m) 25.1	(n) 83.2	(o) 22.0	(p) 83.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.5	64.3	68.0	69.3	74.4	77.9	81.7	83.2	83.7	82.7	78.8	71.7	69.2
	DBStd	8.17	7.60	7.07	5.94	4.02	3.00	2.36	1.99	1.82	1.95	4.35	6.10	7.06
	HDD50	8	5	1	0	0	0	0	0	0	0	0	0	2
	HDD65	254	106	50	31	3	0	0	0	0	0	2	17	45
	CDD50	9301	449	506	599	731	866	952	1029	1046	981	894	651	597
	CDD65	4074	85	135	166	285	401	502	564	581	531	431	218	175
	CDH74	36650	556	982	1432	2587	3687	4748	5627	5912	4974	3617	1484	1044
	CDH80	14114	80	229	371	968	1614	2120	2433	2448	1916	1305	398	232
(14) Wind	WSAvg	2.5	2.5	2.6	3.0	2.9	2.7	2.3	1.9	2.0	2.2	2.7	2.6	2.4
(15) Precipitation	PrecAvg	52.8	1.6	1.6	1.9	1.8	3.6	10.5	7.9	8.1	8.8	4.0	1.7	1.4
	PrecMax	77.5	6.1	7.0	8.9	6.3	10.2	23.5	15.6	16.1	18.5	12.2	10.4	7.8
	PrecMin	32.5	0.1	0.0	0.0	0.0	0.2	2.8	2.4	2.8	3.1	0.1	0.1	0.0
	PrecStd	10.5	1.4	1.6	1.9	1.5	2.3	5.0	3.2	3.4	3.9	2.7	1.9	1.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.1	87.4	88.7	92.0	93.8	95.3	95.4	95.4	94.1	92.7	90.4	87.4
		MCWB	72.2	72.9	72.6	74.3	74.4	78.2	79.4	79.5	78.8	77.7	76.3	74.8
	2%	DB	82.3	85.1	86.1	89.5	91.5	93.4	93.4	93.6	92.2	90.5	87.0	84.8
		MCWB	70.6	71.8	71.0	73.7	74.6	78.0	78.7	78.7	78.3	77.1	75.0	73.5
	5%	DB	80.0	83.1	84.2	87.6	89.9	91.8	91.9	92.2	90.8	88.7	84.4	82.8
		MCWB	69.1	70.9	70.3	72.7	74.5	77.8	78.4	78.7	78.0	76.3	73.1	72.3
	10%	DB	77.4	80.7	82.0	85.8	88.2	90.0	90.5	90.7	89.2	86.9	82.0	80.3
		MCWB	67.7	69.9	69.6	71.8	74.1	77.3	78.2	78.7	77.8	75.2	71.3	70.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.2	75.2	75.6	77.7	79.0	81.0	81.3	81.3	80.9	79.9	78.2	76.9
		MCDB	81.6	83.2	83.6	88.0	89.5	90.8	91.5	90.1	88.8	85.9	85.5	84.0
	2%	WB	72.7	73.7	74.2	76.6	77.6	80.0	80.3	80.5	80.2	78.9	76.7	75.3
		MCDB	79.5	82.0	82.1	86.5	87.7	89.4	89.7	88.7	87.9	86.2	84.6	82.2
	5%	WB	71.2	72.5	72.9	75.2	76.6	79.2	79.7	80.1	79.5	78.1	75.3	73.9
		MCDB	77.5	80.5	80.8	84.4	86.1	88.2	88.6	88.2	87.2	85.1	82.7	80.7
	10%	WB	69.5	71.1	71.3	74.0	75.5	78.4	79.1	79.5	78.9	77.2	73.9	72.3
		MCDB	75.0	78.7	79.2	82.8	84.5	86.9	87.5	87.2	86.1	83.7	79.7	78.3
(35) Mean Daily Temperature Range	5% DB	MDBR	22.3	22.7	24.2	23.8	21.7	17.8	16.3	15.6	14.9	16.4	20.3	20.5
		MCDBR	23.0	23.1	24.4	25.6	23.6	20.1	18.1	17.6	16.4	17.1	19.9	20.1
		MCWBR	11.7	10.8	11.0	10.8	8.8	7.0	6.2	5.9	5.4	5.9	8.4	9.6
	5% WB	MCDBR	19.7	21.1	21.1	22.2	20.5	18.2	17.2	16.2	15.1	15.6	18.1	18.1
		MCWBR	11.5	10.6	11.0	10.2	8.3	6.8	6.3	6.0	5.5	5.8	7.8	9.2
(40) Clear-Sky Solar Irradiance	taub		0.355	0.370	0.382	0.396	0.425	0.452	0.462	0.454	0.426	0.406	0.370	0.359
	taud		2.525	2.490	2.439	2.378	2.348	2.349	2.311	2.367	2.428	2.456	2.503	2.537
	Ebn at Noon		285	288	290	287	276	267	264	267	272	273	278	279
	Edh at Noon		30	33	36	39	40	40	42	39	36	33	30	28
(44) All-Sky Solar Radiation	RadAvg		1197	1468	1783	2032	2055	1854	1850	1760	1592	1495	1288	1117
	RadStd		83	85	93	93	155	164	106	82	97	86	64	76

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.70	+1.64	N/A	N/A	N/A	N/A	N/A	-34	+239	+202

Nomenclature: See separate page