

EDINBURG 17 NNE, TX, USA

WMO: 752550

Lat: 26.5258N

Lon: 98.0633W

Elev: 64

StdP: 14.66

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12987

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.9	38.8	18.2	13.8	52.5	23.0	17.4	53.1	18.1	76.7	16.3	75.3	4.7	N/A	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.8	100.4	76.1	98.7	76.3	97.1	76.3	80.4	87.4	79.8	87.8	79.2	87.7	8.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	153.0	81.7	78.3	147.1	81.4	77.4	142.9	81.3	44.1	86.1	43.2	87.7	42.6	87.7	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.6	13.9	12.5	29.7	103.9	3.6	2.6	27.1	105.8	25.0	107.2	23.0	108.7	20.4	110.5		
			27.5	81.9	2.8	1.9	25.4	83.3	23.8	84.4	22.2	85.5	20.2	86.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.8	59.8	64.9	70.3	75.6	80.7	84.8	85.7	86.6	82.6	76.4	67.6	61.5
	DBStd	11.57	9.57	10.21	8.02	6.35	4.94	2.81	2.76	2.68	3.81	6.77	8.93	9.60
	HDD50	61	26	12	2	0	0	0	0	0	0	0	4	17
	HDD65	660	216	120	44	8	0	0	0	0	0	8	77	187
	CDD50	9096	330	430	632	768	951	1045	1106	1135	977	817	533	372
	CDD65	4221	56	118	209	326	486	595	641	670	527	360	156	77
	CDH74	44923	407	857	1591	2943	5067	7055	7816	8360	5390	3582	1300	555
	CDH80	21622	83	277	542	1200	2322	3686	4199	4635	2588	1557	415	118
Wind	WSAvg	5.8	5.7	6.5	6.9	7.0	6.8	6.2	5.9	5.3	4.2	4.8	5.1	5.2
Precipitation	PrecAvg	21.5	0.9	0.8	1.2	1.4	2.1	2.3	2.0	1.7	4.5	2.2	1.2	1.0
	PrecMax	32.7	3.9	3.1	3.9	4.5	5.6	10.0	10.7	5.5	9.8	7.8	3.3	4.3
	PrecMin	7.3	0.1	0.0	0.1	0.0	0.1	0.1	0.0	0.1	0.2	0.2	0.0	0.0
	PrecStd	5.6	0.8	0.9	1.0	1.3	1.5	2.0	2.7	1.4	2.6	1.8	1.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.1	91.6	94.3	97.0	97.6	101.2	101.8	102.4	100.7	95.9	91.1	86.4
		MCWB	67.2	67.3	68.5	72.2	75.8	76.3	75.8	76.0	74.2	74.4	72.9	71.0
	2%	DB	82.3	86.9	88.8	92.4	95.2	98.1	99.9	100.6	97.4	93.1	87.7	83.6
		MCWB	66.0	68.9	70.9	73.2	76.3	76.7	76.2	76.4	75.6	74.3	72.1	69.4
	5%	DB	78.8	83.5	85.8	89.8	93.3	96.4	97.9	99.0	94.9	91.0	85.1	80.3
		MCWB	64.2	68.7	70.1	72.6	75.7	76.7	76.5	76.6	75.8	74.2	70.9	68.0
	10%	DB	74.9	79.6	82.7	87.1	91.0	94.6	95.7	97.0	92.4	88.6	82.0	76.7
		MCWB	63.8	67.1	68.6	72.1	75.1	76.7	76.5	76.8	76.0	73.4	70.1	68.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.3	73.0	74.4	81.2	80.4	81.6	81.1	80.9	80.7	80.3	78.0	77.8
		MCDB	79.1	83.7	83.3	84.8	88.2	88.9	86.8	88.7	86.3	84.0	81.3	78.8
	2%	WB	69.9	71.6	73.2	77.7	79.2	80.2	80.0	79.9	79.6	78.2	76.0	73.0
		MCDB	76.6	80.2	82.6	86.1	88.3	88.7	87.3	88.9	86.9	85.0	82.7	79.1
	5%	WB	68.4	70.8	72.1	75.9	78.2	79.3	79.1	79.2	78.8	77.2	74.1	71.2
		MCDB	74.3	78.7	80.3	84.6	86.8	88.4	87.4	88.9	86.5	84.9	81.2	77.2
	10%	WB	66.5	69.9	71.1	74.4	77.4	78.6	78.4	78.4	78.2	76.2	72.4	69.6
		MCDB	72.3	76.7	78.5	82.4	85.6	87.4	87.3	88.6	86.0	83.9	79.0	75.2
Mean Daily Temperature Range	5% DB	MDBR	21.9	21.6	21.2	21.4	19.7	20.3	20.4	21.8	19.4	22.1	22.0	20.8
		MCDBR	24.8	24.0	22.6	23.1	21.2	22.4	23.4	24.0	23.0	22.6	23.0	23.3
		MCWBR	12.2	9.2	7.6	8.4	5.1	4.6	4.5	4.7	5.8	7.9	9.6	11.6
	5% WB	MCDBR	20.0	19.6	19.0	19.3	17.0	18.8	20.0	22.2	17.8	19.5	19.9	20.0
		MCWBR	12.0	9.4	8.1	7.9	5.7	5.5	5.2	5.2	5.8	7.8	9.5	12.9
Clear-Sky Solar Irradiance	taub	0.351	0.369	0.391	0.422	0.436	0.423	0.429	0.424	0.425	0.379	0.369	0.350	
	taud	2.475	2.413	2.356	2.280	2.280	2.374	2.362	2.385	2.350	2.473	2.447	2.480	
	Ebn at Noon	285	288	286	279	273	275	273	275	272	281	276	280	
	Edh at Noon	30	35	39	43	43	39	39	38	39	32	31	29	
All-Sky Solar Radiation	RadAvg	990	1200	1468	1739	1894	2113	2101	2010	1661	1446	1112	891	
	RadStd	110	189	173	161	142	80	147	95	129	146	121	127	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	+218	+205

Nomenclature: See separate page