

TORREY 7 E, UT, USA

WMO: 755710

Lat: 38.3028N

Lon: 111.2935W

Elev: 6204

StdP: 11.69

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 53149

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.6	13.2	-6.0	5.0	24.0	-2.9	5.9	29.3	13.0	31.1	12.0	31.1	5.0	N/A	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	91.1	54.9	89.1	54.7	87.0	54.3	61.2	74.1	60.1	74.7	59.1	75.1	6.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	89.1	65.7	55.4	82.5	65.7	53.2	75.9	66.9	30.5	73.8	29.5	74.4	28.7	75.0	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.5	9.0	3.6	94.6	3.8	1.4	0.8	95.6	-1.4	96.4	-3.6	97.2	-6.3	98.2		
(5)			1.3	64.2	3.7	0.9	-1.4	64.9	-3.6	65.5	-5.7	66.0	-8.4	66.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	29.4	34.3	43.1	48.9	56.8	70.6	74.7	72.2	65.2	51.3	39.7	28.8		
	DBStd	17.53	7.67	8.58	7.38	7.64	7.61	6.87	4.17	4.35	6.27	7.71	8.19	8.22		
	HDD50	2510	638	441	236	112	28	0	0	0	2	76	319	658		
	HDD65	5805	1103	859	678	483	267	30	1	4	70	427	760	1123		
	CDD50	2998	0	2	23	79	241	617	766	687	459	115	9	0		
	CDD65	819	0	0	0	0	14	197	302	227	77	2	0	0		
	CDH74	8819	0	0	0	13	202	2527	3092	2162	805	18	0	0		
	CDH80	3219	0	0	0	0	25	1030	1260	739	164	1	0	0		
(14) Wind	WSAvg	5.0	4.3	4.8	5.3	5.7	5.4	5.6	5.2	5.0	5.1	5.0	4.8	4.3		
(15) Precipitation	PrecAvg	8.1	0.5	0.5	0.5	0.6	0.5	0.5	0.7	1.3	0.8	1.1	0.4	0.4		
	PrecMax	11.9	1.9	2.0	1.3	2.1	2.0	1.9	1.8	2.7	3.1	4.5	1.9	0.9		
	PrecMin	4.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.1	0.0	0.1		
	PrecStd	2.2	0.6	0.6	0.4	0.6	0.5	0.4	0.5	0.6	0.8	1.1	0.5	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	59.6	70.1	76.3	83.5	93.9	93.1	91.3	87.9	76.5	64.0	52.4		
		MCWB	37.7	41.2	45.0	47.1	50.8	55.0	56.2	54.8	54.0	49.8	43.7	38.8		
	2%	DB	47.0	55.7	64.8	71.5	79.0	91.3	91.1	88.9	84.3	71.8	59.4	48.0		
		MCWB	35.3	39.6	43.2	45.6	49.0	54.4	55.6	54.4	53.4	48.2	42.4	36.5		
	5%	DB	43.2	51.4	61.0	67.9	76.0	89.0	89.2	86.8	81.5	68.1	56.5	44.2		
		MCWB	33.3	37.7	41.5	44.5	47.9	53.3	55.9	54.5	52.4	47.1	40.9	35.2		
	10%	DB	40.2	47.5	56.9	64.1	72.5	86.3	87.1	84.5	79.0	64.5	53.3	41.0		
		MCWB	31.5	36.4	39.7	43.2	47.0	52.4	55.6	55.0	51.9	45.7	39.3	33.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.2	43.0	46.0	48.9	52.5	58.7	63.5	62.5	60.1	54.4	46.1	41.1		
		MCDB	50.6	56.7	68.5	70.0	76.0	83.8	74.0	73.3	70.6	66.9	59.8	49.0		
	2%	WB	36.2	40.9	44.1	47.3	50.3	56.8	61.6	61.0	58.3	51.2	43.3	39.2		
		MCDB	44.6	53.5	63.9	69.1	73.8	84.0	74.7	72.8	69.9	63.5	56.9	45.1		
	5%	WB	34.3	39.2	42.4	45.6	48.9	55.3	60.5	59.8	56.5	49.4	41.4	37.1		
		MCDB	41.8	50.8	60.1	65.6	71.7	83.9	75.5	73.1	70.7	62.9	55.1	43.6		
	10%	WB	32.6	37.2	40.6	44.0	47.7	53.8	59.7	58.6	55.0	47.8	39.4	34.3		
		MCDB	39.3	47.8	56.5	63.1	69.5	82.0	76.2	73.8	71.8	61.6	51.8	41.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	16.7	20.2	21.7	21.6	24.8	22.1	21.7	22.3	19.7	17.8	14.1		
		MCDBR	17.2	20.5	24.9	26.2	26.0	26.8	25.2	24.6	25.4	23.5	20.9	17.2		
		MCWBR	10.4	10.5	11.3	11.1	9.7	9.5	8.0	7.9	9.4	10.2	10.9	10.4		
	5% WB	MCDBR	15.7	18.5	23.1	24.4	23.6	18.9	19.2	19.6	18.6	20.0	15.8			
		MCWBR	10.2	10.0	10.8	10.6	9.3	8.8	7.0	7.5	8.4	8.8	10.7	10.2		
(40) Clear-Sky Solar Irradiance	taub		0.240	0.252	0.264	0.291	0.304	0.298	0.346	0.344	0.299	0.278	0.248	0.241		
	taud		2.571	2.547	2.532	2.438	2.454	2.485	2.392	2.402	2.522	2.544	2.587	2.586		
	Ebn at Noon		308	316	320	313	309	309	294	292	303	301	302	300		
	Edh at Noon		23	27	30	35	35	34	37	36	30	26	22	21		
(44) All-Sky Solar Radiation	RadAvg		850	1127	1576	1990	2261	2548	2184	1952	1771	1338	961	737		
	RadStd		67	90	100	102	159	164	122	110	96	105	65	56		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page